



PRIMARY EFFLUENT FILTRATION

**FINAL REPORT 05 -08
APRIL 2005**

**NEW YORK STATE
ENERGY RESEARCH AND
DEVELOPMENT AUTHORITY**





The New York State Energy Research and Development Authority (NYSERDA) is a public benefit corporation created in 1975 by the New York State Legislature. NYSERDA's responsibilities include:

- Conducting a multifaceted energy and environmental research and development program to meet New York State's diverse economic needs.
- Administering the **New York Energy SmartSM** program, a Statewide public benefit R&D, energy efficiency, and environmental protection program.
- Making energy more affordable for residential and low-income households.
- Helping industries, schools, hospitals, municipalities, not-for-profits, and the residential sector, including low-income residents, implement energy-efficiency measures.
- Providing objective, credible, and useful energy analysis and planning to guide decisions made by major energy stakeholders in the private and public sectors.
- Managing the Western New York Nuclear Service Center at West Valley, including: (1) overseeing the State's interests and share of costs at the West Valley Demonstration Project, a federal/State radioactive waste clean-up effort, and (2) managing wastes and maintaining facilities at the shut-down State-Licensed Disposal Area.
- Coordinating the State's activities on energy emergencies and nuclear regulatory matters, and monitoring low-level radioactive waste generation and management in the State.
- Financing energy-related projects, reducing costs for ratepayers.

NYSERDA administers the **New York Energy SmartSM** program, which is designed to support certain public benefit programs during the transition to a more competitive electricity market. Some 2,700 projects in 40 programs are funded by a charge on the electricity transmitted and distributed by the State's investor-owned utilities. The **New York Energy SmartSM** program provides energy efficiency services, including those directed at the low-income sector, research and development, and environmental protection activities.

NYSERDA derives its basic research revenues from an assessment on the intrastate sales of New York State's investor-owned electric and gas utilities, and voluntary annual contributions by the New York Power Authority and the Long Island Power Authority. Additional research dollars come from limited corporate funds. Some 400 NYSERDA research projects help the State's businesses and municipalities with their energy and environmental problems. Since 1990, NYSERDA has successfully developed and brought into use more than 170 innovative, energy-efficient, and environmentally beneficial products, processes, and services. These contributions to the State's economic growth and environmental protection are made at a cost of about \$.70 per New York resident per year.

Federally funded, the Energy Efficiency Services program is working with more than 540 businesses, schools, and municipalities to identify existing technologies and equipment to reduce their energy costs.

For more information, contact the Communications unit, NYSERDA, 17 Columbia Circle, Albany, New York 12203-6399; toll-free 1-866-NYSERDA, locally (518) 862-1090, ext. 3250; or on the web at www.nyserdera.org

STATE OF NEW YORK
George E. Pataki
Governor

ENERGY RESEARCH AND DEVELOPMENT AUTHORITY
Vincent A. DeIorio, Esq., Chairman
Peter R. Smith, President

PRIMARY EFFLUENT FILTRATION

FINAL REPORT

Prepared for the
**NEW YORK STATE
ENERGY RESEARCH AND
DEVELOPMENT AUTHORITY**

Albany, NY
www.nyserda.org

Gregory Lampman, PE
Project Manager

and

NIAGAGA COUNTY SEWER DISTRICT No.1

Niagara Falls, NY

Frank A. Nerone, PE
Project Manager

Prepared by
WENDEL DUCHSCHERER ARCHITECTS & ENGINEERS, PC

Amherst, NY
www.wd-ae.com

Jeffrey D. Telecky
Project Manager

NOTICE

This report was prepared by Wendel Duchscherer Architects & Engineers, PC in the course of performing work contracted for and sponsored by the New York State Energy Research and Development Authority, and the Niagara County Sewer District No. 1, (hereafter the "Sponsors"). The opinions expressed in this report do not necessarily reflect those of the Sponsors or the State of New York, and reference to any specific product, service, process, or method does not constitute an implied or expressed recommendation or endorsement of it. Further, the Sponsors and the State of New York make no warranties or representations, expressed or implied, as to the fitness for particular purpose or merchantability of any product, apparatus, or service, or the usefulness, completeness, or accuracy of any processes, methods, or other information contained, described, disclosed, or referred to in this report. The Sponsors, the State of New York, and the contractor make no representation that the use of any product, apparatus, process, method, or other information will not infringe on privately owned rights and will assume no liability for any loss, injury, or damage resulting from, or occurring in connection with, the use of information contained, described, disclosed, or referred to in this report.

ABSTRACT

A demonstration project was performed at the Niagara County Sewer District No.1, evaluating the use of coarse, mono-media filtration for the treatment of primary and CSO/SSO type wastewater. A secondary objective of the project was to quantify the benefits of mono-media filtration compared to mixed-media filtration with regard to wet weather hydraulic capacity, solids removal efficiency, energy use and operational costs. An evaluation of coarse mono-media filtration versus standard mixed-media filtration was performed and a mono-media filtration system was installed. In a second phase of the project, additional piping was installed to allow the District to directly filter primary treated and CSO/SSO type wastewater. The demonstration project revealed several significant benefits of coarse, mono-media filtration, including the following:

- The hydraulic capabilities of the filters were increased with the capability to treat a peak hydraulic loading of 10 gpm/sf with mono-media filtration compared to 3.8 gpm/sf with mixed-media filtration.
- The mono-media filtration system was shown to save approximately 184,662 kWh per year based on an average flow of 6.8 MGD.
- The mono-media filtration system has reduced effluent TSS and BOD discharge levels by 55% and 21% respectively.
- The mono-media filtration system was shown to enhance the performance of the existing liquid chlorine disinfection system. The 7 and 30-day effluent fecal coliform levels have been reduced by 55% and 26%, respectively.
- The mono-media filtration system was also shown to increase wet weather treatment capacity while minimizing capital costs compared to the elimination of wet weather flow by rehab and repair measures in the collection system.
- Mono-media filtration was shown to be a viable treatment option for primary treated wastewater with a 75% TSS removal rate at a filtration rate of 4.13 gpm/sf.
- Mono-media filtration was shown to be a viable treatment option for SSO/CSO with a 77% TSS removal rate of 4.89 gpm/sf.

Keywords: Mono-media, deep bed filtration, sand filters, filter backwash, tertiary filtration, wet weather treatment

TABLE OF CONTENTS

| <u>SECTION</u> | <u>PAGE</u> |
|---|--------------------|
| SUMMARY | S-1 |
| 1 INTRODUCTION | 1-1 |
| 2 MIXED-MEDIA VERSUS MONO-MEDIA FILTRATION..... | 2-1 |
| 3 PROJECT CONSTRUCTION..... | 3-1 |
| 4 ANALYSIS OF PROJECT RESULTS | 4-1 |
| Filter Comparison | 4-1 |
| CSO / SSO Results | 4-6 |
| 5 ENERGY, ECONOMIC AND ENVIRONMENTAL BENEFITS | 5-1 |
| Energy Savings | 5-1 |
| Chlorine Reduction..... | 5-2 |
| Environmental Benefits | 5-2 |
| 6 PROJECTED RESULTS VERSUS ACTUAL RESULTS | 6-1 |
| 7 DEMONSTRATION PROJECT SUMMARY AND CONCLUSIONS | 7-1 |
| | |
| Appendix A Cost Analysis of Wet Weather Treatment vs Removal..... | A-1 |
| Appendix B Total Suspended Solids Summary..... | A-2 |
| Appendix C Fecal Coliform Summary | A-3 |
| Appendix D Treatment Plant Summary Reports | A-4 |
| Appendix E Phosphorus Summary..... | A-5 |

FIGURES

| <u>Figure</u> | <u>PAGE</u> |
|----------------------|--|
| 1 | Niagara County Sewer District No. 1 – Treatment Plant..... 1-1 |
| 2 | Previous Filter-Media 2-1 |
| 3 | Clay Underdrain Tile 2-1 |
| 4 | Comparison of Mono-Media versus Anthracite..... 2-4 |
| 5 | Comparison of Effluent Total Suspended Solids 4-3 |
| 6 | Effluent Total Suspended Solids During Wet Weather Events..... 4-5 |

TABLES

| <u>Table</u> | <u>PAGE</u> |
|---------------------|---|
| 1 | Comparison of Filter-Media 2-4 |
| 2 | Filter Hydraulic Loading Rates and Run Times 4-1 |
| 3 | Filter Effluent Comparison 4-2 |
| 4 | Niagara County Sewer District No. 1 - Demonstration Project Results 4-4 |
| 5 | Filter Backwash Energy Comparison 5-2 |
| 6 | Total Suspended Solids Removal Cost Comparison..... 5-3 |
| 7 | Inflow/Infiltration Management Options 5-5 |
| 8 | Cost Per Pound of TSS Removed 5-5 |
| 9 | Projected versus Actual Results..... 6-1 |
| 10 | Summary of Results..... 7-1 |

SUMMARY

The Niagara County Sewer District No. 1 (NCS D No.1) operates an activated sludge treatment plant (with tertiary filtration facilities) that was designed for an average daily flow rate of 14 MGD. In 1998, the Niagara County Sewer District No. 1 decided to initiate an upgrade of its existing gravity sand filters. The District proceeded to replace its existing mixed-media sand filters with deep bed, mono-media sand filters. Under this demonstration project, co-founded by the New York State Energy Research and Development Authority (NYSERDA), the District proceeded to install bypass piping to allow for the filtration of primary and combined sewer overflow/sanitary sewer overflow (CSO/SSO) type wastewater during wet weather storm events.

Operational data collected since the startup of the new filter system has highlighted that the mono-media system provided longer filter run times, improved effluent quality, reduced energy consumption, reduced backwash flow rates, and reduced bleach use for disinfection. It was therefore desired to quantify the performance of mono-media filtration versus mixed-media filtration during the demonstration project for the following items:

- Hydraulic capacities during wet weather events
- Energy use related to the filtration and backwash process
- Effluent quality and receiving body impact
- Performance of existing disinfection systems.

The following objectives were also evaluated for mono-media filtration:

- Show the opportunity to increase wet weather capacity while minimizing capital investment
- Show treatability of primary wastewater utilizing mono-media filtration
- Show treatability of CSO/SSO type wastewater utilizing mono-media filtration.

The demonstration project was a success, quantifying the increased hydraulic capacity and treatment performance of mono-media filtration as well as highlighting the potential for mono-media filtration to provide advanced treatment of CSO and SSO type wastewater. Table S-1, presented on the following page provides a summary of the results obtained during the demonstration project.

Table S-1 Summary of Results

| Item | Mixed-Media | Mono-Media |
|--|---------------------|-------------------------|
| Peak Hydraulic Loading | 3.8 gpm/sf | 10 gpm/sf |
| Backwash Energy Savings of Mono-Media vs Mixed-Media | - | 142,548 kW-hrs per year |
| Energy Savings of Dry/Wet Weather Control System | | 42,114 kW-hrs per year |
| Effluent TSS | 6.24 mg/L | 2.81 mg/L |
| Chlorine for Disinfection | 52,200 gal per year | 43,475 gal per year |
| Effluent Fecal Coliform (7 Day Avg) | 143 CFU / 100 ml | 63 CFU / 100 ml |
| TSS Removal (Primary Wastewater) | - | 75 Percent |
| TSS Removal (CSO/SSO Wastewater) | - | 77 Percent |
| Total Operational & Energy Savings (Compared to Mixed-Media System) | - | \$27,420 per year |
| Cost per lb TSS Removed | \$0.358 | \$0.175 |

As highlighted in Table S-1, the mono-media filtration system outperformed traditional mixed-media filters related both to treatment performance and to operational costs. Mono-media filtration was also shown to remove 75 to 77% of total suspended solids (TSS) for primary treated or “CSO/SSO type wastewater” highlighting its promise as an advanced treatment technology.

The total operational cost savings of approximately \$27,420 per year, results in a payback of approximately 13 years for the added cost of the mono-media conversion compared to replacement with mixed-media. The mono-media filtration system removed substantially more suspended solids than the previous mixed-media filtration system resulting in significantly lower cost per lb of TSS removed. The mono-media filtration system has been in operation for 6 years and removed approximately 96,310 lbs of TSS per year. Basing savings on both filter systems removing 96,310 lbs of TSS over one year, the mono-media filtration system would save approximately \$43,460 resulting in a payback of 7.5 years.

The following conclusions are made based on the results of this demonstration project:

- Mono-media filtration is an excellent option for wastewater treatment plants that have capacity problems related to wet weather flows. The operational and energy savings when compared to traditional mixed-media filtration can help offset the capital cost of the upgrade.
- Mono-media filtration is a cost effective and energy-efficient process for treating CSO and SSO type wastewater.
- Mono-media filtration removes TSS at a substantially cheaper cost per lb. than mixed-media filtration and therefore should be considered for all new wastewater treatment plants as well as rehabilitating existing treatment plants.
- Mono-media filtration is an effective tool to help increase the efficiency of existing liquid bleach disinfection systems.

Section 1

INTRODUCTION

All wastewater treatment plants are challenged to meet capacity requirements related to infiltration and inflow events which cause degradation of effluent discharges to receiving streams, and limits plant capacities. Most sanitary sewer systems tributary to these areas have overflow points in the collection system that bypass sewage to adjacent water streams resulting in negative impacts on the environment. The United States Environmental Protection Agency (USEPA) has pending Sanitary Sewer Overflow (SSO) regulations to address these overflows on a national basis.

The Niagara County Sewer District No. 1 (NCS D No.1) operates an activated sludge treatment plant (Figure 1) with tertiary filtration facilities that were designed for an average daily flow rate of 14 MGD. The treatment plant was originally constructed in 1978 and is manned by 18 employees. The plant currently treats about 50% of its design flow on an annual average but experiences significant storm related peak flows up to approximately 32 MGD.

FIGURE 1 – Niagara County Sewer District No.1 Treatment Plant



The NCS D No.1 facility completed a tertiary filter upgrade utilizing mono-media sand and deep bed filtering technology that was recognized statewide with a design excellence award from the New York Association of Consulting Engineers, Inc. Operational data collected since the startup of the new filter system indicated that the mono-media system is capable of successfully filtering primary wastewater and wastewater similar to that discharged from sanitary sewer overflows. In addition, filter performance data

has shown longer filter run times, improved effluent quality, reduced bleach use for disinfection, reduced energy consumption due to longer filter run times, and reduced backwash flow rates.

The outstanding performance of the upgraded filter system has led the NCS D No.1 to believe that additional opportunities exist for use of mono-media filters in the treatment of wastewater discharged during sanitary and combined sewer overflows. The NCS D No.1 decided to undertake a demonstration project with the New York State Energy Research and Development Authority to evaluate the use of mono-media filters for treating primary wastewater, sanitary sewer overflow (SSO) and combined sewer overflow (CSO) type wastewater. The objectives of this demonstration project are as follows:

Comparison of Mono-Media versus Mixed-Media Filtration System

- Quantify increased treatment capabilities within existing facilities
- Quantify energy savings related to filtration process
- Quantify improved effluent quality and receiving water body impact
- Quantify improvement of liquid bleach disinfection system performance
- Show opportunity to increase wet weather treatment capacity while minimizing capital investment.

Demonstration of Mono-Media Filtration for Treatment of Primary and SSO/CSO Type Wastewater

- Show treatability of primary wastewater utilizing mono-media filtration
- Show treatability of SSO/CSO type wastewater using mono-media filtration.

Successful completion of this project would prove to be significant to New York State. A June 1992 NYSDEC publication identifies 152 wastewater treatment plants in New York State with tertiary filters. Most were built in the 1970's with USEPA construction grant funds and they are at, or beyond, their projected service life. All are subject to wet weather flow events from infiltration/inflow with the related operational and treatability problems. Pending SSO regulation will result in large future capital outlays to either treat at SSO points, build interceptors to convey SSO flows to the wastewater treatment plants, and/or increase WWTP capacities. This demonstration project provides an opportunity for a full-scale pilot study to address all of these issues, minimize capital investment, save energy, and improve the environment in the process.

Section 2

MIXED-MEDIA VERSUS MONO-MEDIA FILTRATION

MIXED-MEDIA FILTER SYSTEM

Like most wastewater treatment plants constructed in the 1970s, the NCSD No.1 plant was equipped with mixed-media sand filters. These filters were shown to function adequately during average day loading and flow conditions but failed to provide the level of treatment needed during wet weather, high-flow and high-loading events.

The filtration process at the District treatment plant consisted of three identical mixed-media, gravity sand filters. The three filters are further broken down into two individual cells each for a total of six filter cells. Each filter cell is 31' 9" by 10' 9" for a total filtration area of 2,048 square feet.

The filters boxes were constructed of concrete and housed an underdrain system made of dual lateral, clay tile blocks and three levels of various sized media. This media consisted of:

- a bottom layer of 12-inches of silica gravel for support
- an intermediate layer of 24-inches of silica sand
- a top layer of 12-inches of anthracite coal.

The top layer of anthracite coal was larger than the intermediate layer of silica sand. In theory, the anthracite coal would remove the largest particles in the filter influent while the silica sand would remove the smaller particles that passed through the top layer. In practice, the top layer of anthracite would become blinded during a high-flow event and the filters would need to be taken out of service for cleaning by running a backwash cycle.



FIGURE 2 – Previous Filter Media



FIGURE 3 – Clay Underdrain Tile

The previous filter system was equipped with a water only backwash system with surface wash facilities which used large volumes of water during the backwash cycle and provided limited agitation to the upper media layers during this cleaning process. The large volumes of water resulted in the backwash holding

tanks becoming completely full during a high flow event within an hour. Therefore, the filters had to be taken off-line and bypassed.

ANALYSIS OF ALTERNATIVES

The problem that needed to be addressed was how to equip the NCSD No.1 treatment plant to treat high flow, high-loading conditions in an economical manner. The following three alternatives were evaluated:

- Option 1 - Rehabilitate the existing filters in kind with minor modifications to media size and depth while adding air backwash capabilities
- Option 2 - Construct additional filter beds to provide more treatment capacity
- Option 3 - Modify the existing filters and utilize deep bed, coarse mono-media with simultaneous air and water backwash facilities.

Option 1 – Mixed-Media with Air/Water Backwash

Rehabilitating the existing filters with minor modifications to the media while adding air and water backwash facilities was not selected. This rehabilitation option would have had the following advantages and disadvantages:

Advantages

- Reduced water required for backwash
- Improved cleaning of filter beds

Disadvantages

- Increased potential for loss of media
- No improvement on filter run times
- No improvement of peak loading capacity
- Incorporation of air supply blowers for air backwash cycle.

Option 2 – Additional Mixed-Media Filters with Water Backwash

Construction of additional filters to provide more treatment capacity was not selected. This option had the following advantages and disadvantages:

Advantages

- Improved total flow and treatment capacity due to additional filter surface area

- Elimination of need for air supply blowers (no air and water backwash cycle)

Disadvantages

- Construction of new building required (high capital cost)
- No improvement on filter run times
- Increased total water required for backwash cycles.

Option 3 – Deep Bed Mono-Media with Air/Water Backwash

Modification of the existing filters to deep bed mono-media was selected as the most cost-effective solution to the District's wet weather treatment problems. This option has the following advantages and disadvantages:

Advantages

- Higher peak loading capacity
- Reuse of existing filter footprints
- Reduced water required for backwash
- Elimination of potential for media loss during backwash
- Longer filter run times
- Improved total flow and treatment capacity
- Reduced chlorine for effluent disinfection

Disadvantages

- Incorporation of air supply blowers for air backwash cycle
- Limited experience in New York State.

Option Three was selected as the most cost effective solution. It provided the advantages of higher filtering capacities with longer filter run times while utilizing the same filter footprints. The reduced use of chlorine for disinfection made up for the additional electrical costs of the air supply blowers. The numerous installations of deep bed, coarse mono-media filters in other areas of the Country provided adequate justification for this treatment system despite the limited operating record in New York State.

ADVANTAGES OF MONO-MEDIA SYSTEM

The key to the design of the deep bed, mono-media filtration system was the large diameter media. Table 1 presented below provides a comparison of the characteristics of the mono-media sand versus the anthracite and silica sand in the previous mixed-media system. The large diameter media allows for deeper

penetration of solids into the filter bed providing for utilization of the whole filter volume instead of just the top layers. The deeper bed and the sphericity of media provide more volume for storage of trapped solids, allowing for higher filtration rates and longer run times. Figure 4 highlights the size difference between the large diameter sand and the anthracite from the previous filter system.

Table 1 Comparison of Filter Media

| CHARACTERISTIC | MONO-MEDIA | ANTHRACITE | SILICA SAND |
|------------------------|------------|------------|-------------|
| Filtration System | New | Previous | Previous |
| Effective Size | 2.5 mm | 1.0 mm | 0.5mm |
| Uniformity Coefficient | < 1.35 | < 1.8 | < 1.8 |
| Specific Gravity | 2.65 | 1.55 | 2.65 |
| Sphericity | 0.9 | 0.5 | 0.7 |
| MOH Hardness | 6 | 2.7 | 6 |



FIGURE 4 – Comparison of Mono-Media vs Anthracite

The deep bed, mono-media system that was selected for the NCS No.1 plant included plastic underdrain that interlock eliminating the need for grouting blocks together. The plastic underdrain block also does not contain orifices that plug over time. The filter media consisted of 54 inches of 2.5-mm silica sand and support gravel. The use of only one filter media eliminates the potential of media layers intermixing as was experienced with the previous filter system.

The sphericity of the coarse, mono-media sand allows the filter to be cleaned at lower water and air backwash rates because the round media gyrates and spins against one another causing scraping and scouring action that removes accumulated solids out of the filter bed. The lower water and air backwash rates result in energy savings due to decreased pumping requirements. The coarseness and high density of the mono-media sand makes fluidization of the filter bed impossible at feasible backwash rates. Despite this lack of fluidization during the backwash cycle, the sphericity of the media and the scouring action achieved during the simultaneous air-water backwash provide thorough cleaning without fluidization of the

filter bed. This scouring and scraping action during backwash does lead to higher levels of erosion and decay of soft filter media. This made the selection of a hard, durable filter media an important design characteristic.

There are several advantages to not fluidizing the filter bed during the backwash cycle. First, no media is washed out of the filters during a backwash as was experienced with mixed-media filtration system. Second, without fluidization of the filter bed, no intermixing of the media and gravel layers take place. The lack of fluidization also allows a deeper layer of media to be utilized because the freeboard between the top of the media and the wash water troughs can be minimized.

The layer of anthracite in the mixed-media filters eroded away over a period of time. The fine particles were either washed away or made their way into the underdrain laterals. Over the course of several years, the fine anthracite particles started to plug the laterals in portions of the underdrain. These plugged areas would cause localized areas of high velocity currents during a backwash leading to increased intermixing and upset of filter media layers. These problems led to the selection of silica sand, with a MOH hardness of six, which has virtually eliminated the erosion of the media.

Another shortcoming of the previous filtration system that was addressed during the course of the design was that it was no longer required to only backwash one filter cell at a time. With the previous system, the backwash facilities were only sized to backwash one filter cell at a time causing one filter, made up of two cells, to be out of service for a longer time period than would otherwise be necessary. This situation provided additional stress on the two on-line filters during a backwash. The goal to backwash two filter cells at one time was an additional reason that a simultaneous air-water backwash system was desirable. The simultaneous air-water backwash system cleans the filter media with water rates in the neighborhood of 6 gpm/sf instead of 20 gpm/sf as was required with the previous filter system.

Due to the aforementioned limitations of the previous backwash system and the concerns about the underdrain age, a complete retrofit, including replacement of the underdrain and incorporation of an air-water backwash system was selected. HDPE underdrain block replaced the clay tile underdrain. This HDPE jacketed underdrain is specifically designed for wastewater, unlike the previous clay tile underdrain that is utilized in both water and wastewater applications. The underdrain selected is shaped to ensure uniform distribution of air during a backwash and does not contain any orifices to plug with solids or biological growth. The underdrain also interlocks together, eliminating the need for grouting between the individual blocks and associated future maintenance issues.

The existing relay/drum timer filter control system was also upgraded as part of the project to a PC/PLC driven automated control system. The new automated control system provides increased flexibility while

requiring less operator attention. The filter control system allows each filter to be controlled by level or flow of water through the filters by modulating the effluent valves. The control system also automatically limits the number of filter feed pumps that are running during a backwash to keep from overwhelming the remaining online filters.

Backwashing is initiated either automatically, through headloss, time of day, and effluent valve position, or manually by operator initiation. The most energy efficient backwashing event happens automatically and is initiated by effluent valve position. This scenario maximizes the filtering capability of the equipment. The control system and piping layout allow either one or two filter cells to be backwashed simultaneously. Backwashing of one filter cell instead of two is not the standard operating procedure, but is beneficial if it is desired to increase the water backwash rate on filters that are extremely dirty. Backwashing only one filter cell at a time also allows the filters to be backwashed if one air supply blower is out of service. Two blowers are needed if both cells are backwashed simultaneously.

DRY WEATHER / WET WEATHER CONTROL SCHEME

In order to reduce energy usage from pumping during low-flow conditions, a two-mode operational control scheme was developed. The filter control system was designed to operate in either dry weather or wet weather mode. In the dry weather mode, the operating levels of the filters are reduced and the filter feed wet well is run at a higher level. These two factors decrease the amount of static lift that the filter feed pumps provide, thereby reducing pumping energy costs. In wet weather mode, one of the keys to the operation of the filtration system is that all water receives tertiary treatment. In order to ensure that all water receives tertiary treatment, the filters are operated at a higher level while the filter-feed wet-well level is dropped to a lower elevation reducing the threat that bypassing of the filters will occur. The filter-feed wet-well is operated at a lower water level because it overflows to the filter effluent channel at high levels.

PIPING UPGRADES

A second phase of construction was undertaken, as part of this NYSERDA Demonstration Project, that allowed the District to isolate primary treated effluent, which is similar to CSO/SSO type wastewater, directly to the filters while bypassing the filters with the biologically treated effluent. The two treatment trains were then blended and all received disinfection with liquid chlorine before discharge to the Niagara River.

The piping upgrades required to allow the District to isolate the primary treated effluent included construction of approximately 360 linear feet of 36 -inch cement lined ductile iron pipe, two 36" by 36" slide gates, and modifications to the existing high flow channels and filter-feed wet-wells.

Section 3

PROJECT CONSTRUCTION

PHASE 1 – FILTER UPGRADE

The first construction phase of the project started in June of 1998. Wendel Duchscherer performed the design and prepared contract documents including plans and specifications to convert the existing mixed-media filters to deep bed, coarse mono media filters at the Niagara County Sewer District No.1 treatment plant. The project consisted of General Construction and Electrical Construction contracts. The contracts consisted of the following:

1. General Construction Contract
 - Demolition of the existing filter underdrain system and the existing surface wash system
 - Extension of six existing filter gullet walls and raise twenty-four existing filter weir troughs
 - Sandblast and paint filter internals for six filter cells
 - Furnish and install 18” of silica sand support gravel for six filter cells
 - Furnish and install 54” of silica sand for six filter cells
 - Furnish and install air/water underdrain block for six filter cells
 - Construct concrete structural sump in six filter cells
 - Furnish and install one filter air backwash system
 - Furnish and install two 60 horsepower air supply blowers
 - Furnish and install stainless steel air supply piping connecting the blowers to the air backwash distribution system
 - Furnish and install six air valves and electric actuators
 - Furnish and install one PLC based filter control system, three differential pressure transmitters and two ultrasonic level transmitters.

2. Electrical Construction Contract
 - Demolition of three local control panels and one main control panel
 - Provide three new local control panels and one main control panel
 - Provide wiring to all electrical devices.

The contract for the General Construction work was awarded to Kohl Construction, Inc. of Alden, New York for \$565,000. The coarse mono-media filtration system was supplied by Severn Trent (Tetra Technologies) as a sub-contractor to Kohl Construction, Inc. The contract for Electrical Construction was awarded to O’Connell Electric, Inc. of Lancaster, New York for \$30,900.

Construction of the project commenced in May of 1999 and was completed in October of 1999.

Phase 2

The second phase of the project started in June of 2002 with Wendel Duchscherer providing design services including preparation of contract documents, which consisted of drawings and specifications. The project consisted of a General Construction Contract including the following components:

- Provide and install 360 linear feet of 36" cement lined ductile iron gravity sewer piping and five manholes
- Provide and install two new slide gates with electric actuators
- Perform core drilling in the existing concrete walls to allow for connection of piping into the existing filter feed wet well and the high flow routing chamber.

The contract for the General Construction work was awarded to Yarussi Construction, Inc of Niagara Falls, NY for approximately \$140,000. Construction of the project commenced in May of 2003 and was completed in July of 2004.

Section 4

ANALYSIS OF PROJECT RESULTS

The results of the demonstration project and the evaluation of coarse mono-media filtration for treatment of primary treated effluent and SSO/CSO type wastewater at the Niagara County Sewer District No. 1 Water Pollution Control Facility are presented in this section. This includes a comparison of the effectiveness of the mixed-media filters versus the mono-media filters for the following parameters:

Comparison of Mono-Media versus Mixed-Media Filtration System

- Quantify increased treatment capabilities within existing facilities
- Quantify energy savings related to filtration process
- Quantify improved effluent quality and receiving water body impact
- Quantify improvement of liquid bleach disinfection system performance
- Show opportunity to increase wet weather treatment capacity while minimizing capital investment.

Demonstration of Mono-Media Filtration for Treatment of Primary and SSO/CSO Type Wastewater

- Show treatability of primary wastewater utilizing mono-media filtration
- Show treatability of SSO/CSO type wastewater using mono-media filtration.

FILTER COMPARISON

The performance of the mono-media filtration system has been superior to the mixed-media filtration system. The District has experienced increased filtering capacity without sacrificing filter performance. The tertiary filters now treat approximately 2.5 times more water between backwashes while being able to handle a peak hydraulic loading rate that is 2.6 times higher than the previous filter system. As a result of this project, the plant now performs half as many backwashes while filtering more water. Filter bypassing has been virtually eliminated. Table 2 below provides filtering rates and run times for dry weather, wet weather and peak flow, hydraulic loading conditions.

Table 2 Filter Hydraulic Loading Rates and Run Times

| Flow Scenario | Mixed-Media Filters | | Mono-Media Filters | |
|--------------------|----------------------------|---------------------|----------------------------|---------------------|
| | Flow Rate (gpm/sq. ft.) | Run Time (hours) | Flow Rate (gpm/sq. ft.) | Run Time (hours) |
| Dry Weather | 1.7 | 20 | 2.3 | 38 |
| Wet Weather | 2.8 | 10 | 5.3 | 24 |
| Peak Flow | 3.8 | 2 | 10 | 8 |

The District has also experienced the added benefit of increased levels of treatment since startup of the new filter system. Table 3 highlights the enhanced treatment performance of the mono-media filter system. Effluent total suspended solids concentrations have been reduced by 44%, effluent phosphorus concentrations have reduced by 40% and fecal coliform levels in the effluent have been reduced 55% and 26% respectively for 7 day and 30 day averages. The turbidity of the effluent discharged from the treatment plant was enhanced with the upgrade to the mono-media filtration system. The effluent turbidity after the filter improvements was typically 2 Nephelometric Turbidity Units (NTUs) with minimum values of 0.3 NTUs.


In addition to the enhanced performance of the filtration process, the efficiency of the plant's existing disinfection system has increased. The District uses liquid bleach for disinfection, which loses effectiveness when high solids levels are present because the bleach is soaked up by the solids. With lower levels of solids, a larger percentage of the individual bacteria and bacteria in small clumps are destroyed. The reduced suspended solids levels in the filter effluent have resulted in the District utilizing less bleach for disinfection per million gallon of water treated.

Table 3 Filter Effluent Comparison

| <i>Effluent Characteristics</i> | <i>Mono-Media</i> | <i>Mixed-Media</i> |
|---------------------------------|--------------------|--------------------|
| Total Suspended Solids | 3.49 mg/L | 6.24 mg/L |
| Total Phosphorous | 0.21 mg/L | 0.35 mg/L |
| Fecal Coliform (7 day avg) | 63 CFU/100 ml | 143 CFU/100 ml |
| Liquid Bleach Used | 3623 gallons/month | 4350 gallons/month |


The average influent total suspended solids (TSS) loading to the mono-media filters has been 18.2 mg/L with a maximum loading of 44.8 mg/L. With an average filter effluent total suspended solids concentration of 3.49 mg/L the mono-media filters are removing approximately 80% of solids entering the filters. The District is removing greater than 95% of the plant influent total suspended solids. Figure 5 graphically highlights the improved total suspended solids removal performance of the deep bed, mono-media filtration system.

FIGURE 5 Comparison of Effluent Total Suspended Solids



As one of the primary goals of the project was to enhance the performance of the tertiary filters during high flow events, it was necessary to compare the performance of the deep bed, mono-media filtration system against the previous mixed-media filtration system for flows greater than 10 MGD. The comparison data set included 146 days with flow greater than 10 MGD for the mono-media filtration system and 101 days with flows greater than 10 MGD for the mixed-media filtration system. The effluent quality produced by the mono-media filtration system was substantially better than the effluent produced by the mixed-media system during high flow wet weather conditions. The average flow and effluent TSS concentration for the mono-media filtration system was 13.27 MGD and 5.87 mg/L, respectively, while the maximum total suspended solids concentration was 16 mg/l. The average flow and effluent TSS concentration for the mixed-media filtration system was 13.84 MGD and 16.45 mg/L, respectively, while the maximum total suspended solids concentration was 65 mg/L. Figure 6 entitled “Wet Weather Effluent Total Suspended Solids”, presented on the following page, plots effluent total suspended solids concentrations versus flow for the mono-media and mixed-media filtration systems during wet weather flow conditions.

Figure 6 Effluent TSS During Wet Weather Events



CSO/SSO RESULTS

As part of the demonstration project the District installed high flow piping and an inline filter influent sampler that allowed primary and SSO/CSO type wastewater to be sent to the filters directly and the filter influent to be sampled for TSS levels. These improvements allowed the District to evaluate the mono-media filters for their ability to treat primary wastewater and SSO/CSO type wastewater. The influent to the District treatment plant during a wet weather event is similar to an SSO/CSO type wastewater. The 2004 EPA Report to Congress presents sampling data which reports the median municipal Wet Weather SSO TSS concentration at 91 mg/L and the median municipal CSO TSS concentration at 127 mg/L. The wastewater strength is diluted by storm water that makes it way into the sewer system through inflow and infiltration.

During the performance of this demonstration project, a high flow event was considered to be a sampled day when the average daily flow for the NCS D No. 1 WPCC was above 10.0 MGD. There were 78 high flow events evaluated during the six-month demonstration project from January through June of 2004. For the purpose of this demonstration project, filter influent for days when flow was above 10.0 MGD and the filter influent TSS concentration was above 30 mg/L most closely resembled CSO/SSO TSS values and was considered to be “CSO/SSO type wastewater.” Filter influent for days when flow was above 10 MGD and the influent TSS concentration was below 30 mg/L was considered to be primary type wastewater.

Table 4 NCS D No.1 Demonstration Project Results

| Wastewater Type | Influent TSS (mg / L) | Effluent TSS (mg / L) | Percent TSS Removal |
|-----------------|-----------------------|-----------------------|---------------------|
| “CSO/SSO” | 41.8 | 9.4 | 77 % |
| Primary | 20.0 | 4.9 | 75 % |
| Dry Weather | 17.6 | 3.3 | 81% |

As shown in Table 4, the mono-media filters are effective filtering both primary and CSO/SSO type wastewater. The influent to the NCS D No.1 WPCC during wet weather events is similar to SSO type wastewater. Based on TSS removal levels experienced by the District, an effluent TSS concentration of 20.9 mg/L is projected when utilizing mono-media filtration on SSO type wastewater with a TSS concentration of 91.0 mg/L. These results show that deep bed mono-media filters are an effective technique for the treatment of SSO and CSO type wastewater whether used in combination with primary treatment or as a standalone process.

Additional sampling on the removal of Phosphorus was performed during the demonstration project. Samples were collected on eight days with plant influent Phosphorus averaging 9.17 mg/L, filter influent Phosphorus averaging 0.43 mg/L and effluent Phosphorus averaging 0.26 mg/L. The data collected is presented in the appendices of this report.

Section 5

ENERGY, ECONOMIC AND ENVIRONMENTAL BENEFITS

The demonstration project highlighted that the NCS D No. 1 has experienced significant energy and economics savings and environmental benefits through the installation of deep-bed, mono-media filters. The energy savings experienced have been from the reduction of filter backwashes, which has resulted in a reduction of backwash water pumping, a decrease in the operation of wash water pumps, and a reduction of the volume of wash water recycled to the headwork of the treatment plant. Additional energy savings have also been seen due to the use of the dry weather/wet weather operating scheme that reduces pumping heads.

ENERGY SAVINGS

The mono-media filtration system has been shown to reduce the amount of energy used for cleaning of the filters during backwash. The reduced energy savings are due to the following changes in the operation of the backwash operation:

- Decrease in the duration of a backwash cycle reducing water use
- Decrease in the frequency of filter backwash
- Decrease in the rate of water per square foot for a filter backwash
- Decrease in the volume of water recycled to the front end of the plant
- Decrease in energy use due to the dry weather / wet weather control system
- Energy reduction during high flow events due to the use of the dual treatment trains.

Table 5 below compares the energy usage related to filter backwash on an annual basis of the previous mixed-media filtration system versus a deep-bed, mono-media filtration system. The additional solids storage capacity of the deep-bed, mono-media filters has resulted in a 75% reduction in the number of backwashes performed per year. This reduction in the number of backwash events, along with the 70% reduction in the volume of water used per filter backwash, has resulted in a decreased energy usage of approximately 142,548 kW-hrs per year. This energy savings is due to the reduction in pumping of backwash water and recycling of wash water to the front of the treatment plant. Due to typical operation during high flow events, no demand reduction is expected.

Table 5 Filter Backwash Energy Usage

| Filter System | Backwashes Per Year | Backwash Step | kWhrs per Backwash | Annual Energy Use (kWhrs per year) |
|-----------------------------|----------------------------|----------------------|---------------------------|---|
| Mixed-Media | 2190 | Water Backwash* | 66.7 | 146,073 |
| | | Water Pumping | 36.3 | 79,497 |
| Deep-Bed Mono-Media | 548 | Water Backwash* | 10.7 | 58,636 |
| | | Air Scour Cleaning | 23.5 | 12,878 |
| | | Water Pumping | 21.0 | 11,508 |
| Total Yearly Savings | | | | 142,548 |

* These water backwash values are based on the NCS D No.1 filling their elevated storage tank by pumping.

The use of a dry weather/wet weather operating control mode has allowed the District to achieve further energy savings. By operating with lower operating levels in the filters and higher operating water levels in the filter feed wet well, the District reduces the head that the filter feed pumps must overcome by approximately 10 feet. Over the course of one year, assuming that the district is in dry weather mode approximately 50% of the time, 42,114 kW-hrs are saved.

Table 6 Total Annual Energy Savings

| Item | Cost Savings |
|--|---------------------|
| Filter Backwash Energy Savings | \$14,250 |
| Dry Weather/Wet Weather Operating Scheme | \$4,420 |
| Total Savings | \$18,670 |

CHLORINE REDUCTION FOR DISINFECTION

The Sewer District utilizes liquid bleach for disinfection, which loses effectiveness when elevated suspended solids levels are present because the liquid bleach is soaked up by the clumps of solids and does not reach the bacteria organisms. With lower solids levels, a larger percentage of the individual bacteria and bacteria in small clumps are destroyed. The decreased levels of suspended solids in the filter effluent has resulted in the Sewer District utilizing less bleach for disinfection per million gallon of water treated.

The District has experienced a 17% reduction in the use of liquid bleach due to the enhanced removal of effluent suspended solids, which results in an annual savings of approximately \$8,750.

ENVIRONMENTAL BENEFITS

Numerous environmental benefits were demonstrated during the project. They included improving the effluent quality to the Niagara River through reduced effluent TSS, effluent Phosphorous and effluent Fecal Coliform. The reduction of the above mentioned parameters is as follows:

- Effluent Total Suspended Solids concentrations were reduced by 55% which results in the elimination of the discharge of approximately 45 tons of solids to the Niagara River over the course of one year.
- Effluent Phosphorous concentrations were reduced by 40% which results in the elimination of the discharge of 2,690 pounds of phosphorous to the Niagara River over the course of one year.
- Effluent Fecal Coliform concentrations were reduced by 55% which results in a substantial reduction in the Colony Forming Units of Fecal Coliform discharged to the Niagara River. This reduction helps to make the river safer for fishing, boating, water skiing and other forms of water surface recreation.
- Chlorine utilized for disinfection was reduced 17%, which will help reduce the formation of chlorine disinfection by-products in the wastewater effluent. The reduction of chlorine disinfection by-products will help the impact to Niagara River aquatic population.

ECONOMIC BENEFITS

Several parameters were selected at the onset of the project for verification of the cost effectiveness of deep-bed, coarse mono-media filtration. These parameters included the following:

- Treatment performance – required filter square footage versus loading rate. As shown in Table 2, the mono-media filters can treat a peak hydraulic loading of 10 gpm/sf while the mixed-media filters were shown to only treat a peak hydraulic loading of 3.8 gpm/sf. Based on this flow to area relationship, approximately 2.5 square feet of mixed-media filter area is needed for every 1 square foot of mono-media filter area.
- Disinfection system efficiency – comparison of chlorine usage and cost. The mono-media filters were shown to utilize 17% less chlorine for disinfection resulting in annual savings of \$8,750.
- Treatment cost versus inflow and infiltration elimination in collection system. The concerns that have been expressed by the Environmental Protection Agency and other regulatory agencies in the proposed SSO regulations leads one to ponder the cost effectiveness of sewer system repair work to eliminate inflow and infiltration versus the cost of treatment. As part of the demonstration project, the cost of treatment versus removal was evaluated based on the specific conditions experienced by the NCSD No. 1.

In order to provide a thorough and realistic economic evaluation comparing the costs of treating Inflow/Infiltration (I/I) versus locating and eliminating I/I, the Hamlet of Bergholtz, a small sub-area of the NCSD No.1 collection system, was selected for evaluation. Bergholtz was selected because it is a known problem area, with previously measured I/I rates, and a small enough system in size to allow for a reasonable projection of rehabilitation costs.

An evaluation of the NCSD's cost of treatment for a peak day flow was performed. The additional incremental cost of treating a peak flow of 26 MGD was calculated. The following items were used as the basis of the District's increased treatment costs on a peak flow day:

- Increased pumping costs at the remote stations
- Increased pumping costs at the WPCC influent station
- Increased aeration (air supply blower) costs of the activated sludge system
- Increased filter feed pumping costs
- Increased backwash air scour blower costs
- Increased backwash holding tank pumping
- Increased disinfection costs.

The analysis showed that the peak flow event resulted in an additional cost of approximately \$2000 per day for a flow of 26 MGD versus an average-flow of approximately 6.6 MGD. (See Appendix A for peak flow versus average day treatment costs). In order to compare the cost of treating the additional flow versus eliminating it in the distribution system, two I/I control measures were evaluated based on the financial impact to the district. The scenarios were evaluated as follows:

- Utilize the WPCC's existing capacity to treat all incoming flows
- Perform infrastructure and rehabilitation work in the collection system to attempt to eliminate I/I.

An analysis was performed on the Hamlet of Bergholtz sub-area because flow rates and repair costs were readily available. The following assumptions were made:

- The calculation to determine the total I/I for Bergholtz for one year was based on the peak I/I of 7500 gpd/in.mi., or 0.345 MGD, being experienced 365 days a year to determine the treatment cost of the additional flow
- A \$650,000 capital cost was identified for repair costs (See capital cost estimate in appendices)
- The reduction of flow by I/I capital work was based on a 50% effectiveness, meaning a removal of 0.173 MGD and treatment of the remaining 0.173 MGD

The results are of the evaluation are summarized below in Table 7.

Table 7 Inflow/Infiltration Management Options

| Scenario | Flow Treated (MGD) | Treatment Cost | Capital Improvement Costs | Total Annual Cost |
|---------------------------------|---------------------------|-----------------------|----------------------------------|--------------------------|
| Utilize Existing Plant Capacity | 0.345 | \$12,595 per year | \$0 per year | \$12,595 |
| Perform Infrastructure Work | 0.173 | \$6,300 per year | \$65,000 per year* | \$71,300 |

*The capital improvements costs were based on the District bonding the \$650,000 project over 20 years with a 6% annual interest rate with \$65,000 being the first year repayment amount.

Through utilization of the treatment plant’s existing capacity, greatly increased by recent capital projects at the plant, the District can treat all additional wet weather flow at a cost of approximately \$100/MGD. The \$100/MGD was calculated based on the difference in treatment costs for an average day versus a peak day loading condition and is based on the assumption that the fixed costs of the District remain constant while the cost to dewater sludge also remains constant. Utilizing the Bergholtz area as an example, the District can treat all additional flow for \$12,595 per year instead of the \$71,300 per year cost to attempt to eliminate the I/I. Additional information on the calculations utilized during the evaluation can be found in Appendix B.

TSS REMOVAL COSTS

The mono-media filtration system was also shown to remove TSS at half the cost per pound than the mixed-media filtration system. A summary of the removal cost is presented in Table 8 below.

Table 8 Cost Per Pound of TSS Removed

| Filter System | Backwash Energy Costs per Year | Disinfection Costs Per Year | Daily Cost / lb TSS Removed |
|----------------------|---------------------------------------|------------------------------------|------------------------------------|
| Mixed-Media | \$22,550 | \$52,220 | \$0.358 |
| Deep-Bed Mono-Media | \$8,300 | \$43,470 | \$0.173 |
| Total Savings | \$14,250 | \$8,750 | \$0.183 |

Section 6

PROJECTED RESULTS VERSUS ACTUAL RESULTS

In the proposal submitted for this project, several performance goals were provided based on projected performance of the mono-media filtration system. Table 9 below provides a summary of the projected results versus the actual results obtained from the demonstration project.

Table 9 Projected versus Actual Results

| Item | Projected Result | Actual Result |
|--|-------------------------|----------------------|
| Reduced Water per Backwash | 40% | 70% |
| Backwashes per Year | 1095 | 548 |
| Reduction in Disinfection Bleach | 20% | 17% |
| Number of High Flow Events (Flow Greater than 10 MGD) | 10 | 78 |

As highlighted in Table 9, the mono-media filtration system reduced both the number of backwashes per year and the water per backwash significantly more than the projected values. The reduction of bleach utilized for disinfection was slightly less than projected. The amount of bleach added to the effluent has both a manual and an automatic adjustment component. The component of the bleach setpoint that is manually adjusted can effect the amount of bleach added and appears to be the reason the bleach reduction was slightly less than projected.

Other project goals were stated in the proposal but did not include a projected performance level. A summary of the results of these project goals were as follows:

- The hydraulic capabilities of the existing filters were increased with the capability to treat peak hydraulic loadings of 10 gpm/sf versus 3.8 gpm/sf with the previous mixed-media filtration system.
- The mono-media filtration system was shown to save approximately 184,662 kW-hrs per year compared to the mixed-media filtration system.
- Effluent TSS and BOD from the plant were reduced 44% and 21% respectively.
- The mono-media filtration system was shown to enhance the performance of the existing disinfection system. The 7 and 30-day effluent fecal coliform levels were reduced 55% and 26% respectively.
- The mono-media filtration system was also shown to increase wet weather treatment capacity while minimizing capital costs instead of the elimination of wet weather flow by rehab and repair measures in the collection system.

- Mono-media filtration was shown to be a viable treatment option for primary treated wastewater with a 75% TSS removal rate.
- Mono-media filtration was shown to be a viable treatment option for SSO/CSO with a 77% TSS removal rate.

Section 7

DEMONSTRATION PROJECT SUMMARY AND CONCLUSIONS

The demonstration project was a success, quantifying the increased hydraulic capacity and treatment performance of mono-media filtration, as well as highlighting the potential for mono-media filtration to provide advanced treatment of CSO and SSO type wastewater. Table 10 provides a summary of results obtained during the demonstration project.

Table 10 Summary of Results

| Item | Mixed-media | Mono-media |
|---|---------------------|-------------------------|
| Peak Hydraulic Loading | 3.8 gpm/sf | 10 gpm/sf |
| Energy Savings | - | 142,548 kW-hrs per year |
| Effluent TSS | 6.24 mg/L | 2.81 mg/L |
| Chlorine for Disinfection | 52,200 gal per year | 43,475 gal per year |
| Effluent Fecal Coliform (7 Day Avg) | 143 CFU / 100 ml | 63 CFU / 100 ml |
| TSS Removal (Primary Wastewater) | - | 75 Percent |
| TSS Removal (CSO/SSO Wastewater) | - | 77 Percent |
| Total Operational & Energy Savings | - | \$23,000 per year |
| Operating Cost per lb TSS Removed* | \$124.63 | \$51.78 |

* The cost per lb. of TSS removed was based on the energy savings due to reduced backwash requirements and the operation of the dry/wet weather control scheme. Other factors in the treatment process were assumed to remain the same.

As highlighted in Table 10, the mono-media filtration system outperformed traditional mixed-media filters related both to treatment performance and operational costs. Mono-media filtration was also shown to be a promising advanced treatment technology for TSS removal related to both primary treated wastewater and CSO/SSO wastewater.

The following conclusions are made based on the results of this demonstration project:

- Mono-media filtration is an excellent option for wastewater treatment plants that have capacity problems related to wet weather flows. The operational and energy savings when compared to traditional mixed-media filtration can help offset the capital cost of the upgrade.

- Mono-media filtration is a cost-effective and energy-efficient process for treating CSO and SSO type wastewater.
- Mono-media filtration removes TSS at approximately half the cost per lb than mixed-media filtration and therefore should be considered for all new wastewater treatment plants as well as rehabilitating existing treatment plants.
- Mono-media filtration is an effective tool to help increase the efficiency of existing liquid bleach disinfection systems.
- A dry weather/wet weather control scheme is an effective tool to optimize energy efficiency of a filter system and should be investigated for all filtration systems.
- The treatment of wet weather inflow and infiltration was shown to be substantially cheaper than the elimination of inflow and infiltration by collection system repair work. For the pilot area, the cost of treatment of wet weather flow was shown to be \$100 / MGD versus the cost of \$205,000 per MGD for the collection system repair work.

Appendix A
Cost Evaluation of Wet Weather Treatment vs Removal

Bergholz I/I Reduction Costs

| Street | Length of 8" Sewer | Number of Manholes | Service Connects |
|--------------------|--------------------|--------------------|------------------|
| Stoelting Street | 2700 | 10 | 35 |
| Washington Street | 2600 | 12 | 29 |
| Niagara Street (N) | 4450 | 21 | 52 |
| Niagara Street (S) | 4550 | 26 | 34 |
| Cayuga Street | 2100 | 11 | 43 |
| Wurl Street | 1000 | 3 | 13 |
| Sy Road | 1400 | 6 | 23 |
| Reynolds Street | 450 | 2 | 11 |
| Luther Street | 2300 | 7 | 29 |
| Sylvan Place | 400 | 2 | 17 |
| Old Falls Blvd | 2950 | 14 | 22 |
| Shultz Street | 1900 | 2 | 19 |
| Rohr Street | 2300 | 3 | 11 |
| Hunt Street | 1500 | 3 | 17 |
| Totals | 30600 | 122 | 355 |

Smoke Testing and CCTV Costs

Percentage of length to test: 50%
 Cost per LF for smoke testing: \$0.20

Smoke Testing Cost: \$3,060.00

Percentage of length to TV: 50% of line smoked
 Cost per LF for TV: \$1.50

TV Cost (Includes Cleaning): \$11,475.00

Slip Lining of 8" Sewer

Percentage of length to repair: 50% of line TV'd
 Cost per LF of repair: \$25.00

Cost for slip lining (w/o laterals) \$95,625.00

Lateral Repairs

% of service laterals to repair: 75%
 Cost per lateral to repair: \$1,000.00

Lateral Repair Cost: \$266,250.00

Manhole Recoating

% of manholes to repair: 50%
 Estimated manhole depth: 8 feet
 Cost per LF to repair: \$140.00

Cost for repairs: \$68,320.00

Total Repair Costs

| | |
|---------------------------|---------------------|
| Smoke Testing | \$3,060.00 |
| CCTV | \$11,475.00 |
| Slip Lining | \$95,625.00 |
| Lateral Repairs | \$266,250.00 |
| Manhole Recoating | \$68,320.00 |
| Sub Total | \$444,730.00 |
| Contingency | \$75,270.00 |
| ELA | \$130,000.00 |
| Total Repair Costs | \$650,000.00 |

NCSD No.1 Peak Flow vs Average Day Treatment Costs

| Conveyance/Treatment Item | Average Cost Per Day | Peak Cost Per Day |
|-----------------------------|----------------------|-------------------|
| Remote Pump Stations | | |
| Shawnee | \$ 4.56 | \$ 35.77 |
| Mapleton | \$ 9.23 | \$ 47.56 |
| Moyer | \$ 3.34 | \$ 15.22 |
| East Canal | \$ 46.94 | \$ 334.71 |
| Townline | \$ 26.19 | \$ 204.38 |
| Tonawanda | \$ 17.13 | \$ 73.21 |
| | \$ 107.39 | \$ 710.85 |
| Influent Raw Pumps | | |
| Influent Raw Pumps | \$ 133.63 | \$ 445.63 |
| Aeration System | | |
| Air Supply Blowers | \$ 190.00 | \$ 337.73 |
| Filtration System | | |
| Filter Feed Pumps | \$ 44.56 | \$ 200.32 |
| Backwash Air Scour Blowers | \$ 5.57 | \$ 48.72 |
| Backwash Holding Tank Pumps | \$ 2.55 | \$ 10.44 |
| Dewatering Costs | | |
| Centrifuging, Polymer, etc | Negligible | Negligible |
| Disinfection | | |
| Bleach Use | \$60 | \$110 |
| Total Cost | \$ 651.09 | \$ 2,574.54 |

Appendix B
Total Suspended Solids Summary
(Demonstration Project Sampling Results)

JAN 2004

| DATE | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS Removal |
|---------------|-------------|---------------|--------------|-------------|---------------|
| 1 | 21.700 | 168.00 | 23.2 | 2.00 | 91 |
| 2 | 12.005 | 216.00 | 16.0 | 3.20 | 80 |
| 3 | 13.610 | 180.00 | 18.8 | 2.00 | 89 |
| 4 | 10.966 | 108.00 | 15.6 | 1.60 | 90 |
| 5 | 11.168 | 112.00 | 14.8 | 5.20 | 65 |
| 6 | 9.500 | 140.00 | 13.6 | 2.60 | 81 |
| 7 | 8.237 | 176.00 | 13.6 | 2.20 | 84 |
| 8 | 8.867 | 116.00 | 8.4 | 1.80 | 79 |
| 9 | 7.120 | 340.00 | 8.0 | 2.00 | 75 |
| 10 | 7.818 | 328.00 | 8.4 | 2.20 | 74 |
| 11 | 8.473 | 80.00 | 9.2 | 2.20 | 76 |
| 12 | 7.825 | 88.00 | 20.0 | 1.80 | 91 |
| 13 | 7.173 | 120.00 | 18.8 | 2.20 | 88 |
| 14 | 7.781 | 136.00 | 18.8 | 2.10 | 89 |
| 15 | 7.371 | 60.00 | 20.4 | 2.80 | 86 |
| 16 | 7.082 | 80.00 | 12.0 | 2.20 | 82 |
| 17 | 6.808 | 248.00 | 3.6 | 1.20 | 67 |
| 18 | 6.886 | 324.00 | 24.0 | 1.60 | 93 |
| 19 | 6.134 | 188.00 | 16.0 | 2.00 | 88 |
| 20 | 7.627 | 344.00 | 14.4 | 2.00 | 86 |
| 21 | 6.083 | 208.00 | 16.0 | 2.40 | 85 |
| 22 | 6.821 | 260.00 | 16.0 | 1.70 | 89 |
| 23 | 6.744 | 232.00 | 16.8 | 1.40 | 92 |
| 24 | 6.668 | 272.00 | 12.8 | 1.70 | 87 |
| 25 | 6.594 | 284.00 | 15.6 | 1.80 | 88 |
| 26 | 6.572 | 252.00 | 16.8 | 1.70 | 90 |
| 27 | 6.532 | 244.00 | 12.8 | 1.90 | 85 |
| 28 | 6.447 | 212.00 | 10.4 | 1.60 | 85 |
| 29 | 6.882 | 268.00 | 17.5 | 2.20 | 87 |
| 30 | 6.412 | 260.00 | 14.8 | 2.80 | 81 |
| 31 | 6.753 | 176.00 | 16.4 | 1.40 | 91 |
| Totals | 8.28 | 200.65 | 14.95 | 2.11 | 86 |

| CSO/SSO Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 |

| Primary Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 5 | 13.9 | 156.8 | 17.7 | 2.8 | 84 |

FEB 2004

| DATE | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS Removal |
|---------------|--------|--------|-------------|--------|---------------|
| 1 | 6.557 | 184.00 | 15.2 | 2 | 87 |
| 2 | 6.761 | 220.00 | 14.4 | 2.8 | 81 |
| 3 | 8.095 | 212.00 | 27.3 | 2.8 | 90 |
| 4 | 9.550 | 136.00 | 14.5 | 3.8 | 74 |
| 5 | 9.052 | 68.00 | 17.2 | 6 | 65 |
| 6 | 9.762 | 80.00 | 13.5 | 4 | 70 |
| 7 | 11.512 | 104.00 | 19.5 | 4 | 79 |
| 8 | 10.545 | 124.00 | 23.5 | 6.25 | 73 |
| 9 | 10.836 | 104.00 | 55.5 | 8.25 | 85 |
| 10 | 8.920 | 188.00 | 18.5 | 6.8 | 63 |
| 11 | 10.258 | 116.00 | 18.0 | 6.8 | 62 |
| 12 | 10.548 | 120.00 | 22.0 | 7.4 | 66 |
| 13 | 7.867 | 80.00 | 21.6 | 5.2 | 76 |
| 14 | 9.050 | 96.00 | 22.4 | 4.4 | 80 |
| 15 | 7.191 | 76.00 | 18.0 | 5.6 | 69 |
| 16 | 7.932 | 64.00 | 16.4 | 5.6 | 66 |
| 17 | 7.526 | 84.00 | 18.0 | 4.4 | 76 |
| 18 | 6.971 | 44.00 | 14.8 | 4 | 73 |
| 19 | 11.068 | 88.00 | 14.4 | 3.8 | 74 |
| 20 | 8.355 | 80.00 | 15.2 | 4.4 | 71 |
| 21 | 13.104 | 72.00 | 25.3 | 7.5 | 70 |
| 22 | 11.916 | 36.00 | 20.0 | 7 | 65 |
| 23 | 11.635 | 24.00 | 20.0 | 8.4 | 58 |
| 24 | 11.098 | 96.00 | 19.6 | 7.2 | 63 |
| 25 | 10.672 | 112.00 | 33.3 | 9.5 | 71 |
| 26 | 10.114 | 176.00 | 23.6 | 9.4 | 60 |
| 27 | 10.200 | 112.00 | 26.0 | 9.8 | 62 |
| 28 | 10.235 | 104.00 | 25.6 | 9.6 | 63 |
| 29 | 12.128 | 68.00 | 25.6 | 8 | 69 |
| Totals | 9.64 | 105.79 | 21.34 | 6.02 | 72 |

| CSO/SSO Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 2 | 10.8 | 108.0 | 44.4 | 8.9 | 80 |

| Primary Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 13 | 11.1 | 95.4 | 21.8 | 7.3 | 67 |

MARCH

2004

| DATE | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS Removal |
|---------------|--------------|--------------|--------------|-------------|---------------|
| 1 | 15.462 | 60.00 | 31.6 | 8.80 | 72 |
| 2 | 26.302 | 188.00 | 35.0 | 12.60 | 64 |
| 3 | 21.515 | 116.00 | 24.0 | 5.60 | 77 |
| 4 | 17.711 | 96.00 | 30.0 | 7.00 | 77 |
| 5 | 20.730 | 92.00 | 15.2 | 7.50 | 51 |
| 6 | 19.670 | 72.00 | 21.0 | 5.00 | 76 |
| 7 | 13.890 | 132.00 | 15.2 | 6.40 | 58 |
| 8 | 13.825 | 124.00 | 15.6 | 6.20 | 60 |
| 9 | 13.747 | 40.00 | 14.4 | 4.20 | 71 |
| 10 | 11.390 | 100.00 | 14.8 | 6.00 | 59 |
| 11 | 11.974 | 116.00 | 16.4 | 6.40 | 61 |
| 12 | 10.244 | 88.00 | 18.4 | 6.20 | 66 |
| 13 | 11.552 | 88.00 | 18.0 | 6.80 | 62 |
| 14 | 8.322 | 68.00 | 19.6 | 5.40 | 72 |
| 15 | 9.375 | 96.00 | 19.2 | 6.80 | 65 |
| 16 | 8.968 | 60.00 | 27.6 | 5.75 | 79 |
| 17 | 9.746 | 20.00 | 20.5 | 5.40 | 74 |
| 18 | 8.879 | 108.00 | 21.0 | 4.50 | 79 |
| 19 | 9.385 | 76.00 | 14.0 | 6.20 | 56 |
| 20 | 12.043 | 36.00 | 24.5 | 3.50 | 86 |
| 21 | 18.463 | 96.00 | 25.5 | 10.50 | 59 |
| 22 | 13.055 | 56.00 | 20.5 | 9.25 | 55 |
| 23 | 10.473 | 68.00 | 27.5 | 9.00 | 67 |
| 24 | 11.645 | 52.00 | 20.4 | 8.75 | 57 |
| 25 | 14.204 | 92.00 | 21.6 | 9.25 | 57 |
| 26 | 15.388 | 36.00 | 20.6 | 7.25 | 65 |
| 27 | 18.379 | 72.00 | 43.0 | 15.50 | 64 |
| 28 | 14.456 | 52.00 | 19.0 | 8.80 | 54 |
| 29 | 12.060 | 52.00 | 34.8 | 7.20 | 79 |
| 30 | 11.501 | 80.00 | 23.0 | 9.20 | 60 |
| 31 | 10.120 | 124.00 | 27.0 | 8.40 | 69 |
| Totals | 13.69 | 82.45 | 22.55 | 7.40 | 67 |

| CSO/SSO Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 5 | 18.0 | 93.6 | 34.9 | 10.2 | 71 |

| Primary Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 20 | 14.0 | 83.0 | 20.1 | 7.2 | 64 |

APRIL 2004

| DATE | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS Removal |
|---------------|-----------------|-----------------|-------------|------------|---------------|
| 1 | 11.437 | 40.00 | 29.0 | 4.40 | 85 |
| 2 | 16.276 | 32.00 | 17.0 | 11.00 | 35 |
| 3 | 15.853 | 40.00 | 20.0 | 5.60 | 72 |
| 4 | 17.424 | 36.00 | 26.0 | 4.80 | 82 |
| 5 | 16.231 | 36.00 | 16.0 | 5.20 | 68 |
| 6 | 13.429 | 40.00 | 13.0 | 4.60 | 65 |
| 7 | 13.387 | 88.00 | 20.0 | 6.00 | 70 |
| 8 | 12.192 | 44.00 | 11.2 | 3.20 | 71 |
| 9 | 11.403 | 68.00 | 14.0 | 3.20 | 77 |
| 10 | 9.657 | 20.00 | 19.2 | 3.60 | 81 |
| 11 | 8.568 | 20.00 | 14.4 | 4.00 | 72 |
| 12 | 9.122 | 28.00 | 20.0 | 3.00 | 85 |
| 13 | 12.031 | 40.00 | 19.5 | 3.60 | 82 |
| 14 | 20.212 | 628.00 | 41.0 | 12.40 | 70 |
| 15 | 13.966 | 20.00 | 18.5 | 5.40 | 71 |
| 16 | 12.584 | 16.00 | 18.5 | 2.20 | 88 |
| 17 | 11.485 | 88.00 | 16.5 | 3.00 | 82 |
| 18 | 13.007 | 124.00 | 42.7 | 2.20 | 95 |
| 19 | 14.711 | 280.00 | 22.0 | 8.60 | 61 |
| 20 | 12.275 | 40.00 | 21.0 | 15.40 | 27 |
| 21 | 11.538 | 40.00 | 23.0 | 2.40 | 90 |
| 22 | 14.063 | 40.00 | 26.0 | 4.40 | 83 |
| 23 | 12.063 | 60.00 | 21.0 | 1.80 | 91 |
| 24 | 10.928 | 48.00 | 31.0 | 4.00 | 87 |
| 25 | 10.529 | 44.00 | 29.0 | 3.20 | 89 |
| 26 | 12.847 | 28.00 | 25.0 | 4.60 | 82 |
| 27 | 10.944 | 12.00 | 25.0 | 5.20 | 79 |
| 28 | 9.049 | 64.00 | 27.5 | 3.40 | 88 |
| 29 | 9.655 | 48.00 | 26.0 | 3.20 | 88 |
| 30 | 8.390 | 88.00 | 24.0 | 3.40 | 86 |
| Totals | 12.50853 | 73.33333 | 22.6 | 4.9 | 78 |

| CSO/SSO Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 3 | 14.8 | 266.7 | 38.2 | 6.2 | 84 |

| Primary Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 21 | 13.2 | 53.9 | 20.5 | 5.1 | 75 |

MAY 2004

| DATE | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS Removal |
|---------------|-------------|--------------|-------------|------------|---------------|
| 1 | 8.753 | 72.00 | 17.0 | 2.60 | 85 |
| 2 | 10.297 | 40.00 | 36.0 | 2.20 | 94 |
| 3 | 11.387 | 448.00 | 12.0 | 2.20 | 82 |
| 4 | 9.918 | 40.00 | 14.0 | 3.00 | 79 |
| 5 | 9.831 | 44.00 | 26.0 | 2.80 | 89 |
| 6 | 9.120 | 32.00 | 20.0 | 4.40 | 78 |
| 7 | 8.658 | 52.00 | 12.0 | 4.00 | 67 |
| 8 | 8.606 | 40.00 | 26.0 | 3.40 | 87 |
| 9 | 10.271 | 76.00 | 22.0 | 3.60 | 84 |
| 10 | 9.980 | 84.00 | 26.0 | 5.00 | 81 |
| 11 | 9.187 | 56.00 | 31.0 | 4.80 | 85 |
| 12 | 8.578 | 112.00 | 13.0 | 1.40 | 89 |
| 13 | 8.300 | 72.00 | 13.6 | 4.40 | 68 |
| 14 | 7.896 | 24.00 | 11.6 | 2.20 | 81 |
| 15 | 7.994 | 40.00 | 15.0 | 2.00 | 87 |
| 16 | 7.773 | 36.00 | 8.4 | 2.30 | 73 |
| 17 | 7.698 | 31.00 | 10.4 | 1.40 | 87 |
| 18 | 8.144 | 172.00 | 3.6 | 1.00 | 72 |
| 19 | 7.723 | 204.00 | 6.8 | 1.80 | 74 |
| 20 | 7.229 | 416.00 | 6.8 | 1.20 | 82 |
| 21 | 7.258 | 340.00 | 9.6 | 3.40 | 65 |
| 22 | 7.624 | 380.00 | 8.4 | 1.00 | 88 |
| 23 | 11.015 | 484.00 | 12.0 | 2.60 | 78 |
| 24 | 21.327 | 792.00 | 42.0 | 14.40 | 66 |
| 25 | 15.121 | 188.00 | 18.0 | 8.40 | 53 |
| 26 | 12.726 | 116.00 | 22.0 | 3.80 | 83 |
| 27 | 10.684 | 116.00 | 26.0 | 3.80 | 85 |
| 28 | 10.546 | 108.00 | 31.0 | 2.00 | 94 |
| 29 | 8.855 | 164.00 | 24.0 | 4.20 | 83 |
| 30 | 8.123 | 108.00 | 11.0 | 1.90 | 83 |
| 31 | 10.126 | 124.00 | 11.0 | 2.20 | 80 |
| Totals | 9.70 | 161.6 | 17.6 | 3.3 | 81 |

| CSO/SSO Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 3 | 14.1 | 313.3 | 36.3 | 6.2 | 83 |

| Primary Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|------|--------|-------------|--------|----------------|
| 7 | 11.6 | 221.7 | 17.6 | 3.8 | 78 |

JUNE 2004

| DATE | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------|------------|--------------|-------------|-------------|----------------|
| 1 | 13.850 | 248.00 | 9.2 | 2.8 | 70 |
| 2 | 10.783 | 120.00 | 6.8 | 2.0 | 71 |
| 3 | 9.651 | 240.00 | 4.8 | 1.4 | 71 |
| 4 | 8.640 | 240.00 | 6.8 | 2.2 | 68 |
| 5 | 8.075 | 428.00 | 6.8 | 2.0 | 71 |
| 6 | 7.765 | 380.00 | 16.0 | 2.4 | 85 |
| 7 | 7.968 | 280.00 | 6.0 | 1.8 | 70 |
| 8 | 7.666 | 324.00 | 4.0 | 2.2 | 45 |
| 9 | 7.340 | 260.00 | 5.2 | 1.5 | 71 |
| 10 | 8.776 | 256.00 | 2.0 | 0.5 | 75 |
| 11 | 7.284 | 212.00 | 3.8 | 1.4 | 63 |
| 12 | 7.137 | 184.00 | 3.6 | 0.7 | 81 |
| 13 | 7.040 | 184.00 | 3.6 | 0.9 | 75 |
| 14 | 7.177 | 256.00 | 5.6 | 0.5 | 91 |
| 15 | 7.740 | 364.00 | 4.4 | 1.3 | 70 |
| 16 | 7.097 | 308.00 | 5.8 | 1.8 | 69 |
| 17 | 7.526 | 304.00 | 5.6 | 1.6 | 71 |
| 18 | 7.500 | 244.00 | 6.0 | 0.6 | 90 |
| 19 | 7.069 | 228.00 | 10.8 | 2.2 | 80 |
| 20 | 7.038 | 224.00 | 4.4 | 0.2 | 95 |
| 21 | 7.000 | 268.00 | 3.6 | 0.2 | 94 |
| 22 | 7.216 | 340.00 | 4.4 | 2.6 | 41 |
| 23 | 7.076 | 332.00 | 4.4 | 0.8 | 82 |
| 24 | 7.044 | 252.00 | 4.4 | 0.8 | 82 |
| 25 | 7.543 | 252.00 | 6.0 | 1.2 | 80 |
| 26 | 6.968 | 204.00 | 10.8 | 1.2 | 89 |
| 27 | 6.577 | 244.00 | 4.8 | 1.9 | 60 |
| 28 | 6.593 | 248.00 | 4.0 | 1.3 | 68 |
| 29 | 6.514 | 360.00 | 5.0 | 1.7 | 66 |
| 30 | 6.527 | 336.00 | 2.0 | 2.0 | 0 |
| Totals | 7.7 | 270.7 | 5.69 | 1.46 | 74 |

| Primary Type Events | FLOW | INF,SS | FILT,INF SS | EFF,SS | % TSS, Removal |
|---------------------|--------|---------|-------------|--------|----------------|
| 2 | 12.317 | 184.000 | 8.0 | 2.4 | 70 |

Appendix C
Fecal Coliform Summary
(Demonstration Project Sampling Results)

**NIAGARA COUNTY SEWER DISTRICT #1
SECONDARY CLARIFIER FECAL COLIFORM SUMMARY
2004**

| DATE | SEC CLAR FECAL 1st Sample | SEC CLAR FECAL 2nd Sample |
|----------|------------------------------|------------------------------|
| 01/02/04 | 12,000 | 10,000 |
| 01/09/04 | 11,000 | 18,000 |
| 01/11/04 | 9,000 | 12,000 |
| 01/16/04 | 14,000 | 10,000 |
| 01/23/04 | 28,000 | 37,000 |
| 02/06/04 | 35,000 | 20,000 |
| 02/08/04 | 39,000 | 45,000 |
| 02/13/04 | 28,000 | 26,000 |
| 02/20/04 | 46,000 | 58,000 |
| 02/22/04 | 84,000 | 95,000 |
| 03/05/04 | 62,000 | 58,000 |
| 03/07/04 | 42,000 | 57,000 |
| 03/12/04 | 37,000 | 35,000 |
| 03/20/04 | 9,000 | 8,000 |
| 03/26/04 | 7,000 | 9,000 |
| 04/02/04 | 13,000 | 9,000 |
| 04/04/04 | 17,000 | 22,000 |
| 04/16/04 | 8,000 | 9,000 |
| 04/18/04 | 47,000 | 44,000 |
| 04/29/04 | 98,000 | 95,000 |
| 05/02/04 | 28,000 | 31,000 |
| 05/06/04 | 11,000 | 9,000 |
| 05/14/04 | 58,000 | 69,000 |
| 05/16/04 | 34,000 | 39,000 |
| 05/23/04 | 24,000 | 26,000 |
| 06/04/04 | 25,000 | 30,000 |
| 06/06/04 | 26,000 | 31,000 |
| 06/11/04 | 21,000 | 23,000 |
| 06/14/04 | 68,000 | 84,000 |
| 06/25/04 | 11,000 | 15,000 |
| 07/02/04 | 32,000 | 31,000 |
| 07/04/04 | 29,000 | 35,000 |
| 07/11/04 | 27,000 | 40,000 |
| 07/16/04 | 14,000 | 17,000 |
| 07/18/04 | 25,000 | 21,000 |
| 08/01/04 | 60,000 | 52,000 |
| 08/06/04 | 74,000 | 84,000 |
| 08/13/04 | 35,000 | 38,000 |
| 08/27/04 | 4,000 | 5,000 |
| 08/28/04 | 4,000 | 5,000 |
| 08/31/04 | 8,000 | 8,000 |
| 09/03/04 | 42,000 | 55,000 |
| 09/10/04 | 59,000 | 46,000 |
| 09/17/04 | 116,000 | 91,000 |
| 09/19/04 | 95,000 | 89,000 |
| | | |

Appendix D
Treatment Plant Summary Reports
(Demonstration Project Sampling Results)

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979 Oct-98

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|-------|----------------|------|----------|----------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| T | 1 | 4.280 | 17.2 | 20.3 | 7.3 | 7.4 | 7.4 | 7.4 | 7.6 | 15 | <0.1 | 107.5 | 3.2 | 180 | 3.6 | |
| F | 2 | 3.602 | 17.0 | 19.3 | 7.1 | 7.4 | 7.3 | 7.8 | 7.8 | 15.0 | <0.1 | 116.5 | 2.0 | 164 | 4.4 | |
| S | 3 | 3.653 | 16.9 | 19.1 | 7.3 | 7.4 | 7.6 | 7.7 | 7.7 | 14.0 | <0.1 | 141.3 | 3.4 | 136 | 22.4 | |
| S | 4 | 3.517 | 16.9 | 19.0 | 7.2 | 7.3 | 7.5 | 7.7 | 7.7 | 13.0 | <0.1 | | | 132 | 8.8 | |
| M | 5 | 3.815 | 16.8 | 18.7 | 7.1 | 7.3 | 7.4 | 7.7 | 7.7 | 16.0 | <0.1 | | | 152 | 4.0 | |
| T | 6 | 3.941 | 16.8 | 19.4 | 7.1 | 7.4 | 7.5 | 7.8 | 7.8 | 15.0 | <0.1 | | | 156 | 2.0 | |
| W | 7 | 3.708 | 17.0 | 19.9 | 7.0 | 7.2 | 7.3 | 7.7 | 7.7 | 13.0 | <0.1 | 123.3 | 3.9 | | | |
| T | 8 | 5.306 | 16.9 | 19.6 | 7.0 | 7.2 | 7.2 | 7.5 | 7.5 | 17.0 | <0.1 | 111.0 | 3.7 | 216 | 11.6 | |
| F | 9 | 3.977 | 16.7 | 19.4 | 6.8 | 7.2 | 7.1 | 7.5 | 7.5 | 12.0 | <0.1 | 124.2 | 2.5 | 208 | 7.6 | |
| S | 10 | 3.592 | 16.5 | 19.4 | 6.9 | 7.6 | 7.6 | 7.6 | 7.6 | 11.5 | <0.1 | | | 144 | 7.2 | |
| S | 11 | 3.627 | 16.5 | 19.3 | 6.9 | 7.2 | 7.5 | 7.5 | 7.5 | 15.0 | <0.1 | | | 160 | 7.6 | |
| M | 12 | 3.300 | 16.7 | 19.2 | 6.7 | 6.8 | 7.1 | 7.4 | 7.4 | 20.0 | <0.1 | | | 184 | 5.6 | |
| T | 13 | 3.768 | 16.7 | 20.6 | 6.7 | 7.0 | 6.8 | 7.5 | 7.5 | 16.0 | <0.1 | | | 192 | 10.4 | |
| W | 14 | 4.039 | 16.6 | 19.3 | 6.6 | 6.8 | 6.8 | 7.6 | 7.6 | 17.0 | <0.1 | 150.5 | 4.1 | | | |
| T | 15 | 4.072 | 16.5 | 18.7 | 6.7 | 6.9 | 7.3 | 7.4 | 7.4 | 15.0 | <0.1 | 113.3 | 3.4 | 152 | 4.8 | |
| F | 16 | 3.473 | 16.3 | 18.8 | 6.9 | 7.4 | 7.0 | 7.1 | 7.1 | 14.0 | <0.1 | 182.4 | 12.3 | 212 | 1.2 | |
| S | 17 | 3.528 | 16.3 | 18.4 | 6.9 | 7.4 | 6.8 | 7.2 | 7.2 | 14.0 | <0.1 | 123.3 | 5.8 | 168 | 8.8 | |
| S | 18 | 4.190 | 16.5 | 19.1 | 6.6 | 6.7 | 6.9 | 7.1 | 7.1 | 16.0 | <0.1 | | | 212 | 2.4 | |
| M | 19 | 3.771 | 16.4 | 15.8 | 6.7 | 7.0 | 6.8 | 7.1 | 7.1 | 11.0 | <0.1 | | | 212 | 3.6 | |
| T | 20 | 3.428 | 16.1 | 16.4 | 6.3 | 7.2 | 6.4 | 7.4 | 7.4 | 11.0 | <0.1 | | | 148 | 5.2 | |
| W | 21 | 3.738 | 15.8 | 15.9 | 7.2 | 8.4 | 7.4 | 8.3 | 8.3 | 14.0 | <0.1 | 130.0 | 5.3 | | | |
| T | 22 | 3.421 | 15.9 | 15.4 | 7.2 | 7.3 | 7.2 | 7.6 | 7.6 | 10.0 | <0.1 | 144.2 | 3.3 | 168 | 2.8 | |
| F | 23 | 3.551 | 15.9 | 15.2 | 6.9 | 7.2 | 7.1 | 7.6 | 7.6 | 10.0 | <0.1 | 138.9 | 3.7 | 188 | 5.2 | |
| S | 24 | 3.700 | 15.6 | 17.7 | 7.0 | 7.2 | 7.2 | 7.5 | 7.5 | 11.0 | <0.1 | 148.6 | 1.8 | 88 | 3.2 | |
| S | 25 | 3.471 | 15.9 | 18.6 | 6.8 | 7.2 | 6.9 | 7.2 | 7.2 | 13.0 | <0.1 | | | 232 | 5.6 | |
| M | 26 | 3.857 | 16.7 | 18.7 | 6.8 | 7.0 | 6.9 | 7.0 | 7.0 | 17.0 | <0.1 | | | 212 | 3.6 | |
| T | 27 | 4.107 | 16.2 | 18.8 | 6.9 | 7.0 | 6.7 | 7.3 | 7.3 | 25.0 | <0.1 | | | 220 | 7.2 | |
| W | 28 | 4.340 | 16.3 | 19.5 | 6.9 | 7.1 | 6.7 | 7.3 | 7.3 | 20.0 | <0.1 | | | | | |
| T | 29 | 4.116 | 16.1 | 18.4 | 7.1 | 7.2 | 6.8 | 7.9 | 7.9 | 19.0 | <0.1 | 170.1 | 7.0 | | | |
| F | 30 | 3.761 | 15.9 | 17.9 | 7.0 | 7.3 | 7.3 | 7.7 | 7.7 | 18.0 | <0.1 | 202.1 | 3.2 | 252 | 4.4 | |
| S | 31 | 3.635 | 15.8 | 17.8 | 7.1 | 7.4 | 7.4 | 7.8 | 7.8 | 18.0 | <0.1 | | | 324 | 4.0 | |
| | | | | | | | | | | | | | | 244 | 7.2 | |
| AVERAGE | | 3.816 | 16.4 | 18.5 | 6.3 | 8.4 | 6.4 | 8.3 | 8.3 | 25.0 | 0.0 | 138.7 | 4.2 | 188.4 | 6.1 | |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | max | 96.9% | 138.3 | 96.7% | 194.1 | |

NIAGARA COUNTY SEWER DISTRICT #1

Oct-98

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS | |
|---------|------|-------|-------------|----------|-------------------|----------|------------------|----------|-------------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | | AVE,mg/l |
| T | 1 | 4.280 | 4.13 | 0.38 | 0.48 | 0.64 | 0.58 | | |
| F | 2 | 3.602 | 4.50 | 0.31 | 0.70 | 0.76 | 0.73 | 28 | |
| S | 3 | 3.653 | 3.36 | 0.39 | 0.67 | 0.71 | 0.69 | 55 | |
| S | 4 | 3.517 | 4.66 | 0.34 | 0.68 | 0.77 | 0.73 | | |
| M | 5 | 3.815 | 4.13 | 0.42 | 0.32 | 0.72 | 0.49 | 45 | |
| T | 6 | 3.941 | | | 0.27 | 1.28 | 0.62 | | |
| W | 7 | 3.708 | 3.36 | 0.55 | 0.86 | 1.18 | 1.04 | 42 | |
| T | 8 | 5.306 | 3.36 | 0.44 | 0.87 | 1.13 | 0.96 | | |
| F | 9 | 3.977 | 8.86 | 0.61 | 0.70 | 0.81 | 0.76 | 39 | |
| S | 10 | 3.592 | 2.63 | 0.57 | 0.63 | 0.79 | 0.73 | 105 | |
| S | 11 | 3.627 | 1.90 | 0.30 | 0.58 | 0.80 | 0.67 | | |
| M | 12 | 3.300 | 8.22 | 0.32 | 0.59 | 0.64 | 0.62 | | |
| T | 13 | 3.768 | | | 0.45 | 0.53 | 0.50 | | |
| W | 14 | 4.039 | 3.32 | 0.55 | 0.57 | 0.68 | 0.63 | 8 | |
| T | 15 | 4.072 | 1.82 | 0.33 | 0.40 | 0.60 | 0.53 | | |
| F | 16 | 3.473 | 4.69 | 0.28 | 0.47 | 0.71 | 0.60 | 3 | |
| S | 17 | 3.528 | 3.12 | 0.49 | 0.44 | 0.52 | 0.49 | 20 | |
| S | 18 | 4.190 | 2.06 | 0.31 | 0.50 | 0.67 | 0.57 | | |
| M | 19 | 3.771 | 4.70 | 0.32 | 0.49 | 0.72 | 0.61 | 9 | |
| T | 20 | 3.428 | | | 0.42 | 0.61 | 0.51 | | |
| W | 21 | 3.738 | 3.81 | 0.81 | 0.36 | 0.43 | 0.39 | 24 | |
| T | 22 | 3.421 | 3.85 | 0.35 | 0.40 | 0.54 | 0.46 | | |
| F | 23 | 3.551 | 4.17 | 0.31 | 0.40 | 0.48 | 0.44 | 16 | |
| S | 24 | 3.700 | 5.02 | 0.31 | 0.65 | 0.83 | 0.72 | 4 | |
| S | 25 | 3.471 | 4.81 | 0.39 | 0.62 | 0.70 | 0.66 | | |
| M | 26 | 3.857 | 3.32 | 0.46 | 0.51 | 0.61 | 0.55 | 3 | |
| T | 27 | 4.107 | | | 0.40 | 0.56 | 0.47 | 3 | |
| W | 28 | 4.340 | 8.59 | 0.52 | 0.59 | 0.70 | 0.65 | 3 | |
| T | 29 | 4.116 | 6.20 | 0.43 | 0.36 | 0.58 | 0.44 | | |
| F | 30 | 3.761 | 5.83 | 0.34 | 0.25 | 0.62 | 0.45 | 25 | |
| S | 31 | 3.635 | 6.28 | 0.34 | 0.25 | 0.64 | 0.44 | 45 | |
| AVERAGE | | 3.816 | 4.46 | 0.42 | 0.25 | 1.28 | 1.04 | 15.3 | 30 day geom |
| | | | | 13.2 | | | | 55.6 | 7 day geom |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979

Nov-98

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|----------|----------|----------|-----------|-----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| T | 1 | 3.899 | 15.7 | 17.7 | 7.0 | 7.1 | 7.7 | 7.7 | 17 | <0.1 | | | | 316 | 4.4 | |
| F | 2 | 3.736 | 15.7 | 16.9 | 6.8 | 7.2 | 7.4 | 7.6 | 18.0 | <0.1 | | | | 184 | 7.2 | |
| S | 3 | 3.600 | 15.5 | 17.1 | 7.1 | 7.4 | 7.8 | 7.8 | 16.0 | <0.1 | | | | 260 | 9.6 | |
| S | 4 | 3.309 | 15.5 | 16.6 | 7.1 | 7.5 | 7.8 | 7.8 | 15.0 | <0.1 | 160.6 | 8.5 | | | | |
| M | 5 | 3.996 | 15.2 | 17.3 | 6.8 | 7.1 | 7.1 | 7.4 | 16.0 | <0.1 | 192.8 | 6.6 | 228 | | 11.2 | |
| T | 6 | 3.866 | 15.5 | 17.0 | 6.7 | 6.9 | 7.0 | 7.5 | 27.0 | <0.1 | 187.8 | 7 | 304 | | 7.6 | |
| W | 7 | 4.016 | 15.0 | 16.3 | 6.7 | 7.1 | 7.1 | 7.2 | 17.0 | <0.1 | 131.8 | 6.8 | 220 | | 8.0 | |
| T | 8 | 3.925 | 15.4 | 16.9 | 6.9 | 7.2 | 7.2 | 7.2 | 20.0 | <0.1 | | | 272 | | 9.6 | |
| F | 9 | 3.082 | 14.2 | 16.5 | 6.8 | 7.0 | 7.2 | 7.2 | 21.0 | <0.1 | | | 172 | | 6.4 | |
| S | 10 | 3.935 | 15.3 | 16.7 | 6.9 | 6.8 | 7.3 | 7.4 | 22.0 | <0.1 | | | 308 | | 5.2 | |
| S | 11 | 4.013 | 15.1 | 16.7 | 6.9 | 7.3 | 7.4 | 7.4 | 28.0 | <0.1 | 245.3 | 6.9 | 284 | | 6.0 | |
| M | 12 | 3.834 | 15.3 | 16.4 | 7.0 | 7.3 | 7.5 | 7.5 | 14.0 | <0.1 | 147.2 | 5.6 | 212 | | 10.0 | |
| T | 13 | 3.276 | 14.3 | 15.9 | 7.0 | 7.0 | 7.2 | 7.2 | 16.0 | <0.1 | 148.6 | 5.8 | 232 | | 8.4 | |
| W | 14 | 3.841 | 14.6 | 16.6 | 6.8 | 6.9 | 7.2 | 7.2 | 25.0 | <0.1 | 153.0 | 10.2 | 296 | | 9.2 | |
| T | 15 | 3.796 | 14.7 | 16.5 | 6.6 | 6.7 | 6.9 | 7.1 | 23.0 | <0.1 | | | 396 | | 8.8 | |
| F | 16 | 3.873 | 14.8 | 16.3 | 6.9 | 7.0 | 7.0 | 7.0 | 23.0 | <0.1 | | | 232 | | 6.0 | |
| S | 17 | 4.086 | 14.8 | 16.3 | 6.9 | 7.2 | 7.6 | 7.6 | 14.0 | <0.1 | | | 260 | | 7.6 | |
| S | 18 | 3.637 | 14.6 | 16.2 | 7.4 | 7.1 | 7.6 | 7.6 | 17.0 | <0.1 | 150.4 | 10.9 | 240 | | 18.1 | |
| M | 19 | 3.649 | 14.2 | 16.2 | 6.7 | 7.2 | 7.9 | 7.6 | 14.0 | <0.1 | 133.1 | 9.1 | 176 | | 6.5 | |
| T | 20 | 4.643 | 16.8 | 16.8 | 7.6 | 7.6 | 7.9 | 8.2 | 15.0 | <0.1 | 124.7 | 12.4 | 252 | | 10.0 | |
| W | 21 | 3.879 | 15.0 | 15.6 | 6.8 | 7.0 | 7.9 | 7.9 | 16.0 | <0.1 | 110.9 | 12.8 | 224 | | 9.0 | |
| T | 22 | 3.607 | 14.9 | 16.1 | 7.3 | 7.2 | 7.7 | 8.2 | 17.0 | <0.1 | | | 344 | | 9.6 | |
| F | 23 | 3.343 | 14.9 | 16.1 | 7.4 | 7.4 | 8.1 | 8.0 | 10.0 | <0.1 | | | 188 | | 5.0 | |
| S | 24 | 3.341 | 15.0 | 15.7 | 7.3 | 7.5 | 7.5 | 7.9 | 22.0 | <0.1 | | | 276 | | 7.4 | |
| S | 25 | 3.717 | 14.9 | 15.1 | 7.2 | 7.7 | 7.8 | 7.8 | 20.0 | <0.1 | 256.2 | 12 | 236 | | 7.6 | |
| M | 26 | 3.496 | 14.5 | 15.9 | 7.2 | 7.7 | 7.7 | 7.7 | 20.0 | <0.1 | 236.1 | 8.2 | 304 | | 14.0 | |
| T | 27 | 3.409 | 14.4 | 15.5 | 7.2 | 7.7 | 7.7 | 7.7 | | | 234.8 | 5.2 | 204 | | 4.0 | |
| W | 28 | 3.551 | 14.3 | 15.2 | 7.1 | 7.2 | 7.6 | 7.6 | 9.0 | <0.1 | 175.8 | 4.7 | 224 | | 9.9 | |
| T | 29 | 3.572 | 14.2 | 16.4 | 7.0 | 7.5 | 7.6 | 7.6 | 12.0 | <0.1 | | | 216 | | 4.0 | |
| F | 30 | 3.401 | 14.3 | 16.6 | 7.1 | 7.5 | 7.5 | 7.6 | 15.0 | <0.1 | | | 184 | | 8.5 | |
| AVERAGE | | 3.711 | 15.0 | 16.4 | 6.6 | 6.7 | 8.1 | 8.2 | 28.0 | 0.0 | 171.9 | 8.2 | 250.4 | 8.1 | 253.2 | |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | 95.2% | 258.4 | 96.8% | | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Nov-98

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|-----------|-------------------|-----------|------------------|------------------|
| | | | INF, mg/l | EFF, mg/l | MIN, mg/l | MAX, mg/l | | |
| T | 1 | 3.899 | 5.10 | 0.44 | 0.60 | 0.70 | 0.64 | |
| F | 2 | 3.736 | 4.33 | 0.45 | 0.54 | 0.65 | 0.60 | 8 |
| S | 3 | 3.600 | | | 0.54 | 0.62 | 0.59 | |
| S | 4 | 3.309 | 8.46 | 0.91 | 0.40 | 0.77 | 0.58 | 11 |
| M | 5 | 3.996 | 4.00 | 0.47 | 0.94 | 1.12 | 1.01 | |
| T | 6 | 3.866 | 3.56 | 0.40 | 1.33 | 1.50 | 1.41 | 3 |
| W | 7 | 4.016 | 4.21 | 0.46 | 1.05 | 1.12 | 1.08 | 3 |
| T | 8 | 3.925 | | | 0.92 | 1.12 | 1.00 | |
| F | 9 | 3.082 | 3.80 | 0.38 | 1.02 | 1.06 | 1.04 | 3 |
| S | 10 | 3.935 | 4.94 | 0.43 | 1.00 | 1.06 | 1.03 | |
| S | 11 | 4.013 | 3.88 | 0.48 | 1.24 | 1.31 | 1.27 | 30 |
| M | 12 | 3.834 | 3.44 | 0.74 | 0.53 | 0.85 | 0.72 | |
| T | 13 | 3.276 | 6.60 | 0.33 | 1.14 | 1.34 | 1.23 | 32 |
| W | 14 | 3.841 | 5.14 | 0.36 | 0.99 | 1.27 | 1.15 | 22 |
| T | 15 | 3.796 | 6.64 | 0.55 | 0.91 | 1.10 | 1.03 | |
| F | 16 | 3.873 | 1.01 | 0.53 | 0.91 | 1.20 | 1.04 | 34 |
| S | 17 | 4.086 | | | 0.98 | 1.25 | 1.07 | |
| S | 18 | 3.637 | 5.02 | 0.80 | 0.89 | 1.08 | 0.97 | 9 |
| M | 19 | 3.649 | 3.24 | 0.49 | 0.74 | 0.92 | 0.80 | |
| T | 20 | 4.643 | 0.64 | 0.39 | 0.77 | 0.90 | 0.84 | 3 |
| W | 21 | 3.879 | 3.32 | 0.40 | 0.80 | 0.93 | 0.85 | 16 |
| T | 22 | 3.607 | 2.95 | 0.46 | 0.95 | 1.06 | 1.00 | |
| F | 23 | 3.343 | 4.37 | 0.52 | 0.90 | 1.07 | 0.99 | 20 |
| S | 24 | 3.341 | | | 0.78 | 1.00 | 0.92 | |
| S | 25 | 3.717 | 3.73 | 0.24 | 0.68 | 0.82 | 0.77 | 72 |
| M | 26 | 3.496 | 4.50 | 0.58 | 0.56 | 0.70 | 0.64 | |
| T | 27 | 3.409 | 4.62 | 0.44 | 0.61 | 0.75 | 0.68 | 11 |
| W | 28 | 3.551 | 3.93 | 0.41 | 0.68 | 0.72 | 0.70 | 14 |
| T | 29 | 3.572 | 4.17 | 0.38 | 0.67 | 0.80 | 0.75 | |
| F | 30 | 3.401 | 3.75 | 0.51 | 0.37 | 0.78 | 0.62 | 11 |
| AVERAGE | | 3.711 | 4.21 | 0.48 | 0.37 | 1.50 | 1.41 | 11.8 30 day geom |
| | | | | 14.9 | | | | 28.9 7 day geom |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

Dec-98

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|-----|----------|-----|-----------|-----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | MAX | EFF, MIN | MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| T | 1 | 3.998 | 14.1 | 16.5 | 7.2 | 7.4 | 7.7 | 7.8 | 7.8 | 17 | <0.1 | | | 184 | 12.0 | |
| W | 2 | 3.961 | 14.2 | 16.6 | 7.4 | 7.5 | 7.8 | 7.8 | 7.8 | 14.0 | <0.1 | 115.5 | 9.6 | | | |
| T | 3 | 4.089 | 14.1 | 16.3 | 7.4 | 7.6 | 7.5 | 7.8 | 7.8 | 18.0 | <0.1 | 136.2 | 14.3 | 204 | 15.0 | |
| F | 4 | 3.672 | 14.4 | 17.2 | 7.3 | 7.4 | 7.6 | 7.7 | 7.7 | 13.5 | <0.1 | 140.2 | 10.4 | 176 | 7.0 | |
| S | 5 | 4.066 | 14.2 | 17.5 | 7.3 | 7.6 | 7.6 | 7.7 | 7.7 | 16.0 | <0.1 | 158.2 | 12.0 | 184 | 6.0 | |
| S | 6 | 4.261 | 13.8 | 17.5 | 7.2 | 7.3 | 7.7 | 7.7 | 7.7 | 20.5 | <0.1 | | | 260 | 8.5 | |
| M | 7 | 4.291 | 14.2 | 17.6 | 7.3 | 7.4 | 7.7 | 7.9 | 7.9 | 15.0 | <0.1 | | | 92 | 5.0 | |
| T | 8 | 3.948 | 14.0 | 16.4 | 7.1 | 7.4 | 7.7 | 7.9 | 7.9 | 14.0 | <0.1 | | | 232 | 10.0 | |
| W | 9 | 3.983 | 13.9 | 15.5 | 7.2 | 7.4 | 7.7 | 8.1 | 8.1 | 15.0 | <0.1 | 123.3 | 24.5 | | | |
| T | 10 | 3.552 | 14.0 | 15.8 | 7.4 | 7.5 | 7.5 | 7.8 | 7.8 | 19.5 | <0.1 | 155.9 | 11.0 | 220 | 12.0 | |
| F | 11 | 4.488 | 13.7 | 15.2 | 7.3 | 7.5 | 7.3 | 7.7 | 7.7 | 16.0 | <0.1 | 145.7 | 8.7 | 216 | 7.0 | |
| S | 12 | 3.901 | 13.7 | 15.2 | 7.2 | 7.3 | 7.4 | 7.6 | 7.6 | 21.0 | <0.1 | 153.9 | 14.4 | 300 | 13.0 | |
| S | 13 | 3.809 | 13.5 | 15.4 | 7.1 | 7.3 | 7.4 | 7.7 | 7.7 | 19.0 | <0.1 | | | 280 | 3.6 | |
| M | 14 | 3.745 | 13.7 | 15.1 | 7.2 | 7.3 | 7.3 | 7.6 | 7.6 | 22.0 | <0.1 | | | 180 | 5.0 | |
| T | 15 | 4.104 | 13.6 | 15.0 | 6.9 | 7.4 | 7.2 | 7.6 | 7.6 | 21.0 | <0.1 | | | 208 | 9.0 | |
| W | 16 | 3.501 | 13.6 | 15.5 | 6.8 | 7.2 | 7.5 | 7.6 | 7.6 | 18.0 | <0.1 | 175.5 | 6.8 | | | |
| T | 17 | 3.638 | 13.5 | 15.4 | 6.8 | 7.1 | 6.6 | 7.5 | 7.5 | 22.0 | <0.1 | 290.0 | 4.5 | 756 | 10.4 | |
| F | 18 | 3.338 | 13.2 | 14.8 | 6.6 | 7.0 | 6.6 | 7.2 | 7.2 | 18.0 | <0.1 | 187.6 | 5.0 | 212 | 5.2 | |
| S | 19 | 3.868 | 13.6 | 14.6 | 7.1 | 7.4 | 7.5 | 7.7 | 7.7 | 16.0 | <0.1 | 142.2 | 3.3 | 260 | 6.0 | |
| S | 20 | 3.340 | 13.2 | 15.1 | 7.1 | 7.3 | 7.5 | 7.7 | 7.7 | 18.0 | <0.1 | | | 256 | 7.2 | |
| M | 21 | 4.027 | 13.3 | 15.0 | 7.0 | 7.2 | 7.5 | 7.7 | 7.7 | 17.0 | <0.1 | | | 244 | 12.1 | |
| T | 22 | 5.501 | 12.9 | 14.0 | 7.1 | 7.2 | 7.2 | 7.5 | 7.5 | 18.5 | <0.1 | | | 244 | 12.0 | |
| W | 23 | 4.145 | 12.8 | 12.8 | 7.1 | 7.1 | 7.5 | 7.6 | 7.6 | 21.0 | <0.1 | 144.4 | 19.1 | | | |
| T | 24 | 3.837 | 12.6 | 13.3 | 6.8 | 7.2 | 7.5 | 7.6 | 7.6 | 14.0 | <0.1 | 144.4 | 8.0 | 132 | 7.3 | |
| F | 25 | 3.820 | 12.6 | 12.9 | 7.0 | 7.1 | 7.5 | 7.5 | 7.5 | 15.0 | <0.1 | 158.9 | 7.2 | 148 | 12.0 | |
| S | 26 | 3.747 | 12.4 | 13.4 | 6.8 | 7.0 | 7.1 | 7.6 | 7.6 | 19.0 | <0.1 | 164.7 | 10.2 | 164 | 15.0 | |
| S | 27 | 3.928 | 12.3 | 13.5 | 6.8 | 6.9 | 7.1 | 7.6 | 7.6 | 16.0 | <0.1 | | | 152 | 4.0 | |
| M | 28 | 4.010 | 12.6 | 13.9 | 7.0 | 7.2 | 7.0 | 7.4 | 7.4 | 32.0 | <0.1 | | | 500 | 4.0 | |
| T | 29 | 3.892 | 12.3 | 13.8 | 7.1 | 7.2 | 7.3 | 7.5 | 7.5 | 18.0 | <0.1 | | | 204 | 14.0 | |
| W | 30 | 3.792 | 12.3 | 12.2 | 7.2 | 7.4 | 7.1 | 7.3 | 7.3 | 15.0 | <0.1 | 154.0 | 16.0 | | | |
| T | 31 | 3.488 | 12.6 | 12.2 | 7.0 | 7.3 | 7.3 | 7.5 | 7.5 | 9.5 | <0.1 | 136.7 | 6.4 | 176 | 9.5 | |
| AVERAGE | | 3.927 | 13.4 | 15.0 | 6.6 | 7.6 | 6.6 | 8.1 | 8.1 | 32.0 | 0.0 | 156.1 | 10.8 | 236.8 | 9.0 | |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | max | 93.1% | 344.5 | 96.2% | 294.2 | |

NIAGARA COUNTY SEWER DISTRICT #1

Dec-98

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|-------------------|----------|----------|------------------|-------------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| T | 1 | 3.998 | | | 0.67 | 0.76 | 0.70 | | |
| W | 2 | 3.961 | 4.29 | 0.60 | 0.46 | 0.70 | 0.60 | 22 | |
| T | 3 | 4.089 | 3.28 | 0.55 | 0.28 | 0.41 | 0.35 | | |
| F | 4 | 3.672 | 5.75 | 0.21 | 0.20 | 0.48 | 0.34 | 159 | |
| S | 5 | 4.066 | 6.15 | 0.38 | 0.18 | 0.25 | 0.21 | 420 | |
| S | 6 | 4.261 | 2.26 | 0.34 | 0.94 | 1.28 | 1.14 | | |
| M | 7 | 4.291 | 5.14 | 0.45 | 1.16 | 1.40 | 1.24 | 9 | |
| T | 8 | 3.948 | | | 1.34 | 1.94 | 1.56 | | |
| W | 9 | 3.983 | 3.11 | 0.54 | 1.47 | 1.96 | 1.74 | 3 | |
| T | 10 | 3.552 | 1.30 | 0.50 | 1.20 | 1.69 | 1.45 | | |
| F | 11 | 4.488 | 1.42 | 0.39 | 1.02 | 1.36 | 1.19 | 24 | |
| S | 12 | 3.901 | 4.45 | 0.47 | 1.13 | 1.37 | 1.25 | 13 | |
| S | 13 | 3.809 | 6.97 | 0.34 | 1.22 | 1.56 | 1.39 | | |
| M | 14 | 3.745 | 2.06 | 0.35 | 0.98 | 1.10 | 1.04 | 6 | |
| T | 15 | 4.104 | | | 0.86 | 1.04 | 0.98 | | |
| W | 16 | 3.501 | 11.90 | 0.52 | 0.71 | 1.01 | 0.90 | 3 | |
| T | 17 | 3.638 | 4.70 | 0.50 | 0.72 | 0.94 | 0.83 | | |
| F | 18 | 3.338 | 6.16 | 0.45 | 0.54 | 0.75 | 0.63 | 30 | |
| S | 19 | 3.868 | 4.25 | 0.43 | 0.62 | 0.90 | 0.72 | 14 | |
| S | 20 | 3.340 | 4.50 | 0.43 | 0.70 | 0.84 | 0.77 | | |
| M | 21 | 4.027 | 3.81 | | 0.80 | 1.01 | 0.94 | 7 | |
| T | 22 | 5.501 | | 0.41 | 0.54 | 1.02 | 0.82 | | |
| W | 23 | 4.145 | 3.56 | 0.29 | 0.55 | 0.83 | 0.70 | | |
| T | 24 | 3.837 | 3.24 | 0.45 | 0.54 | 0.75 | 0.66 | | |
| F | 25 | 3.820 | 3.48 | 0.49 | 0.60 | 0.84 | 0.75 | 25 | |
| S | 26 | 3.747 | 5.14 | 0.35 | 0.70 | 0.88 | 0.81 | 20 | |
| S | 27 | 3.928 | 3.36 | 0.36 | 0.78 | 0.98 | 0.90 | | |
| M | 28 | 4.010 | 3.85 | | 0.60 | 0.87 | 0.76 | 26 | |
| T | 29 | 3.892 | | 0.87 | 0.75 | 0.93 | 0.82 | | |
| W | 30 | 3.792 | 4.13 | 0.50 | 0.52 | 0.81 | 0.63 | 3 | |
| T | 31 | 3.488 | 4.81 | 0.00 | 0.63 | 0.77 | 0.72 | | |
| AVERAGE | | 3.927 | 4.29 | 0.44 | 0.18 | 1.96 | 1.74 | 16.2 | 30 day geom |
| | | | 14.3 | | | | | 60.3 | 7 day geom |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979

Nov-99

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|-----------|-----------|------------------|-----------|-----------|-----------|-------------|-------|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| M | 1 | 4.997 | 16.5 | 20.1 | 7.1 | 7.4 | 7.4 | 7.4 | 7.4 | 24 | <0.1 | | | | 312 | 3.5 |
| T | 2 | 8.187 | 16.9 | 18.7 | 6.7 | 7.3 | 7.4 | 7.4 | 7.5 | 20.0 | <0.1 | | | | 324 | 4.8 |
| W | 3 | 21.379 | 15.4 | 14.8 | 6.6 | 7.1 | 7.5 | 7.6 | 7.6 | 11.0 | <0.1 | | | | 228 | 15.0 |
| T | 4 | 10.983 | 15.2 | 14.9 | 6.6 | 7.2 | 7.3 | 7.3 | 7.3 | 8.0 | <0.1 | | 90.2 | 6.8 | 164 | 9.5 |
| F | 5 | 8.486 | 15.5 | 15.9 | 6.7 | 7.2 | 6.8 | 7.0 | 7.0 | 11.0 | <0.1 | | 77.3 | 23.6 | 88 | 3.8 |
| S | 6 | 6.968 | 15.9 | 16.1 | 6.7 | 7.3 | 7.0 | 7.2 | 7.2 | 12.0 | <0.1 | | 114.8 | 3.7 | 108 | 4.2 |
| S | 7 | 5.474 | 15.7 | 15.0 | 6.3 | 7.0 | 6.6 | 7.1 | 7.1 | 12.0 | <0.1 | | 97.3 | 5.2 | 120 | 5.6 |
| M | 8 | 4.953 | 15.9 | 15.6 | 6.6 | 7.0 | 6.8 | 7.1 | 7.1 | 12.0 | <0.1 | | | | 84 | 0.9 |
| T | 9 | 5.341 | 16.1 | 16.7 | 6.7 | 6.9 | 6.9 | 6.9 | 7.0 | 13.0 | <0.1 | | | | 128 | 1.5 |
| W | 10 | 5.252 | 16.2 | 17.7 | 6.6 | 7.1 | 6.9 | 6.9 | 6.9 | 15.0 | <0.1 | | | | | |
| T | 11 | 5.823 | 15.9 | 16.4 | 6.9 | 7.2 | 6.8 | 6.8 | 6.9 | 15.0 | <0.1 | | 135.6 | 3.1 | 40 | 1.0 |
| F | 12 | 5.438 | 15.7 | 16.0 | 6.8 | 7.2 | 6.8 | 7.0 | 7.0 | 10.0 | <0.1 | | 116.0 | 3.3 | 128 | 1.2 |
| S | 13 | 4.864 | 15.7 | 16.5 | 7.0 | 7.1 | 6.8 | 7.0 | 7.0 | 10.0 | <0.1 | | 92.7 | 1.4 | 140 | 2.5 |
| S | 14 | 5.115 | 15.9 | 16.9 | 6.7 | 7.0 | 6.9 | 7.1 | 7.1 | 3.0 | <0.1 | | 85.9 | 1.5 | 140 | 1.4 |
| M | 15 | 5.171 | 15.8 | 16.4 | 6.9 | 7.0 | 6.9 | 7.0 | 7.0 | 15.0 | <0.1 | | | | 184 | 1.3 |
| T | 16 | 5.094 | 15.2 | 15.6 | 6.7 | 7.1 | 7.0 | 7.0 | 7.0 | 7.0 | <0.1 | | | | 216 | 2.2 |
| W | 17 | 4.643 | 15.3 | 15.2 | 6.3 | 6.9 | 6.7 | 6.7 | 6.7 | 13.0 | <0.1 | | 197.2 | 3.0 | | |
| T | 18 | 4.425 | 15.2 | 15.6 | 6.8 | 7.2 | 7.0 | 7.1 | 7.1 | 0.0 | <0.1 | | 218.7 | 2.5 | 688 | 2.2 |
| F | 19 | 4.147 | 15.3 | 16.2 | 7.0 | 7.1 | 6.9 | 7.1 | 7.1 | 22.0 | <0.1 | | 204.2 | 1.8 | 316 | 2.4 |
| S | 20 | 5.408 | 15.4 | 16.8 | 7.0 | 7.4 | 6.7 | 6.8 | 6.8 | 15.0 | <0.1 | | 32.8 | 1.9 | 204 | 2.4 |
| S | 21 | 4.419 | 15.2 | 16.9 | 7.0 | 7.5 | 6.9 | 6.9 | 6.9 | 11.0 | <0.1 | | | | 212 | 3.0 |
| M | 22 | 4.659 | 15.2 | 17.0 | 7.0 | 7.3 | 7.1 | 7.2 | 7.2 | 10.0 | <0.1 | | | | 184 | 2.6 |
| T | 23 | 4.482 | 15.2 | 17.6 | 7.2 | 7.7 | 7.3 | 7.3 | 7.3 | 12.0 | <0.1 | | | | 228 | 3.2 |
| W | 24 | 4.476 | 15.2 | 17.4 | 7.4 | 7.7 | 7.4 | 7.4 | 7.6 | 13.0 | <0.1 | | 136.2 | 2.0 | | |
| T | 25 | 4.410 | 15.1 | 16.7 | 7.3 | 7.8 | 7.4 | 7.4 | 7.4 | 18.0 | <0.1 | | 194.6 | 2.7 | 320 | 2.4 |
| F | 26 | 6.870 | 14.9 | 16.4 | 7.3 | 7.5 | 7.4 | 7.4 | 7.5 | 12.0 | <0.1 | | 132.9 | 3.0 | 220 | 4.0 |
| S | 27 | 9.628 | 14.3 | 15.4 | 7.2 | 7.3 | 7.2 | 7.3 | 7.3 | 10.0 | <0.1 | | 105.9 | 2.1 | 164 | 2.0 |
| S | 28 | 6.702 | 14.3 | 15.0 | 7.2 | 7.3 | 7.4 | 7.4 | 7.5 | 7.0 | <0.1 | | | | 100 | 2.0 |
| M | 29 | 5.809 | 14.6 | 15.1 | 7.2 | 7.4 | 7.4 | 7.4 | 7.5 | 12.0 | <0.1 | | | | 128 | 3.4 |
| T | 30 | 4.689 | 14.6 | 15.0 | 7.1 | 7.4 | 7.1 | 7.5 | 7.5 | 15.0 | <0.1 | | | | 264 | 2.8 |
| AVERAGE | | 6.276 | 15.5 | 16.3 | 6.3 | 7.8 | 6.6 | 7.6 | 7.6 | 24.0 | 0.0 | | 120.0 | 5.6 | 195.2 | 4.7 |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | max | | 95.3% | 331.3 | 97.6% | 250.9 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Nov-99

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | |
| M | 1 | 4.997 | 5.47 | 0.24 | 0.52 | 0.60 | 0.56 | |
| T | 2 | 8.187 | | | 0.41 | 0.58 | 0.52 | |
| W | 3 | 21.379 | 1.70 | 0.40 | 0.39 | 0.73 | 0.53 | 84 |
| T | 4 | 10.983 | 1.82 | 0.24 | 0.21 | 0.43 | 0.33 | |
| F | 5 | 8.486 | 2.02 | 0.23 | 0.30 | 0.78 | 0.50 | 26 |
| S | 6 | 6.968 | 3.56 | 0.21 | 0.19 | 1.33 | 0.87 | 3 |
| S | 7 | 5.474 | 3.03 | 0.01 | 0.91 | 1.07 | 1.00 | |
| M | 8 | 4.953 | 1.94 | 0.02 | 0.58 | 1.09 | 0.88 | 3 |
| T | 9 | 5.341 | | | 0.72 | 0.80 | 0.76 | |
| W | 10 | 5.252 | 1.86 | 0.05 | 0.84 | 0.95 | 0.89 | 3 |
| T | 11 | 5.823 | 6.48 | 0.02 | 0.63 | 0.85 | 0.77 | |
| F | 12 | 5.438 | 2.88 | 0.06 | 0.72 | 0.78 | 0.76 | 3 |
| S | 13 | 4.864 | 2.67 | 0.09 | 0.64 | 0.95 | 0.82 | 3 |
| S | 14 | 5.115 | 3.28 | 0.14 | 0.70 | 0.73 | 0.72 | |
| M | 15 | 5.171 | 4.17 | 0.16 | 0.66 | 0.70 | 0.68 | |
| T | 16 | 5.094 | | | 0.70 | 0.83 | 0.75 | |
| W | 17 | 4.643 | 7.57 | 0.25 | 0.41 | 0.78 | 0.64 | 3 |
| T | 18 | 4.425 | 21.34 | 0.19 | 0.45 | 0.92 | 0.75 | |
| F | 19 | 4.147 | 7.45 | 0.23 | 0.55 | 0.68 | 0.61 | 3 |
| S | 20 | 5.408 | 3.93 | 0.20 | 0.57 | 0.65 | 0.60 | 3 |
| S | 21 | 4.419 | 3.32 | 0.29 | 0.62 | 0.72 | 0.68 | |
| M | 22 | 4.659 | 4.41 | 0.21 | 0.56 | 1.01 | 0.73 | 3 |
| T | 23 | 4.482 | | | 0.56 | 0.70 | 0.61 | |
| W | 24 | 4.476 | 5.10 | 0.17 | 0.31 | 0.48 | 0.38 | 3 |
| T | 25 | 4.410 | 7.49 | 0.19 | 0.23 | 0.50 | 0.34 | |
| F | 26 | 6.870 | 3.32 | 0.21 | 0.25 | 0.39 | 0.34 | 3 |
| S | 27 | 9.628 | 2.19 | 0.14 | 0.33 | 0.49 | 0.43 | 3 |
| S | 28 | 6.702 | 2.27 | 0.15 | 0.39 | 0.60 | 0.49 | |
| M | 29 | 5.809 | 1.54 | 0.19 | 0.50 | 0.65 | 0.56 | |
| T | 30 | 4.689 | | | 0.33 | 0.48 | 0.42 | |
| AVERAGE | | 6.276 | 3.78 | 0.20 | 0.19 | 1.33 | 1.00 | 4.4 |
| | | | 10.5 | | | | | 18.7 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
SPDES # NY-0027979
Dec-99

7346 LIBERTY DRIVE
NIAGARA FALLS, NEW YORK

716-693-0001
716-693-8759 FAX
FRANK A. Nerone, P.E.
CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE,C | | pH | | pH | pH | pH | pH | SETT SOLIDS,1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|---------------|------|----------|----------|-----|-----|-----|-----|-----------------|----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | EFF, MAX | | | | | INF, MAX | EFF, MIN | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l |
| W | 1 | 4.753 | 14.5 | 14.7 | 7.1 | 7.4 | 7.4 | 7.0 | 7.4 | 7.3 | <0.1 | 172.7 | 14.8 | | | |
| T | 2 | 5.353 | 14.5 | 14.4 | 7.1 | 7.4 | 7.4 | 7.1 | 7.3 | 7.3 | <0.1 | 192.6 | 7.3 | 216 | 8.4 | |
| F | 3 | 4.906 | 14.7 | 15.6 | 6.9 | 7.3 | 7.3 | 7.3 | 7.5 | 7.5 | <0.1 | 162.7 | 7.5 | 180 | 3.4 | |
| S | 4 | 5.600 | 14.8 | 16.1 | 6.6 | 7.3 | 7.3 | 7.3 | 7.4 | 7.4 | <0.1 | 148.4 | 3.2 | 188 | 2.4 | |
| S | 5 | 5.339 | 14.6 | 16.6 | 6.9 | 7.3 | 7.3 | 7.1 | 7.5 | 7.5 | <0.1 | | | 184 | 1.2 | |
| M | 6 | 5.556 | 15.0 | 16.1 | 6.9 | 7.1 | 7.1 | 7.1 | 7.2 | 7.2 | <0.1 | | | 160 | 0.7 | |
| T | 7 | 5.368 | 14.7 | 15.5 | 6.6 | 7.2 | 7.2 | 6.7 | 7.2 | 7.2 | <0.1 | | | 132 | 1.8 | |
| W | 8 | 5.540 | 14.5 | 15.4 | 6.5 | 7.0 | 7.0 | 6.6 | 7.2 | 7.2 | <0.1 | | | | | |
| T | 9 | 5.630 | 14.7 | 15.5 | 6.7 | 7.2 | 7.2 | 6.6 | 7.1 | 7.1 | <0.1 | 127.2 | 1.5 | | | |
| F | 10 | 7.563 | 14.5 | 15.7 | 6.7 | 7.1 | 7.1 | 6.6 | 7.2 | 7.2 | <0.1 | 170.3 | 5.5 | 160 | 2.0 | |
| S | 11 | 7.439 | 14.0 | 14.5 | 6.8 | 6.8 | 6.9 | 6.9 | 7.2 | 7.2 | <0.1 | 119.7 | 1.5 | 180 | 2.0 | |
| S | 12 | 7.264 | 13.7 | 14.3 | 7.0 | 7.1 | 7.1 | 6.8 | 7.0 | 7.0 | <0.1 | 21.0 | 3.4 | 156 | 3.0 | |
| M | 13 | 7.517 | 14.0 | 14.6 | 6.8 | 6.9 | 6.9 | 7.0 | 7.1 | 7.1 | <0.1 | | | 160 | 2.2 | |
| T | 14 | 8.580 | 13.9 | 14.3 | 6.9 | 7.0 | 7.0 | 6.8 | 7.1 | 7.1 | <0.1 | | | 200 | 3.0 | |
| W | 15 | 11.839 | 13.1 | 13.8 | 6.7 | 6.8 | 6.8 | 6.6 | 6.9 | 6.9 | <0.1 | | | 108 | 0.6 | |
| T | 16 | 13.154 | 12.8 | 12.9 | 6.8 | 7.1 | 7.1 | 6.8 | 6.8 | 6.8 | <0.1 | 133.2 | 6.2 | 228 | 1.6 | |
| F | 17 | 11.754 | 12.4 | 12.6 | 6.8 | 7.1 | 7.1 | 6.6 | 7.0 | 7.0 | <0.1 | 72.6 | 3.2 | 164 | 3.2 | |
| S | 18 | 6.147 | 12.5 | 12.7 | 6.9 | 7.0 | 7.0 | 6.9 | 7.0 | 7.0 | <0.1 | 95.4 | 2.8 | 192 | 1.3 | |
| S | 19 | 5.595 | 12.7 | 12.9 | 6.9 | 7.2 | 7.2 | 7.0 | 7.2 | 7.2 | <0.1 | 105.6 | 3.6 | 112 | 3.2 | |
| M | 20 | 5.416 | 13.0 | 13.3 | 6.9 | 7.2 | 7.2 | 6.9 | 7.1 | 7.1 | <0.1 | | | 156 | 1.6 | |
| T | 21 | 6.950 | 12.4 | 12.8 | 7.1 | 7.3 | 7.3 | 7.0 | 7.3 | 7.3 | <0.1 | | | 132 | 1.0 | |
| W | 22 | 5.745 | 12.1 | 11.4 | 7.3 | 7.4 | 7.4 | 7.3 | 7.4 | 7.4 | <0.1 | | | 76 | 1.1 | |
| T | 23 | 4.694 | 12.1 | 11.5 | 6.4 | 7.2 | 7.2 | 6.4 | 7.1 | 7.1 | <0.1 | 120.2 | 2.8 | | | |
| F | 24 | 4.313 | 11.8 | 11.3 | 6.5 | 7.3 | 7.3 | 6.5 | 7.2 | 7.2 | <0.1 | 176.3 | 1.0 | 124 | 1.2 | |
| S | 25 | 4.561 | 11.7 | 11.5 | 6.7 | 6.9 | 6.9 | 6.8 | 6.9 | 6.9 | <0.1 | 147.0 | 2.1 | 140 | 1.2 | |
| S | 26 | 5.152 | 11.9 | 11.3 | 6.7 | 6.7 | 6.7 | 6.6 | 6.9 | 6.9 | <0.1 | 158.8 | 3.0 | 148 | 0.8 | |
| M | 27 | 4.848 | 11.8 | 11.6 | 6.6 | 7.2 | 7.2 | 6.6 | 6.9 | 6.9 | <0.1 | | | 236 | 0.9 | |
| T | 28 | 4.614 | 11.9 | 11.5 | 6.9 | 6.9 | 6.9 | 6.8 | 7.2 | 7.2 | <0.1 | | | 232 | 0.9 | |
| W | 29 | 5.028 | 11.9 | 11.6 | 7.0 | 7.2 | 7.2 | 6.2 | 7.2 | 7.2 | <0.1 | | | 348 | 0.2 | |
| T | 30 | 4.903 | 12.0 | 12.0 | 7.1 | 7.2 | 7.2 | 7.0 | 7.1 | 7.1 | <0.1 | 158.0 | 2.8 | | | |
| F | 31 | 4.687 | 11.6 | 12.2 | 7.3 | 7.4 | 7.4 | 7.4 | 7.5 | 7.5 | <0.1 | 180.2 | 2.4 | 124 | 0.5 | |
| | | | | | | | | | | | | 142.2 | 6.8 | 128 | 0.9 | |
| AVERAGE | | 6.316 | 13.2 | 13.6 | 6.4 | 7.4 | 7.4 | 6.2 | 7.5 | 7.5 | 0.0 | 127.2 | 3.9 | 169.5 | 1.9 | |
| | | Monthly | ave. | ave. | min | max | max | min | max | max | max | 96.9% | 213.6 | 98.9% | 101.2 | |

NIAGARA COUNTY SEWER DISTRICT #1

Dec-99

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS | |
|---------|------|--------|-------------|----------|-------------------|----------|------------------|----------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | | AVE,mg/l |
| W | 1 | 4.753 | 4.94 | 0.26 | 0.37 | 0.55 | 0.46 | 3 | |
| T | 2 | 5.353 | 6.60 | 0.25 | 0.38 | 0.80 | 0.52 | | |
| F | 3 | 4.906 | 4.66 | 0.27 | 0.54 | 0.59 | 0.57 | 3 | |
| S | 4 | 5.600 | 4.86 | 0.19 | 0.24 | 0.38 | 0.33 | 3 | |
| S | 5 | 5.339 | 6.16 | 0.16 | 0.05 | 0.13 | 0.08 | | |
| M | 6 | 5.556 | 5.59 | 0.13 | 0.15 | 0.43 | 0.30 | | |
| T | 7 | 5.368 | | | 0.08 | 0.85 | 0.39 | | |
| W | 8 | 5.540 | 5.71 | 0.19 | 1.08 | 1.15 | 1.11 | 3 | |
| T | 9 | 5.630 | 1.70 | 0.25 | 0.94 | 0.95 | 0.94 | | |
| F | 10 | 7.563 | 7.33 | 0.21 | 0.92 | 0.97 | 0.95 | 3 | |
| S | 11 | 7.439 | 3.68 | 0.17 | 0.72 | 0.90 | 0.81 | 3 | |
| S | 12 | 7.264 | 2.43 | 0.19 | 0.45 | 0.86 | 0.72 | | |
| M | 13 | 7.517 | 3.32 | 0.22 | 0.77 | 1.05 | 0.88 | | |
| T | 14 | 8.580 | | | 0.70 | 0.82 | 0.78 | | |
| W | 15 | 11.839 | 3.40 | 0.30 | 0.45 | 0.49 | 0.46 | 25 | |
| T | 16 | 13.154 | 1.99 | 0.18 | 0.41 | 1.15 | 0.87 | | |
| F | 17 | 11.754 | 2.88 | 0.12 | 0.68 | 0.95 | 0.83 | 9 | |
| S | 18 | 6.147 | 0.69 | 0.13 | 0.62 | 0.94 | 0.79 | 4 | |
| S | 19 | 5.595 | 2.79 | 0.16 | 0.67 | 0.83 | 0.76 | | |
| M | 20 | 5.416 | 3.28 | 0.13 | 0.64 | 0.66 | 0.65 | | |
| T | 21 | 6.950 | | | 0.57 | 0.65 | 0.62 | | |
| W | 22 | 5.745 | 2.06 | 0.18 | 0.52 | 0.68 | 0.62 | 3 | |
| T | 23 | 4.694 | 2.79 | 0.14 | 0.38 | 0.80 | 0.63 | | |
| F | 24 | 4.313 | 3.24 | 0.15 | 0.49 | 0.60 | 0.56 | 11 | |
| S | 25 | 4.561 | 4.94 | 0.17 | 0.42 | 0.62 | 0.50 | 3 | |
| S | 26 | 5.152 | 3.60 | 0.20 | 0.39 | 0.52 | 0.44 | | |
| M | 27 | 4.848 | 3.48 | 0.18 | 0.46 | 0.55 | 0.52 | | |
| T | 28 | 4.614 | | | 0.44 | 0.59 | 0.50 | | |
| W | 29 | 5.028 | 3.89 | 0.17 | 0.32 | 0.48 | 0.41 | 9 | |
| T | 30 | 4.903 | 4.05 | 0.16 | 0.36 | 0.42 | 0.39 | | |
| F | 31 | 4.687 | 1.78 | 0.17 | 0.25 | 0.33 | 0.28 | 15 | |
| AVERAGE | | 6.316 | 3.65 | 0.19 | 0.05 | 1.15 | 1.11 | 5.2 | 9.8 |
| | | | | 10.2 | | | | | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 May-01

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| T | 1 | 5.129 | 10.4 | 15.6 | 7.1 | 7.4 | 7.1 | 7.1 | 24 | <0.1 | | | 236 | 5.2 |
| W | 2 | 5.296 | 10.4 | 16.2 | 7.1 | 7.3 | 7.1 | 7.1 | 24.0 | <0.1 | 263.4 | 10.2 | | |
| T | 3 | 5.021 | 10.8 | 16.2 | 7.1 | 7.3 | 7.1 | 7.1 | 25.0 | <0.1 | 237.5 | 6.3 | 244 | 10.0 |
| F | 4 | 4.877 | 10.7 | 16.6 | 7.0 | 7.2 | 7.0 | 7.1 | 28.0 | <0.1 | 246.0 | 1.8 | 268 | 10.0 |
| S | 5 | 5.178 | 10.9 | 16.6 | 7.0 | 7.2 | 7.0 | 7.0 | 30.0 | <0.1 | 269.6 | 5.7 | 308 | 6.4 |
| S | 6 | 4.290 | 10.9 | 16.0 | 7.0 | 7.2 | 7.0 | 7.1 | 30.0 | <0.1 | | | 372 | 3.6 |
| M | 7 | 5.333 | 10.5 | 15.7 | 7.0 | 7.3 | 7.0 | 7.0 | 31.0 | <0.1 | | | 280 | 9.6 |
| T | 8 | 4.988 | 10.6 | 15.6 | 6.7 | 6.9 | 6.7 | 6.9 | 23.0 | <0.1 | | | 272 | 4.0 |
| W | 9 | 5.716 | 10.4 | 16.0 | 6.5 | 7.0 | 6.8 | 6.9 | 26.0 | <0.1 | 243.9 | 1.7 | 232 | 2.0 |
| T | 10 | 5.067 | 10.7 | 16.4 | 6.8 | 7.1 | 6.9 | 7.1 | 30.0 | <0.1 | 224.6 | 3.2 | 232 | 2.0 |
| F | 11 | 5.277 | 11.4 | 15.7 | 6.6 | 7.3 | 6.8 | 6.9 | 7.0 | <0.1 | 246.5 | 2.4 | | |
| S | 12 | 6.364 | 11.1 | 16.4 | 7.1 | 7.3 | 7.1 | 7.2 | 5.0 | <0.1 | 158.9 | 2.1 | 124 | 3.2 |
| S | 13 | 5.597 | 11.7 | 15.2 | 7.0 | 7.3 | 7.0 | 7.0 | 2.0 | <0.1 | | | 108 | 2.5 |
| M | 14 | 5.403 | 11.7 | 15.1 | 6.8 | 7.2 | 6.8 | 7.1 | 4.0 | <0.1 | | | 176 | 5.3 |
| T | 15 | 4.977 | 12.2 | 15.8 | 6.8 | 7.1 | 6.8 | 7.1 | 5.0 | <0.1 | | | 140 | 4.3 |
| W | 16 | 5.115 | 11.9 | 16.3 | 7.0 | 7.3 | 7.0 | 7.3 | 6.0 | <0.1 | 163.4 | 4.4 | | |
| T | 17 | 5.118 | 12.1 | 16.4 | 6.8 | 7.2 | 7.0 | 7.2 | 5.0 | <0.1 | 180.9 | 7.2 | 136 | 4.6 |
| F | 18 | 5.243 | 12.3 | 15.9 | 6.8 | 7.1 | 6.9 | 7.0 | 6.0 | <0.1 | 163.6 | 3.2 | 96 | 2.4 |
| S | 19 | 4.661 | 12.4 | 16.6 | 6.8 | 7.1 | 6.9 | 7.0 | 4.5 | <0.1 | 207.3 | 3.3 | 116 | 3.4 |
| S | 20 | 5.298 | 11.7 | 17.0 | 6.9 | 7.1 | 7.0 | 7.1 | 5.0 | <0.1 | | | 112 | 2.5 |
| M | 21 | 6.286 | 12.1 | 16.6 | 6.7 | 7.1 | 6.8 | 7.1 | 5.0 | <0.1 | | | 120 | 3.3 |
| T | 22 | 10.188 | 12.6 | 15.9 | 6.6 | 7.1 | 6.6 | 7.1 | 4.5 | <0.1 | | | 188 | 5.0 |
| W | 23 | 13.024 | 13.2 | 15.2 | 6.6 | 7.2 | 6.6 | 7.2 | 3.0 | <0.1 | 81.3 | 2.7 | | |
| T | 24 | 8.968 | 12.6 | 15.7 | 7.1 | 7.3 | 7.1 | 7.2 | 2.5 | <0.1 | 81.7 | 3.1 | 68 | 10.0 |
| F | 25 | 7.758 | 12.6 | 15.9 | 7.2 | 7.5 | 7.2 | 7.3 | 4.0 | <0.1 | 113.5 | 2.3 | 48 | 2.0 |
| S | 26 | 5.782 | 12.6 | 16.4 | 7.2 | 7.5 | 7.2 | 7.5 | 4.5 | <0.1 | 121.0 | 2.1 | 96 | 5.0 |
| S | 27 | 9.219 | 12.3 | 16.5 | 7.3 | 7.4 | 7.3 | 7.4 | 3.5 | <0.1 | | | 72 | 2.8 |
| M | 28 | 12.158 | 12.5 | 15.1 | 6.9 | 7.4 | 6.9 | 7.4 | 2.5 | <0.1 | | | 64 | 9.2 |
| T | 29 | 11.520 | 12.7 | 14.6 | 6.8 | 7.4 | 6.9 | 7.4 | 5.5 | <0.1 | | | 92 | 4.0 |
| W | 30 | 8.432 | 13.0 | 15.2 | 7.0 | 7.4 | 7.2 | 7.4 | 5.0 | <0.1 | 104.1 | 4.5 | | 8.8 |
| T | 31 | 7.630 | 12.7 | 15.5 | 7.2 | 7.3 | 7.2 | 7.3 | 0.0 | <0.1 | 88.7 | 9.8 | 84 | 5.2 |
| AVERAGE | | 6.610 | 11.7 | 15.9 | 6.5 | 7.5 | 6.6 | 7.5 | 31.0 | 0.0 | 161.9 | 4.1 | 149.1 | 5.2 |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | 97.5% | 219.0 | 96.5% | 284.0 |

NIAGARA COUNTY SEWER DISTRICT #1

May-01

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | |
| T | 1 | 5.129 | | | 0.23 | 0.39 | 0.30 | |
| W | 2 | 5.296 | 6.16 | 1.74 | 0.52 | 0.85 | 0.66 | |
| T | 3 | 5.021 | 7.17 | 1.02 | 0.00 | 0.14 | 0.08 | 3 |
| F | 4 | 4.877 | 3.69 | 0.85 | 0.12 | 1.06 | 0.61 | 3000 |
| S | 5 | 5.178 | 11.83 | 0.82 | 0.09 | 0.85 | 0.44 | 1020 |
| S | 6 | 4.290 | 1.58 | 0.43 | 0.28 | 0.45 | 0.37 | |
| M | 7 | 5.333 | 1.46 | 0.54 | 0.31 | 0.39 | 0.36 | |
| T | 8 | 4.988 | | | 0.39 | 0.65 | 0.52 | |
| W | 9 | 5.716 | 2.27 | 0.26 | 0.55 | 0.90 | 0.68 | 4 |
| T | 10 | 5.067 | 3.24 | 0.22 | 0.41 | 0.51 | 0.47 | |
| F | 11 | 5.277 | 3.52 | 0.20 | 0.40 | 0.53 | 0.46 | 3 |
| S | 12 | 6.364 | 1.01 | 0.30 | 0.37 | 0.39 | 0.38 | 3 |
| S | 13 | 5.597 | 3.64 | 0.32 | 0.37 | 0.40 | 0.39 | |
| M | 14 | 5.403 | 3.81 | 0.30 | 0.20 | 0.42 | 0.29 | |
| T | 15 | 4.977 | | | 0.08 | 0.28 | 0.19 | |
| W | 16 | 5.115 | 3.04 | 0.47 | 0.27 | 0.32 | 0.29 | 520 |
| T | 17 | 5.118 | 0.32 | 0.35 | 0.08 | 0.42 | 0.27 | |
| F | 18 | 5.243 | 3.04 | 0.34 | 0.32 | 0.97 | 0.60 | 640 |
| S | 19 | 4.661 | 4.53 | 0.20 | 0.74 | 1.12 | 0.97 | 115 |
| S | 20 | 5.298 | 2.91 | 0.35 | 0.72 | 1.04 | 0.85 | |
| M | 21 | 6.286 | 2.34 | 0.41 | 0.72 | 1.12 | 0.97 | |
| T | 22 | 10.188 | | | 0.52 | 0.80 | 0.66 | |
| W | 23 | 13.024 | 2.59 | 0.35 | 0.68 | 0.89 | 0.78 | 9 |
| T | 24 | 8.968 | 1.54 | 0.27 | 0.34 | 0.84 | 0.51 | |
| F | 25 | 7.758 | 1.62 | 0.28 | 0.39 | 0.75 | 0.58 | 4 |
| S | 26 | 5.782 | 2.67 | 0.39 | 0.39 | 0.80 | 0.61 | 4 |
| S | 27 | 9.219 | 1.50 | 0.33 | 0.62 | 0.78 | 0.71 | |
| M | 28 | 12.158 | 4.78 | 0.16 | 0.46 | 0.60 | 0.55 | |
| T | 29 | 11.520 | | | 0.65 | 0.95 | 0.81 | |
| W | 30 | 8.432 | 2.18 | 0.49 | 0.75 | 0.81 | 0.78 | 3 |
| T | 31 | 7.630 | 2.35 | 0.29 | 0.73 | 1.02 | 0.89 | |
| AVERAGE | | 6.610 | 3.13 | 0.42 | 0.00 | 1.12 | 0.97 | 28.1 |
| | | | 22.6 | | | | | 337.0 |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Jun-01

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|-------|----------------|------|----------|----------|----------|----------|------------------|----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| F | 1 | 6.838 | 12.8 | 15.6 | 7.2 | 7.3 | 7.3 | 7.3 | 5.5 | <0.1 | 145.4 | 6.7 | 128 | 4.0 |
| S | 2 | 6.974 | 12.7 | 16.0 | 7.3 | 7.3 | 7.3 | 7.3 | 3.0 | <0.1 | 116.7 | 6.2 | 116 | 4.4 |
| S | 3 | 6.612 | 12.6 | 16.4 | 7.1 | 7.3 | 7.0 | 7.0 | 5.0 | <0.1 | | | 144 | 3.6 |
| M | 4 | 6.370 | 12.7 | 15.9 | 7.0 | 7.4 | 7.0 | 7.0 | 4.0 | <0.1 | | | 112 | 9.6 |
| T | 5 | 6.612 | 12.9 | 15.0 | 6.9 | 7.4 | 7.2 | 7.2 | 5.0 | <0.1 | | | 104 | 5.3 |
| W | 6 | 7.127 | 13.1 | 17.1 | 7.2 | 7.3 | 7.3 | 7.3 | 5.0 | <0.1 | 128.1 | 3.0 | 88 | 5.5 |
| T | 7 | 5.600 | 13.0 | 17.5 | 7.2 | 7.4 | 7.3 | 7.3 | 5.0 | <0.1 | 165.8 | 3.6 | 57 | 4.0 |
| F | 8 | 6.717 | 13.2 | 17.6 | 7.2 | 7.5 | 7.2 | 7.2 | 5.5 | <0.1 | 143.1 | 2.4 | 80 | 4.4 |
| S | 9 | 5.544 | 13.1 | 17.8 | 7.2 | 7.5 | 7.2 | 7.2 | 4.5 | <0.1 | 151.2 | 3.2 | 56 | 2.4 |
| S | 10 | 5.913 | 13.4 | 17.6 | 7.2 | 7.3 | 7.1 | 7.1 | 5.0 | <0.1 | | | 100 | 4.0 |
| M | 11 | 6.444 | 13.5 | 17.4 | 7.0 | 7.4 | 7.2 | 7.2 | 5.0 | <0.1 | | | 104 | 5.8 |
| T | 12 | 6.003 | 15.9 | 16.3 | 6.8 | 7.4 | 7.0 | 7.0 | 14.5 | <0.1 | | | 208 | 4.0 |
| W | 13 | 5.925 | 13.5 | 18.3 | 7.0 | 7.2 | 7.2 | 7.2 | 5.0 | <0.1 | 168.2 | 6.5 | 104 | 3.6 |
| T | 14 | 5.349 | 13.7 | 18.1 | 7.0 | 7.2 | 7.0 | 7.0 | 8.0 | <0.1 | 181.4 | 12.9 | 160 | 3.8 |
| F | 15 | 5.475 | 13.9 | 18.5 | 6.8 | 7.2 | 7.1 | 7.1 | 18.0 | <0.1 | 319.1 | 13.0 | 212 | 3.0 |
| S | 16 | 5.072 | 14.1 | 19.0 | 7.1 | 7.3 | 7.2 | 7.2 | 18.0 | <0.1 | 429.0 | 18.3 | 160 | 2.2 |
| S | 17 | 4.825 | 13.9 | 19.0 | 7.0 | 7.3 | 7.2 | 7.2 | 25.0 | <0.1 | | | 376 | 3.0 |
| M | 18 | 5.219 | 13.9 | 18.5 | 6.3 | 7.1 | 7.0 | 7.0 | 24.0 | <0.1 | | | 252 | 4.0 |
| T | 19 | 5.024 | 14.2 | 18.9 | 6.2 | 6.8 | 7.1 | 7.1 | 24.0 | <0.1 | | | 244 | 3.5 |
| W | 20 | 5.466 | 14.2 | 18.7 | 7.1 | 7.3 | 7.4 | 7.4 | 35.0 | <0.1 | 285.1 | 5.6 | 348 | 11.6 |
| T | 21 | 5.343 | 14.0 | 18.0 | 7.2 | 7.3 | 7.3 | 7.3 | 20.0 | <0.1 | 171.3 | 9.4 | 372 | 11.6 |
| F | 22 | 5.399 | 14.5 | 18.7 | 7.1 | 7.5 | 7.4 | 7.4 | 18.0 | <0.1 | 212.8 | 3.4 | 176 | 5.2 |
| S | 23 | 5.781 | 14.3 | 17.5 | 7.1 | 7.3 | 7.3 | 7.3 | 18.5 | <0.1 | 206.2 | 4.3 | 172 | 6.8 |
| S | 24 | 5.444 | 14.3 | 18.0 | 7.2 | 7.3 | 7.1 | 7.1 | 4.5 | <0.1 | | | 128 | 6.5 |
| M | 25 | 4.995 | 14.2 | 18.5 | 6.9 | 7.0 | 6.9 | 6.9 | 5.0 | <0.1 | | | 268 | 11.2 |
| T | 26 | 5.017 | 14.5 | 18.7 | 6.9 | 7.2 | 7.2 | 7.2 | 4.0 | <0.1 | | | 184 | 9.2 |
| W | 27 | 4.274 | 15.1 | 19.5 | 6.8 | 7.1 | 7.2 | 7.2 | 8.5 | <0.1 | 148.1 | 1.4 | 212 | 6.7 |
| T | 28 | 4.631 | 15.1 | 19.7 | 6.9 | 7.2 | 7.1 | 7.1 | 5.0 | <0.1 | 152.1 | 4.1 | 132 | 5.3 |
| F | 29 | 4.616 | 15.3 | 19.7 | 6.8 | 7.3 | 6.9 | 6.9 | 12.0 | <0.1 | 234.8 | 3.8 | 192 | 3.7 |
| S | 30 | 4.944 | 14.5 | 19.2 | 7.1 | 7.2 | 7.2 | 7.2 | 5.5 | <0.1 | | | 152 | 7.3 |
| AVERAGE | | 5.652 | 13.9 | 17.9 | 6.2 | 7.5 | 6.9 | 7.4 | 35.0 | 0.0 | 193.8 | 6.3 | 165.7 | 5.5 |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | 96.8% | 295.6 | 96.7% | 257.5 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Jun-01

| DAY | DATE | FLOW | PHOSPHOROUS | | | CHLORINE RESIDUAL | | | F.COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|----------|-------------------|----------|-------|-----------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | | |
| F | 1 | 6.838 | 2.67 | 0.25 | 0.84 | 0.96 | 0.91 | 3 | | |
| S | 2 | 6.974 | 1.22 | 0.24 | 0.64 | 1.08 | 0.80 | 3 | | |
| S | 3 | 6.612 | 1.70 | 0.23 | 0.63 | 0.94 | 0.76 | | | |
| M | 4 | 6.370 | 3.04 | 0.41 | 0.40 | 0.70 | 0.54 | | | |
| T | 5 | 6.612 | | | 0.56 | 0.66 | 0.63 | | | |
| W | 6 | 7.127 | 2.23 | 0.24 | 0.67 | 0.76 | 0.72 | 3 | | |
| T | 7 | 5.600 | 2.02 | 0.28 | 0.49 | 0.66 | 0.59 | | | |
| F | 8 | 6.717 | 2.51 | 0.48 | 0.51 | 0.70 | 0.59 | 3 | | |
| S | 9 | 5.544 | 1.66 | 0.35 | 0.52 | 0.70 | 0.60 | 4 | | |
| S | 10 | 5.913 | 3.60 | 0.38 | 0.47 | 0.66 | 0.57 | | | |
| M | 11 | 6.444 | 3.32 | 0.43 | 0.42 | 0.50 | 0.47 | | | |
| T | 12 | 6.003 | | | 0.49 | 0.52 | 0.50 | | | |
| W | 13 | 5.925 | 2.67 | 0.34 | 0.38 | 0.56 | 0.45 | 10 | | |
| T | 14 | 5.349 | 5.46 | 0.40 | 0.45 | 0.48 | 0.47 | | | |
| F | 15 | 5.475 | 8.54 | 0.33 | 0.36 | 0.63 | 0.52 | 3 | | |
| S | 16 | 5.072 | 3.84 | 0.38 | 0.41 | 0.58 | 0.49 | 3 | | |
| S | 17 | 4.825 | | | 0.34 | 0.55 | 0.45 | | | |
| M | 18 | 5.219 | 5.39 | 0.35 | 0.30 | 0.44 | 0.39 | | | |
| T | 19 | 5.024 | 3.32 | 0.31 | 0.12 | 0.38 | 0.27 | | | |
| W | 20 | 5.466 | 4.45 | 0.30 | 0.18 | 0.29 | 0.24 | 171 | | |
| T | 21 | 5.343 | 3.69 | 0.12 | 0.21 | 0.34 | 0.27 | | | |
| F | 22 | 5.399 | 3.69 | 0.34 | 0.22 | 0.26 | 0.24 | 1060 | | |
| S | 23 | 5.781 | 3.77 | 0.40 | 0.18 | 0.50 | 0.31 | 55000 | | |
| S | 24 | 5.444 | 3.93 | 0.44 | 0.35 | 0.38 | 0.36 | | | |
| M | 25 | 4.995 | 5.27 | 0.67 | 0.18 | 0.26 | 0.22 | | | |
| T | 26 | 5.017 | | | 0.10 | 0.18 | 0.15 | | | |
| W | 27 | 4.274 | 5.06 | 0.60 | 0.50 | 0.59 | 0.54 | 3 | | |
| T | 28 | 4.631 | 3.97 | 0.49 | 0.45 | 0.50 | 0.48 | | | |
| F | 29 | 4.616 | 5.35 | 0.44 | 0.28 | 0.40 | 0.35 | 77 | | |
| S | 30 | 4.944 | 5.55 | 0.49 | 0.10 | 0.44 | 0.30 | 2400 | | |
| AVERAGE | | 5.652 | 3.64 | 0.37 | 0.10 | 1.08 | 0.91 | 27.7 | 2151.4 | |
| | | | | 17.2 | | | | | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Jul-01

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|----------|----------|----------|-----------|-----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| S | 1 | 4.139 | 14.9 | 19.6 | 7.1 | 7.5 | 7.1 | 7.4 | 5 | <0.1 | | | 100 | 4.0 | | |
| M | 2 | 5.431 | 14.9 | 18.0 | 7.1 | 7.4 | 7.1 | 7.4 | 6 | <0.1 | | | 144 | 1.6 | | |
| T | 3 | 3.645 | 15.3 | 18.7 | 7.0 | 7.4 | 7.0 | 7.2 | 4 | <0.1 | | | 80 | 3.3 | | |
| W | 4 | 4.987 | 15.2 | 18.9 | 7.0 | 7.2 | 7.0 | 7.2 | 5 | <0.1 | 186.6 | 3.0 | | | | |
| T | 5 | 4.430 | 14.8 | 18.9 | 7.1 | 7.4 | 7.2 | 7.2 | 6 | <0.1 | 174.4 | 3.2 | 136 | 4.6 | | |
| F | 6 | 4.167 | 14.8 | 18.5 | 6.9 | 7.3 | 7.0 | 7.1 | 5 | <0.1 | 200.3 | 3.5 | 76 | 3.0 | | |
| S | 7 | 4.167 | 15.1 | 18.8 | 6.9 | 7.3 | 6.9 | 7.1 | 5.5 | <0.1 | 205.2 | 3.9 | 160 | 6.8 | | |
| S | 8 | 4.300 | 15.3 | 18.9 | 6.8 | 7.2 | 6.8 | 7.0 | 5 | <0.1 | | | 148 | 6.8 | | |
| M | 9 | 5.533 | 14.9 | 19.5 | 7.0 | 7.1 | 7.0 | 7.0 | 4.5 | <0.1 | | | 80 | 8.0 | | |
| T | 10 | 4.567 | 14.9 | 19.7 | 6.7 | 7.3 | 6.7 | 7.1 | 4 | <0.1 | | | 104 | 6.0 | | |
| W | 11 | 4.761 | 15.6 | 19.5 | 7.1 | 7.4 | 7.2 | 7.4 | 5.5 | <0.1 | 190.1 | 19.4 | 132 | 6.3 | | |
| T | 12 | 4.675 | 16.0 | 19.2 | 7.0 | 7.3 | 7.1 | 7.1 | 6 | <0.1 | 179.7 | 13.0 | 128 | 5.0 | | |
| F | 13 | 3.831 | 16.1 | 19.1 | 7.0 | 7.2 | 7.0 | 7.2 | 6 | <0.1 | 198.3 | 3.5 | 128 | 4.7 | | |
| S | 14 | 4.841 | 15.9 | 18.7 | 7.1 | 7.3 | 7.1 | 7.3 | 7 | <0.1 | 175.5 | 15.6 | 232 | 8.3 | | |
| S | 15 | 4.018 | 15.4 | 19.4 | 6.9 | 7.2 | 7.1 | 7.2 | 5.5 | <0.1 | | | 96 | 3.7 | | |
| M | 16 | 4.519 | 15.8 | 19.6 | 6.9 | 7.3 | 7.1 | 7.3 | 7 | <0.1 | | | 112 | 6.3 | | |
| T | 17 | 4.446 | 15.6 | 19.8 | 6.9 | 7.3 | 7.1 | 7.3 | 5 | <0.1 | | | 120 | 5.3 | | |
| W | 18 | 4.311 | 16.1 | 20.5 | 7.3 | 7.4 | 7.4 | 7.4 | 5 | <0.1 | 181.8 | 0.8 | | | | |
| T | 19 | 4.474 | 16.0 | 20.5 | 7.2 | 7.5 | 7.4 | 7.5 | 5 | <0.1 | 347.5 | 1.6 | 100 | 4.8 | | |
| F | 20 | 4.721 | 16.0 | 20.8 | 7.3 | 7.5 | 7.4 | 7.5 | 5 | <0.1 | 169.8 | 4.0 | 116 | 4.5 | | |
| S | 21 | 4.449 | 17.4 | 20.9 | 7.0 | 7.2 | 7.2 | 7.2 | 6 | <0.1 | 143.8 | 3.4 | 124 | 3.5 | | |
| S | 22 | 4.376 | 17.3 | 21.5 | 6.9 | 7.2 | 6.9 | 7.2 | 6 | <0.1 | | | 104 | 4.3 | | |
| M | 23 | 4.400 | 16.3 | 21.4 | 6.8 | 7.2 | 6.8 | 7.1 | 4 | <0.1 | | | 128 | 2.6 | | |
| T | 24 | 4.179 | 17.0 | 21.5 | 6.8 | 7.1 | 6.8 | 6.9 | 9 | <0.1 | | | 208 | 2.6 | | |
| W | 25 | 4.550 | 17.6 | 21.7 | 6.8 | 7.1 | 7.1 | 7.1 | 9.5 | <0.1 | | | 144 | 5.0 | | |
| T | 26 | 5.343 | 17.5 | 20.7 | 6.8 | 7.2 | 6.9 | 7.1 | 6 | <0.1 | 170.7 | 3.5 | 180 | 3.6 | | |
| F | 27 | 4.563 | 17.1 | 20.6 | 6.8 | 7.1 | 7.0 | 7.1 | 7 | <0.1 | 176.3 | 2.8 | 184 | 3.8 | | |
| S | 28 | 4.485 | 16.6 | 20.2 | 6.6 | 7.1 | 6.8 | 7.1 | 6.5 | <0.1 | 179.1 | 5.5 | 164 | 3.6 | | |
| S | 29 | 4.459 | 16.9 | 20.5 | 6.9 | 7.0 | 6.9 | 7.0 | 14 | <0.1 | | | 104 | 1.6 | | |
| M | 30 | 4.706 | 17.7 | 20.6 | 6.7 | 6.9 | 6.7 | 6.9 | 9.5 | <0.1 | | | 96 | 1.2 | | |
| T | 31 | 5.284 | 17.0 | 19.5 | 6.8 | 7.2 | 6.8 | 7.1 | 7 | <0.1 | | | 192 | 3.2 | | |
| AVERAGE | | 4.540 | 16.0 | 19.9 | 6.6 | 7.5 | 6.7 | 7.5 | 14.0 | 0.0 | 191.3 | 5.9 | 132.7 | 4.4 | | |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | 96.9% | 223.7 | 96.7% | 167.1 | | |

NIAGARA COUNTY SEWER DISTRICT #1

Jul-01

| DAY | DATE | FLOW | PHOSPHOROUS | | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|----------|-------------------|----------|------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | | |
| S | 1 | 4.139 | 2.96 | 0.47 | 0.59 | 0.63 | 0.61 | | | |
| M | 2 | 5.431 | 4.25 | 0.48 | 0.32 | 0.58 | 0.44 | | | |
| T | 3 | 3.645 | | | 0.28 | 0.88 | 0.53 | | | |
| W | 4 | 4.967 | 3.24 | 0.64 | 0.64 | 0.84 | 0.75 | 3 | | |
| T | 5 | 4.430 | 3.20 | 0.73 | 0.79 | 0.94 | 0.87 | | | |
| F | 6 | 4.167 | 3.24 | 0.91 | 0.90 | 1.03 | 0.95 | 3 | | |
| S | 7 | 4.167 | 3.32 | 0.92 | 0.94 | 0.99 | 0.97 | 3 | | |
| S | 8 | 4.300 | 2.79 | 0.82 | 0.85 | 0.93 | 0.90 | | | |
| M | 9 | 5.533 | 2.88 | 0.71 | 0.66 | 0.98 | 0.79 | | | |
| T | 10 | 4.567 | | | 0.58 | 0.87 | 0.77 | | | |
| W | 11 | 4.761 | 3.28 | 0.52 | 0.69 | 0.95 | 0.82 | 3 | | |
| T | 12 | 4.675 | 4.62 | 0.56 | 1.04 | 1.11 | 1.07 | | | |
| F | 13 | 3.831 | 3.60 | 0.52 | 0.47 | 1.36 | 0.92 | 48 | | |
| S | 14 | 4.841 | 3.60 | 0.50 | 0.67 | 0.96 | 0.78 | 3 | | |
| S | 15 | 4.018 | 4.98 | 0.65 | 0.56 | 0.63 | 0.59 | | | |
| M | 16 | 4.519 | 3.97 | 0.82 | 0.60 | 0.64 | 0.62 | | | |
| T | 17 | 4.446 | | | 0.45 | 0.53 | 0.49 | | | |
| W | 18 | 4.311 | 3.32 | 0.81 | 0.38 | 0.70 | 0.55 | | | |
| T | 19 | 4.474 | 3.65 | 0.71 | 0.59 | 0.61 | 0.60 | | | |
| F | 20 | 4.721 | 5.10 | 0.68 | 0.42 | 0.66 | 0.53 | 16 | | |
| S | 21 | 4.449 | 2.55 | 0.52 | 0.55 | 1.04 | 0.72 | 4 | | |
| S | 22 | 4.376 | 3.16 | 0.52 | 0.34 | 0.49 | 0.40 | | | |
| M | 23 | 4.400 | 2.67 | 0.44 | 0.24 | 0.54 | 0.35 | | | |
| T | 24 | 4.179 | | | 0.25 | 0.37 | 0.33 | | | |
| W | 25 | 4.550 | 4.13 | 0.48 | 0.14 | 0.28 | 0.22 | | | |
| T | 26 | 5.343 | 4.37 | 0.45 | 0.17 | 0.29 | 0.23 | | | |
| F | 27 | 4.563 | 3.48 | 0.45 | 0.43 | 0.68 | 0.59 | 3 | | |
| S | 28 | 4.485 | 9.51 | 0.56 | 0.51 | 0.57 | 0.54 | 3 | | |
| S | 29 | 4.459 | 4.41 | 0.60 | 0.49 | 0.72 | 0.58 | | | |
| M | 30 | 4.706 | 28.90 | 0.61 | 0.36 | 0.61 | 0.51 | | | |
| T | 31 | 5.284 | | | 0.48 | 0.60 | 0.54 | | | |
| AVERAGE | | 4.540 | 4.85 | 0.62 | 0.14 | 1.36 | 1.07 | 4.8 | | |
| | | | | 23.4 | | | | 12.0 | | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Aug-01

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|-------|----------------|------|----------|----------|----------|----------|-----------|-----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| W | 1 | 4.911 | 17.7 | 21.5 | 6.6 | 7.2 | 6.6 | 7.2 | 10 | <0.1 | 163.1 | 2.1 | | | | |
| T | 2 | 5.044 | 17.5 | 21.3 | 6.9 | 7.3 | 6.9 | 7.1 | 18 | <0.1 | 145.6 | 2.8 | 316 | 6.6 | | |
| F | 3 | 4.052 | 16.9 | 21.6 | 7.0 | 7.3 | 7.1 | 7.1 | 10 | <0.1 | 155.5 | 1.7 | 156 | 1.8 | | |
| S | 4 | 3.872 | 18.2 | 21.7 | 6.8 | 7.1 | 6.8 | 6.9 | 5 | <0.1 | 132.7 | 2.7 | 132 | 2.8 | | |
| S | 5 | 3.716 | 16.9 | 21.3 | 6.9 | 7.3 | 6.9 | 7.0 | 8 | <0.1 | | | 162 | 2.4 | | |
| M | 6 | 3.882 | 16.7 | 21.3 | 6.9 | 7.1 | 6.9 | 7.0 | 6 | <0.1 | | | 196 | 3.6 | | |
| T | 7 | 4.039 | 17.3 | 22.0 | 6.2 | 7.6 | 6.2 | 7.2 | 11 | <0.1 | | | 204 | 3.2 | | |
| W | 8 | 5.284 | 17.8 | 21.2 | 6.8 | 7.2 | 6.9 | 7.2 | 7 | <0.1 | 138.6 | 3.7 | | | | |
| T | 9 | 4.232 | 18.0 | 20.4 | 6.9 | 7.3 | 6.9 | 6.9 | 4.5 | <0.1 | 131.0 | 1.5 | 152 | 3.4 | | |
| F | 10 | 3.557 | 18.0 | 21.1 | 6.7 | 7.2 | 6.7 | 7.0 | 7 | <0.1 | 169.2 | 2.1 | 96 | 2.0 | | |
| S | 11 | 3.947 | 17.7 | 19.4 | 6.9 | 7.2 | 6.9 | 7.0 | 9.5 | <0.1 | 176.8 | 9.1 | 312 | 1.2 | | |
| S | 12 | 4.050 | 16.9 | 20.7 | 6.7 | 7.0 | 6.7 | 6.8 | 9.5 | <0.1 | | | 84 | 1.2 | | |
| M | 13 | 3.944 | 17.7 | 20.7 | 6.7 | 8.0 | 6.7 | 6.8 | 10 | <0.1 | | | 264 | 3.2 | | |
| T | 14 | 4.016 | 17.5 | 20.9 | 6.8 | 7.2 | 6.8 | 7.0 | 7 | <0.1 | | | 196 | 2.2 | | |
| W | 15 | 3.908 | 17.2 | 20.8 | 6.8 | 7.6 | 6.8 | 7.0 | 6.5 | <0.1 | 150.7 | 1.9 | | | | |
| T | 16 | 3.977 | 17.9 | 20.7 | 6.9 | 7.3 | 6.9 | 7.1 | 8 | <0.1 | 149.6 | 1.2 | 216 | 3.8 | | |
| F | 17 | 3.867 | 18.0 | 21.3 | 6.9 | 7.3 | 6.9 | 7.1 | 9 | <0.1 | 141.1 | 2.1 | 196 | 1.2 | | |
| S | 18 | 3.678 | 17.4 | 21.2 | 6.9 | 7.2 | 6.9 | 7.0 | 7 | <0.1 | 144.1 | 1.6 | 200 | 0.6 | | |
| S | 19 | 4.294 | 17.1 | 21.8 | 6.7 | 7.2 | 6.7 | 7.1 | 7 | <0.1 | | | 236 | 1.4 | | |
| M | 20 | 4.526 | 17.9 | 21.3 | 6.8 | 7.4 | 6.8 | 6.9 | 7 | <0.1 | | | 252 | 1.4 | | |
| T | 21 | 4.067 | 17.9 | 21.7 | 6.9 | 7.3 | 6.9 | 7.1 | 9 | <0.1 | | | 232 | 0.2 | | |
| W | 22 | 3.917 | 17.7 | 21.2 | 6.8 | 7.4 | 6.8 | 7.0 | 12 | <0.1 | 211.6 | 4.3 | 276 | 2.2 | | |
| T | 23 | 4.335 | 17.7 | 21.8 | 6.8 | 7.4 | 6.8 | 6.9 | 12 | <0.1 | 158.5 | 4.3 | 216 | 2.0 | | |
| F | 24 | 3.787 | 18.2 | 21.5 | 6.7 | 7.5 | 6.7 | 7.1 | 19 | <0.1 | 232.8 | 2.0 | 440 | 3.6 | | |
| S | 25 | 3.526 | 18.4 | 21.7 | 6.7 | 7.0 | 6.8 | 6.9 | 9 | <0.1 | 247.8 | 4.2 | 205 | 2.2 | | |
| S | 26 | 3.779 | 18.2 | 21.8 | 6.7 | 7.4 | 6.7 | 7.0 | 17.5 | <0.1 | | | 252 | 2.0 | | |
| M | 27 | 3.949 | 18.0 | 21.7 | 6.7 | 7.3 | 6.7 | 6.9 | 11 | <0.1 | | | 204 | 0.8 | | |
| T | 28 | 3.675 | 18.3 | 21.4 | 6.6 | 7.1 | 6.7 | 6.9 | 10.5 | <0.1 | | | 164 | 1.4 | | |
| W | 29 | 3.868 | 18.4 | 22.0 | 6.6 | 7.2 | 6.7 | 7.0 | 23 | <0.1 | 236.4 | 3.0 | 352 | 1.2 | | |
| T | 30 | 3.504 | 18.9 | 21.6 | 6.6 | 7.3 | 6.8 | 7.3 | 20 | <0.1 | 190.6 | 3.4 | | | | |
| F | 31 | 4.259 | 18.5 | 22.5 | 6.7 | 6.9 | 6.7 | 6.8 | 10 | <0.1 | 169.4 | 5.4 | 212 | 2.8 | | |
| AVERAGE | | 4.047 | 17.8 | 21.3 | 6.2 | 8.0 | 6.2 | 7.3 | 23.0 | 0.0 | 169.0 | 3.1 | 220.6 | 2.3 | | |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | 98.2% | 105.9 | 99.0% | 76.0 | | |

NIAGARA COUNTY SEWER DISTRICT #1
Aug-01

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| W | 1 | 4.911 | 6.04 | 0.55 | 0.43 | 0.57 | 0.52 | 15 | |
| T | 2 | 5.044 | 7.81 | 0.47 | 0.19 | 0.33 | 0.28 | | |
| F | 3 | 4.052 | 14.82 | 0.41 | 0.11 | 0.30 | 0.19 | 3 | |
| S | 4 | 3.872 | 10.24 | 0.45 | 0.31 | 0.40 | 0.36 | 8 | |
| S | 5 | 3.716 | 6.44 | 0.48 | 0.14 | 0.31 | 0.21 | | |
| M | 6 | 3.882 | 5.35 | 0.62 | 0.16 | 0.25 | 0.20 | | |
| T | 7 | 4.039 | | | 0.59 | 0.96 | 0.79 | | |
| W | 8 | 5.284 | 5.39 | 0.44 | 0.65 | 0.87 | 0.73 | 3 | |
| T | 9 | 4.232 | 3.65 | 0.32 | 0.65 | 0.78 | 0.72 | | |
| F | 10 | 3.557 | 4.86 | 0.34 | 0.53 | 0.64 | 0.59 | 3 | |
| S | 11 | 3.947 | 5.67 | 0.27 | 0.42 | 0.53 | 0.48 | 3 | |
| S | 12 | 4.050 | 7.29 | 0.31 | 0.21 | 0.27 | 0.24 | | |
| M | 13 | 3.944 | 17.44 | 0.27 | 0.12 | 0.35 | 0.26 | | |
| T | 14 | 4.016 | | | 0.29 | 0.43 | 0.38 | | |
| W | 15 | 3.908 | 7.04 | 0.35 | 0.13 | 0.87 | 0.60 | 3 | |
| T | 16 | 3.977 | 5.99 | 0.29 | 0.97 | 0.99 | 0.98 | | |
| F | 17 | 3.867 | 2.31 | 0.28 | 0.23 | 0.90 | 0.62 | 3 | |
| S | 18 | 3.678 | 4.13 | 0.33 | 0.65 | 0.89 | 0.77 | 3 | |
| S | 19 | 4.294 | 6.07 | 0.31 | 0.65 | 0.89 | 0.79 | | |
| M | 20 | 4.526 | 4.49 | 0.33 | 0.55 | 0.75 | 0.63 | | |
| T | 21 | 4.067 | | | 0.14 | 0.26 | 0.20 | | |
| W | 22 | 3.917 | 5.62 | 0.41 | 0.22 | 0.26 | 0.24 | | |
| T | 23 | 4.335 | 6.72 | 0.41 | 0.12 | 0.26 | 0.18 | | |
| F | 24 | 3.787 | 2.59 | 0.43 | 0.06 | 0.94 | 0.57 | 3 | |
| S | 25 | 3.526 | 4.94 | 0.45 | 0.28 | 0.30 | 0.29 | 30 | |
| S | 26 | 3.779 | 10.70 | 0.41 | 0.20 | 0.75 | 0.40 | | |
| M | 27 | 3.949 | 5.02 | 0.36 | 0.65 | 1.36 | 0.92 | | |
| T | 28 | 3.675 | | | 0.39 | 0.96 | 0.59 | | |
| W | 29 | 3.868 | 10.60 | 0.24 | 0.18 | 0.27 | 0.23 | 3200 | |
| T | 30 | 3.504 | 8.74 | 0.20 | 0.09 | 0.20 | 0.15 | | |
| F | 31 | 4.259 | 3.88 | 0.21 | 0.10 | 0.25 | 0.16 | 123 | |
| AVERAGE | | 4.047 | 6.78 | 0.37 | 0.06 | 1.36 | 0.98 | 10.0 | |
| | | | 12.6 | | | | | 66.0 | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979 Sep-01

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|-------|----------------|------|----------|-----|----------|-----|------------|------------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | MAX | EFF, MIN | MAX | INF, m/l/l | EFF, m/l/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| S | 1 | 4.200 | 17.8 | 21.7 | 7.1 | 7.5 | 6.9 | 7.1 | 18 | <0.1 | 366.8 | 6.1 | 304 | 1.0 | | |
| S | 2 | 4.200 | 17.6 | 21.2 | 7.0 | 7.1 | 6.9 | 7.4 | 15.0 | <0.1 | | | 260 | 2.0 | | |
| M | 3 | 4.218 | 17.6 | 21.0 | 6.9 | 7.3 | 6.7 | 7.1 | 15.0 | <0.1 | | | 244 | 1.4 | | |
| T | 4 | 4.324 | 17.7 | 21.9 | 7.1 | 7.3 | 6.6 | 7.2 | 18.0 | <0.1 | | | 252 | 2.0 | | |
| W | 5 | 4.154 | 17.9 | 21.8 | 7.1 | 7.4 | 6.9 | 7.2 | 18.5 | <0.1 | 199.0 | 6.4 | 280 | 1.8 | | |
| T | 6 | 4.154 | 18.3 | 21.2 | 7.1 | 7.3 | 7.0 | 7.1 | 19.0 | <0.1 | 179.5 | 21.9 | 208 | 2.4 | | |
| F | 7 | 4.429 | 18.1 | 21.6 | 7.1 | 7.2 | 6.7 | 7.1 | 20.0 | <0.1 | 279.4 | 2.4 | 248 | 2.0 | | |
| S | 8 | 4.225 | 17.8 | 22.6 | 7.2 | 7.2 | 6.9 | 7.1 | 20.0 | <0.1 | 240.5 | 3.3 | 276 | 5.8 | | |
| S | 9 | 3.924 | 18.3 | 22.6 | 6.9 | 7.2 | 7.0 | 7.1 | 19.0 | <0.1 | | | 232 | 0.8 | | |
| M | 10 | 3.927 | 18.5 | 22.3 | 6.8 | 7.1 | 6.9 | 7.1 | 19.0 | <0.1 | | | 200 | 1.1 | | |
| T | 11 | 4.239 | 18.1 | 22.5 | 6.9 | 7.0 | 6.9 | 7.0 | 20.0 | <0.1 | | | 268 | 1.1 | | |
| W | 12 | 4.239 | 18.4 | 22.2 | 6.9 | 7.1 | 6.8 | 7.1 | 24.0 | <0.1 | 210.4 | 3.2 | | | | |
| T | 13 | 4.089 | 18.7 | 21.8 | 6.9 | 7.4 | 6.7 | 7.0 | 25.0 | <0.1 | 257.9 | 3.6 | 372 | 2.0 | | |
| F | 14 | 3.924 | 18.3 | 20.8 | 7.0 | 7.2 | 6.9 | 7.2 | 29.0 | <0.1 | 182.3 | 3.6 | 344 | 1.2 | | |
| S | 15 | 3.600 | 18.1 | 21.3 | 7.1 | 7.1 | 6.8 | 6.9 | 25.0 | <0.1 | 283.9 | 1.8 | 276 | 0.8 | | |
| S | 16 | 3.850 | 18.2 | 20.5 | 6.9 | 6.9 | 6.6 | 6.9 | 23.0 | <0.1 | | | 216 | 0.4 | | |
| M | 17 | 3.724 | 18.4 | 20.8 | 6.7 | 7.0 | 6.7 | 6.8 | 15.0 | <0.1 | | | 252 | 0.8 | | |
| T | 18 | 3.825 | 18.6 | 21.6 | 6.7 | 7.1 | 6.5 | 6.6 | 23.0 | <0.1 | | | 128 | 0.6 | | |
| W | 19 | 3.469 | 18.5 | 21.8 | 6.9 | 7.1 | 6.6 | 7.0 | 22.0 | <0.1 | 221.3 | 3.2 | | | | |
| T | 20 | 3.621 | 18.1 | 21.6 | 6.9 | 7.3 | 6.9 | 7.1 | 24.0 | <0.1 | 211.5 | 2.5 | 168 | 0.4 | | |
| F | 21 | 4.417 | 18.4 | 21.5 | 7.2 | 7.4 | 7.0 | 7.1 | 21.0 | <0.1 | 171.2 | 2.1 | 276 | 0.9 | | |
| S | 22 | 4.019 | 18.7 | 20.7 | 7.1 | 7.3 | 6.8 | 7.1 | 19.0 | <0.1 | 230.7 | 2.3 | 184 | 0.8 | | |
| S | 23 | 4.007 | 18.2 | 20.6 | 7.1 | 7.2 | 6.9 | 7.0 | 28.0 | <0.1 | | | 144 | 0.4 | | |
| M | 24 | 3.203 | 19.0 | 20.3 | 7.2 | 7.3 | 6.8 | 7.0 | 24.0 | <0.1 | | | 232 | 0.6 | | |
| T | 25 | 4.567 | 18.4 | 20.4 | 7.1 | 7.3 | 6.8 | 7.1 | 18.0 | <0.1 | | | 492 | 2.6 | | |
| W | 26 | 5.650 | 18.5 | 19.9 | 7.1 | 7.2 | 7.0 | 7.3 | 18.0 | <0.1 | 220.1 | 6.4 | | | | |
| T | 27 | 7.459 | 18.3 | 19.5 | 7.1 | 7.3 | 7.0 | 7.1 | 20.0 | <0.1 | 281.2 | 3.8 | 292 | 1.6 | | |
| F | 28 | 6.850 | 18.3 | 19.6 | 7.0 | 7.1 | 6.8 | 7.1 | 17.0 | <0.1 | 128.7 | 2.5 | 180 | 1.2 | | |
| S | 29 | 4.692 | 18.0 | 20.1 | 7.0 | 7.1 | 6.8 | 6.9 | 16.0 | <0.1 | 171.5 | 2.4 | 172 | 2.0 | | |
| S | 30 | 4.333 | 17.4 | 20.1 | 7.0 | 7.2 | 6.8 | 6.9 | 20.0 | <0.1 | | | 236 | 1.6 | | |
| AVERAGE | | 4.318 | 18.2 | 21.2 | 6.7 | 7.5 | 6.5 | 7.4 | 29.0 | 0.0 | 227.0 | 4.6 | 250.6 | 1.5 | | |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | 98.0% | 175.2 | 99.4% | 53.5 | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
Sep-01

| DAY | DATE | FLOW | PHOSPHOROUS | | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|----------|-------------------|----------|------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | | |
| S | 1 | 4.200 | 7.65 | 0.21 | 0.21 | 0.34 | 0.26 | 540 | | |
| S | 2 | 4.200 | 4.29 | 0.20 | 0.52 | 0.58 | 0.54 | | | |
| M | 3 | 4.218 | 4.45 | 0.24 | 0.52 | 0.79 | 0.63 | | | |
| T | 4 | 4.324 | | | 0.32 | 0.43 | 0.37 | | | |
| W | 5 | 4.154 | 5.50 | 0.38 | 0.00 | 0.92 | 0.45 | 3 | | |
| T | 6 | 4.154 | 6.08 | 0.43 | 0.72 | 1.12 | 0.88 | | | |
| F | 7 | 4.429 | 6.16 | 0.39 | 0.36 | 0.65 | 0.49 | 8 | | |
| S | 8 | 4.225 | 6.16 | 0.44 | 0.39 | 0.66 | 0.55 | 3 | | |
| S | 9 | 3.924 | 4.57 | 0.41 | 0.53 | 0.67 | 0.60 | | | |
| M | 10 | 3.927 | 3.44 | 0.44 | 0.05 | 0.57 | 0.35 | | | |
| T | 11 | 4.239 | | | 0.46 | 0.55 | 0.50 | | | |
| W | 12 | 4.239 | 1.29 | 0.42 | 0.35 | 0.50 | 0.43 | 3 | | |
| T | 13 | 4.089 | 7.24 | 0.46 | 0.06 | 0.68 | 0.27 | | | |
| F | 14 | 3.924 | 6.07 | 0.35 | 0.15 | 0.45 | 0.27 | 66 | | |
| S | 15 | 3.600 | 5.83 | 0.31 | 0.19 | 0.47 | 0.29 | 2100 | | |
| S | 16 | 3.850 | 4.86 | 0.34 | 0.51 | 0.53 | 0.52 | | | |
| M | 17 | 3.724 | 6.03 | 0.26 | 0.00 | 0.52 | 0.25 | | | |
| T | 18 | 3.825 | | | 0.79 | 1.32 | 1.05 | | | |
| W | 19 | 3.469 | 5.30 | 0.25 | 0.49 | 0.53 | 0.51 | 3 | | |
| T | 20 | 3.621 | 4.53 | 0.23 | 0.50 | 0.65 | 0.60 | | | |
| F | 21 | 4.417 | 3.56 | 0.24 | 0.52 | 0.76 | 0.61 | 3 | | |
| S | 22 | 4.019 | 6.32 | 0.33 | 0.58 | 0.68 | 0.62 | 3 | | |
| S | 23 | 4.007 | 4.57 | 0.40 | 0.53 | 0.60 | 0.57 | | | |
| M | 24 | 3.203 | 4.78 | 0.35 | 0.50 | 0.70 | 0.59 | | | |
| T | 25 | 4.567 | | | 0.33 | 0.98 | 0.64 | | | |
| W | 26 | 5.650 | 4.90 | 0.31 | 0.35 | 0.54 | 0.46 | 5 | | |
| T | 27 | 7.459 | 0.57 | 0.28 | 0.25 | 0.68 | 0.51 | | | |
| F | 28 | 6.850 | 3.77 | 0.19 | 0.44 | 0.65 | 0.56 | 3 | | |
| S | 29 | 4.692 | 1.22 | 0.23 | 0.52 | 0.67 | 0.61 | 3 | | |
| S | 30 | 4.333 | 3.73 | 0.28 | 0.47 | 0.51 | 0.49 | | | |
| AVERAGE | | 4.318 | 4.55 | 0.32 | 0.00 | 1.32 | 1.05 | 10.5 | | |
| | | | | 11.4 | | | | 74.5 | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Oct-01

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|----------|----------|----------|-----------|-----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| M | 1 | 4.393 | 17.8 | 20.2 | 6.9 | 7.1 | 6.7 | 6.8 | 12.00 | <0.1 | | | | | 184 | 1.9 |
| T | 2 | 4.505 | 18.0 | 20.7 | 6.8 | 7.3 | 6.9 | 7.1 | 15.00 | <0.1 | | | | | 244 | 2.4 |
| W | 3 | 4.286 | 18.5 | 20.4 | 6.9 | 7.0 | 6.9 | 7.4 | 12.00 | <0.1 | | | | | | |
| T | 4 | 4.096 | 18.3 | 20.7 | 7.3 | 7.4 | 7.0 | 7.2 | 13.00 | <0.1 | 173.2 | 22.8 | | | 180 | 2.3 |
| F | 5 | 5.818 | 18.3 | 20.2 | 7.1 | 7.7 | 7.2 | 7.2 | 10.00 | <0.1 | 174.4 | 2.9 | | | 224 | 2.2 |
| S | 6 | 15.901 | 17.4 | 18.8 | 7.1 | 7.2 | 6.8 | 7.0 | 15.50 | <0.1 | 170.9 | 14.6 | | | 432 | 5.8 |
| S | 7 | 7.935 | 17.6 | 18.4 | 7.1 | 7.3 | 6.9 | 6.9 | 9.00 | <0.1 | | | | | 292 | 3.8 |
| M | 8 | 6.150 | 17.3 | 18.5 | 7.2 | 7.4 | 6.8 | 6.8 | 10.50 | <0.1 | | | | | 88 | 0.2 |
| T | 9 | 5.381 | 17.4 | 18.6 | 7.1 | 7.3 | 6.9 | 7.1 | 16.00 | <0.1 | | | | | 152 | 0.7 |
| W | 10 | 5.339 | 17.7 | 19.5 | 7.3 | 7.4 | 6.9 | 7.1 | 6.50 | <0.1 | 167.7 | 1.5 | | | 184 | 1.6 |
| T | 11 | 5.198 | 17.7 | 20.3 | 7.2 | 7.4 | 7.1 | 7.2 | 10.50 | <0.1 | 197.2 | 2.1 | | | 268 | 2.2 |
| F | 12 | 4.937 | 17.9 | 20.7 | 7.0 | 7.3 | 7.0 | 7.1 | 6.00 | <0.1 | 142.9 | 1.7 | | | 164 | 1.0 |
| S | 13 | 4.767 | 17.7 | 20.6 | 7.2 | 7.3 | 6.9 | 7.1 | 5.00 | <0.1 | 156.8 | 3.0 | | | 136 | 4.0 |
| S | 14 | 4.834 | 17.5 | 21.6 | 7.2 | 7.2 | 7.1 | 7.1 | 4.50 | <0.1 | | | | | 152 | 3.6 |
| M | 15 | 5.624 | 17.5 | 19.8 | 7.3 | 7.5 | 6.9 | 7.0 | 4.00 | <0.1 | | | | | 148 | 4.0 |
| T | 16 | 5.476 | 17.8 | 19.2 | 7.2 | 7.4 | 6.9 | 7.0 | 4.50 | <0.1 | | | | | 156 | 3.2 |
| W | 17 | 8.560 | 17.4 | 18.3 | 7.0 | 7.5 | 7.0 | 7.0 | 4.00 | <0.1 | 132.6 | 3.7 | | | | |
| T | 18 | 6.482 | 17.1 | 18.0 | 7.4 | 7.5 | 7.0 | 7.1 | 4.00 | <0.1 | 92.8 | 1.6 | | | 56 | 2.8 |
| F | 19 | 5.614 | 17.4 | 18.5 | 7.3 | 7.4 | 7.0 | 7.2 | 4.00 | <0.1 | 108.0 | 2.4 | | | 112 | 2.0 |
| S | 20 | 4.886 | 17.1 | 19.5 | 7.3 | 7.4 | 6.9 | 7.1 | 5.00 | <0.1 | 116.4 | 0.9 | | | 80 | 2.0 |
| S | 21 | 5.148 | 17.2 | 19.3 | 7.2 | 7.3 | 7.0 | 7.1 | 4.00 | <0.1 | | | | | 104 | 1.8 |
| M | 22 | 5.257 | 17.5 | 19.4 | 7.2 | 7.3 | 6.9 | 7.1 | 4.00 | <0.1 | | | | | 220 | 1.8 |
| T | 23 | 5.363 | 17.4 | 19.6 | 7.0 | 7.6 | 6.8 | 7.2 | 3.50 | <0.1 | | | | | 136 | 1.0 |
| W | 24 | 5.713 | 17.7 | 19.6 | 7.3 | 7.3 | 6.8 | 7.0 | 6.00 | <0.1 | 147.1 | 2.9 | | | 188 | 2.2 |
| T | 25 | 6.578 | 17.1 | 19.2 | 7.3 | 7.3 | 6.9 | 7.1 | 5.00 | <0.1 | 121.2 | 2.8 | | | 140 | 1.4 |
| F | 26 | 8.168 | 16.8 | 17.5 | 7.3 | 7.4 | 6.9 | 7.0 | 3.00 | <0.1 | 105.5 | 2.7 | | | 92 | 1.2 |
| S | 27 | 5.620 | 16.6 | 17.8 | 7.3 | 7.4 | 7.0 | 7.2 | 5.00 | <0.1 | 124.6 | 1.5 | | | 116 | 2.0 |
| S | 28 | 5.383 | 16.4 | 18.3 | 7.2 | 7.3 | 6.9 | 7.0 | 4.00 | <0.1 | | | | | 188 | 1.8 |
| M | 29 | 4.960 | 16.7 | 17.9 | 7.3 | 7.3 | 6.9 | 7.1 | 4.00 | <0.1 | | | | | 120 | 1.8 |
| T | 30 | 4.858 | 16.6 | 18.5 | 7.2 | 7.3 | 6.9 | 7.1 | 4.00 | <0.1 | | | | | 108 | 1.4 |
| W | 31 | 4.596 | 16.9 | 18.5 | 7.1 | 7.4 | 6.9 | 7.2 | 4.50 | <0.1 | 106.9 | 14.0 | | | | |
| AVERAGE | | 5.865 | 17.4 | 19.3 | 6.8 | 7.7 | 6.7 | 7.4 | 16.0 | 0.0 | 141.0 | 5.6 | | | 183.0 | 2.4 |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | 96.0% | 298.4 | | | 98.7% | 119.5 |

NIAGARA COUNTY SEWER DISTRICT #1

Oct-01

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F.COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|-----------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | |
| M | 1 | 4.393 | 4.29 | 0.35 | 0.48 | 1.48 | 0.83 | |
| T | 2 | 4.505 | | | 0.99 | 1.14 | 1.09 | |
| W | 3 | 4.286 | 3.85 | 0.41 | 0.81 | 1.03 | 0.94 | 3 |
| T | 4 | 4.096 | 2.99 | 0.24 | 0.72 | 1.06 | 0.89 | |
| F | 5 | 5.818 | 1.58 | 0.54 | 0.50 | 0.99 | 0.70 | 3 |
| S | 6 | 15.901 | 8.46 | 0.34 | 0.72 | 1.12 | 0.93 | 3 |
| S | 7 | 7.935 | 2.34 | 0.15 | 0.75 | 0.78 | 0.77 | |
| M | 8 | 6.150 | | | 0.71 | 0.95 | 0.80 | |
| T | 9 | 5.381 | 2.22 | 0.18 | 0.76 | 0.81 | 0.78 | |
| W | 10 | 5.339 | 6.60 | 0.25 | 0.96 | 1.15 | 1.05 | 3 |
| T | 11 | 5.196 | 16.60 | 0.28 | 0.60 | 0.99 | 0.84 | |
| F | 12 | 4.937 | 4.65 | 0.30 | 0.72 | 0.94 | 0.80 | 3 |
| S | 13 | 4.767 | 3.40 | 0.39 | 0.62 | 0.82 | 0.75 | 3 |
| S | 14 | 4.834 | 3.52 | 0.44 | 0.24 | 0.77 | 0.45 | |
| M | 15 | 5.624 | 4.09 | 0.53 | 0.06 | 0.29 | 0.19 | |
| T | 16 | 5.476 | | | 0.00 | 1.23 | 0.47 | |
| W | 17 | 8.560 | 2.83 | 0.61 | 0.73 | 1.00 | 0.91 | 3 |
| T | 18 | 6.482 | 2.02 | 0.47 | 0.88 | 1.27 | 1.02 | |
| F | 19 | 5.614 | 2.51 | 0.49 | 0.58 | 0.94 | 0.75 | 3 |
| S | 20 | 4.886 | 2.79 | 0.42 | 0.78 | 1.00 | 0.91 | 3 |
| S | 21 | 5.148 | 3.32 | 0.44 | 0.91 | 1.18 | 1.03 | |
| M | 22 | 5.257 | 5.67 | 0.43 | 0.58 | 1.05 | 0.82 | |
| T | 23 | 5.363 | | | 0.67 | 0.80 | 0.75 | |
| W | 24 | 5.713 | 4.09 | 0.41 | 0.00 | 0.90 | 0.39 | 3 |
| T | 25 | 6.578 | 2.71 | 0.43 | 0.57 | 0.73 | 0.63 | |
| F | 26 | 8.168 | 2.63 | 0.33 | 0.00 | 0.55 | 0.27 | 3 |
| S | 27 | 5.620 | 2.19 | 0.33 | 0.80 | 0.94 | 0.86 | 3 |
| S | 28 | 5.383 | 3.97 | 0.35 | 0.78 | 0.83 | 0.80 | |
| M | 29 | 4.960 | 3.28 | 0.36 | 0.81 | 1.06 | 0.92 | |
| T | 30 | 4.858 | | | 0.24 | 0.54 | 0.39 | |
| W | 31 | 4.596 | 2.88 | 0.36 | 0.20 | 0.22 | 0.21 | 3800 |
| AVERAGE | | 5.865 | 4.25 | 0.38 | 0.00 | 1.48 | 1.09 | 5.2 |
| | | | | 18.9 | | | | 13.6 |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

Nov-01

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|----------|----------|----------|------------------|----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| T | 1 | 4,612 | 16.8 | 18.5 | 7.2 | 6.9 | 7.3 | 7.0 | 4.5 | <0.1 | 123.5 | 5.9 | 124 | 0.9 |
| F | 2 | 4,642 | 17.0 | 18.7 | 7.0 | 6.8 | 7.3 | 7.0 | 5.0 | <0.1 | 118.6 | 2.0 | 132 | 1.3 |
| S | 3 | 4,234 | 16.7 | 19.1 | 7.0 | 6.9 | 7.3 | 7.1 | 7.0 | <0.1 | 166.4 | 4.1 | 148 | 1.6 |
| S | 4 | 4,694 | 16.4 | 19.4 | 7.1 | 6.8 | 7.3 | 7.1 | 7.0 | <0.1 | | | 120 | 1.8 |
| M | 5 | 4,841 | 16.4 | 18.0 | 6.8 | 6.7 | 7.2 | 7.2 | 5.0 | <0.1 | | | 132 | 1.7 |
| T | 6 | 4,542 | 16.3 | 18.1 | 6.8 | 6.9 | 7.2 | 7.0 | 5.0 | <0.1 | | | 104 | 0.8 |
| W | 7 | 4,678 | 16.3 | 18.5 | 6.8 | 6.9 | 6.9 | 7.2 | 11.0 | <0.1 | 176.2 | 2.0 | 224 | 2.8 |
| T | 8 | 4,686 | 16.4 | 19.1 | 6.9 | 6.8 | 7.2 | 7.0 | 7.5 | <0.1 | 178.7 | 2.1 | 160 | 1.8 |
| F | 9 | 4,969 | 16.2 | 18.8 | 6.9 | 7.0 | 7.4 | 7.0 | 10.0 | <0.1 | 156.8 | 3.0 | 216 | 0.8 |
| S | 10 | 4,781 | 16.3 | 19.1 | 7.1 | 6.9 | 7.1 | 7.0 | 13.0 | <0.1 | 238.5 | 5.0 | 188 | 2.1 |
| S | 11 | 4,616 | 15.7 | 18.4 | 7.0 | 6.9 | 7.1 | 7.0 | 14.0 | <0.1 | | | 224 | 1.0 |
| M | 12 | 4,615 | 15.8 | 18.1 | 7.0 | 6.8 | 7.1 | 7.0 | 14.0 | <0.1 | | | 160 | 1.2 |
| T | 13 | 4,435 | 16.2 | 18.0 | 6.9 | 6.8 | 7.5 | 7.1 | 10.0 | <0.1 | | | 208 | 0.6 |
| W | 14 | 4,495 | 16.2 | 18.4 | 7.2 | 7.0 | 7.5 | 7.1 | 11.0 | <0.1 | 156.9 | 3.0 | 208 | |
| T | 15 | 4,980 | 15.8 | 19.1 | 7.2 | 7.0 | 7.3 | 7.2 | 8.0 | <0.1 | 137.5 | 4.6 | 124 | 1.6 |
| F | 16 | 4,416 | 16.1 | 18.9 | 7.3 | 6.9 | 7.6 | 7.2 | 8.0 | <0.1 | 159.0 | 2.0 | 132 | 1.4 |
| S | 17 | 4,519 | 16.0 | 17.6 | 7.2 | 7.0 | 7.4 | 7.3 | 6.0 | <0.1 | 157.9 | 3.6 | 200 | 1.8 |
| S | 18 | 3,889 | 15.5 | 16.6 | 6.8 | 6.6 | 7.3 | 7.2 | 9.0 | <0.1 | | | 260 | 1.6 |
| M | 19 | 4,765 | 15.7 | 16.5 | 6.8 | 6.9 | 7.1 | 7.0 | 11.0 | <0.1 | | | 220 | 0.6 |
| T | 20 | 5,056 | 15.7 | 15.8 | 6.7 | 6.9 | 7.0 | 7.1 | 8.0 | <0.1 | | | 284 | 1.6 |
| W | 21 | 5,722 | 15.6 | 15.4 | 7.0 | 6.8 | 7.3 | 6.9 | 6.0 | <0.1 | 152.8 | 6.0 | 104 | 1.4 |
| T | 22 | 5,399 | 15.5 | 15.6 | 6.7 | 6.8 | 6.9 | 7.2 | 9.0 | <0.1 | 305.2 | 2.5 | 344 | 3.0 |
| F | 23 | 4,394 | 15.4 | 15.6 | 6.9 | 6.6 | 6.9 | 6.9 | 4.0 | <0.1 | 146.9 | 2.2 | 116 | 1.4 |
| S | 24 | 4,499 | 15.2 | 15.6 | 6.9 | 6.8 | 6.9 | 6.9 | 5.0 | <0.1 | 141.1 | 2.6 | 112 | 1.2 |
| S | 25 | 6,652 | 15.2 | 16.2 | 7.0 | 6.9 | 7.0 | 6.9 | 4.0 | <0.1 | | | 168 | 1.2 |
| M | 26 | 6,116 | 15.2 | 15.6 | 6.9 | 6.8 | 7.0 | 6.9 | 3.0 | <0.1 | | | 96 | 2.0 |
| T | 27 | 6,385 | 15.4 | 17.3 | 6.4 | 6.5 | 7.5 | 7.2 | 3.0 | <0.1 | | | 84 | 1.2 |
| W | 28 | 6,291 | 15.5 | 17.7 | 7.3 | 7.1 | 7.3 | 7.2 | 4.5 | <0.1 | 94.7 | 3.2 | | |
| T | 29 | 9,854 | 14.8 | 16.6 | 7.3 | 7.1 | 7.4 | 7.2 | 5.0 | <0.1 | 112.4 | 3.5 | 96 | 0.6 |
| F | 30 | 13,223 | 14.3 | 15.5 | 7.2 | 7.0 | 7.3 | 7.2 | 1.4 | <0.1 | 56.2 | 5.9 | 92 | 4.0 |
| AVERAGE | | 5,367 | 15.8 | 17.5 | 6.4 | 6.5 | 7.6 | 7.3 | 14.0 | 0.0 | 144.0 | 3.7 | 157.4 | 1.6 |
| | | Monthly | ave. | ave. | min | min | max | max | max | max | 97.4% | 173.7 | 99.0% | 73.7 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
Nov-01

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| T | 1 | 4.612 | 3.85 | 0.34 | 0.08 | 1.23 | 0.73 | | |
| F | 2 | 4.642 | 3.77 | 0.32 | 0.73 | 1.14 | 0.93 | 3 | |
| S | 3 | 4.234 | 4.25 | 0.35 | 0.24 | 0.68 | 0.47 | 3 | |
| S | 4 | 4.694 | | | 0.16 | 0.56 | 0.39 | | |
| M | 5 | 4.841 | 3.84 | 0.42 | 0.66 | 0.81 | 0.71 | | |
| T | 6 | 4.542 | 3.88 | 0.34 | 0.65 | 0.70 | 0.67 | | |
| W | 7 | 4.678 | 5.50 | 0.52 | 0.77 | 0.92 | 0.84 | 3 | |
| T | 8 | 4.686 | 3.96 | 0.50 | 0.61 | 0.84 | 0.75 | | |
| F | 9 | 4.969 | 4.73 | 0.44 | 0.71 | 1.20 | 0.97 | 3 | |
| S | 10 | 4.781 | 4.09 | 0.49 | 0.80 | 1.12 | 0.95 | 3 | |
| S | 11 | 4.616 | 5.91 | 0.53 | 0.85 | 1.10 | 1.00 | | |
| M | 12 | 4.615 | 6.48 | 0.35 | 0.93 | 1.27 | 1.08 | | |
| T | 13 | 4.435 | | | 1.00 | 1.57 | 1.23 | | |
| W | 14 | 4.495 | | | 1.27 | 1.41 | 1.36 | 3 | |
| T | 15 | 4.980 | 3.77 | 0.45 | 1.00 | 1.30 | 1.13 | | |
| F | 16 | 4.416 | 4.09 | 0.41 | 1.10 | 1.57 | 1.26 | 3 | |
| S | 17 | 4.519 | 5.95 | 0.40 | 1.17 | 1.30 | 1.23 | 3 | |
| S | 18 | 3.889 | 10.77 | 0.49 | 1.20 | 1.54 | 1.34 | | |
| M | 19 | 4.765 | 41.10 | 0.39 | 0.36 | 1.36 | 0.71 | | |
| T | 20 | 5.056 | | | 0.12 | 0.23 | 0.17 | | |
| W | 21 | 5.722 | 0.22 | 0.30 | 0.14 | 0.44 | 0.29 | 43 | |
| T | 22 | 5.399 | 10.41 | 0.36 | 0.15 | 0.84 | 0.44 | | |
| F | 23 | 4.394 | 3.81 | 0.40 | 0.18 | 1.22 | 0.54 | 8 | |
| S | 24 | 4.499 | 3.81 | 0.55 | 1.35 | 1.52 | 1.42 | 3 | |
| S | 25 | 6.652 | 3.16 | 0.48 | 0.25 | 0.87 | 0.51 | | |
| M | 26 | 6.116 | 3.40 | 0.37 | 0.46 | 0.95 | 0.69 | | |
| T | 27 | 6.385 | | | 0.20 | 0.36 | 0.25 | | |
| W | 28 | 6.291 | 3.24 | 0.38 | 0.19 | 0.26 | 0.22 | 3933 | |
| T | 29 | 9.854 | 2.31 | 0.30 | 0.70 | 1.08 | 0.84 | | |
| F | 30 | 13.223 | 2.02 | 0.30 | 0.45 | 1.12 | 0.68 | 11 | |
| AVERAGE | | 5.367 | 5.43 | 0.40 | 0.08 | 1.57 | 1.42 | 7.6 | |
| | | | 17.9 | | | | | 17.4 | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Dec-01

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | EFF, MAX | INF, MAX | EFF, MIN | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| S | 1 | 10.065 | 14.4 | 15.3 | 7.1 | 7.4 | 7.1 | 7.2 | 7.1 | 2.00 | <0.1 | 56.5 | 6.6 | 44 | 3.6 | |
| S | 2 | 7.786 | 14.4 | 15.7 | 7.2 | 7.3 | 7.0 | 7.1 | 7.2 | 1.30 | <0.1 | | | 44 | 2.0 | |
| M | 3 | 9.665 | 14.9 | 16.1 | 6.7 | 7.4 | 7.1 | 7.2 | 7.2 | 3.00 | <0.1 | | | 64 | 1.2 | |
| T | 4 | 5.889 | 14.9 | 16.1 | 7.1 | 7.2 | 7.0 | 7.3 | 7.3 | 2.00 | <0.1 | | | 108 | 1.4 | |
| W | 5 | 4.975 | 14.8 | 17.2 | 7.2 | 7.4 | 7.0 | 7.4 | 7.4 | 4.00 | <0.1 | 131.6 | 6.4 | 88 | 0.9 | |
| T | 6 | 5.720 | 15.1 | 16.7 | 7.2 | 7.4 | 6.8 | 7.3 | 7.3 | 7.50 | <0.1 | 123.3 | 3.7 | 208 | 1.2 | |
| F | 7 | 4.847 | 14.9 | 16.4 | 7.2 | 7.6 | 6.8 | 7.3 | 7.3 | 4.00 | <0.1 | 100.1 | 4.5 | 108 | 3.0 | |
| S | 8 | 8.426 | 14.5 | 16.1 | 6.8 | 7.2 | 6.9 | 7.0 | 7.0 | 2.00 | <0.1 | 103.0 | 6.0 | 72 | 1.6 | |
| S | 9 | 4.571 | 14.5 | 16.3 | 7.0 | 7.3 | 6.9 | 7.1 | 7.1 | 3.00 | <0.1 | | | 68 | 1.3 | |
| M | 10 | 7.857 | 14.5 | 15.9 | 7.1 | 7.3 | 6.8 | 7.1 | 7.1 | 3.50 | <0.1 | | | 96 | 1.3 | |
| T | 11 | 4.770 | 15.0 | 16.9 | 7.0 | 7.3 | 7.0 | 7.2 | 7.2 | 12.00 | <0.1 | | | 256 | 1.4 | |
| W | 12 | 4.358 | 14.7 | 16.7 | 6.6 | 7.4 | 6.8 | 7.1 | 7.1 | 8.00 | <0.1 | 160.2 | 3.8 | | | |
| T | 13 | 4.803 | 14.9 | 17.0 | 7.2 | 7.5 | 7.2 | 7.3 | 7.3 | 4.00 | <0.1 | 170.8 | 5.3 | 72 | 0.4 | |
| F | 14 | 5.492 | 14.9 | 17.0 | 7.3 | 7.5 | 7.1 | 7.3 | 7.3 | 7.00 | <0.1 | 100.6 | 4.4 | 108 | 0.3 | |
| S | 15 | 9.874 | 13.5 | 15.8 | 7.3 | 7.5 | 7.1 | 7.2 | 7.2 | 3.00 | <0.1 | 91.9 | 6.9 | 112 | 1.8 | |
| S | 16 | 8.280 | 13.4 | 14.5 | 7.3 | 7.4 | 6.8 | 7.1 | 7.1 | 2.00 | <0.1 | | | 84 | 1.2 | |
| M | 17 | 13.898 | 13.6 | 14.4 | 7.0 | 7.3 | 6.8 | 7.2 | 7.2 | 8.00 | <0.1 | | | 184 | 3.1 | |
| T | 18 | 14.157 | 13.1 | 13.6 | 6.9 | 7.3 | 7.0 | 7.1 | 7.1 | 2.00 | <0.1 | | | 60 | 7.3 | |
| W | 19 | 10.673 | 13.4 | 13.7 | 6.8 | 7.1 | 6.7 | 7.1 | 7.1 | 2.00 | <0.1 | 86.4 | 9.6 | 36 | 3.2 | |
| T | 20 | 9.073 | 13.3 | 14.2 | 6.8 | 7.2 | 6.7 | 7.0 | 7.0 | 3.00 | <0.1 | 63.1 | 15.5 | 32 | 2.3 | |
| F | 21 | 9.990 | 13.3 | 13.9 | 6.8 | 6.9 | 6.8 | 6.9 | 6.9 | 3.00 | <0.1 | 67.6 | 7.1 | 96 | 3.3 | |
| S | 22 | 6.194 | 13.3 | 13.6 | 6.7 | 6.9 | 6.9 | 6.9 | 6.9 | 2.00 | <0.1 | 62.9 | 9.4 | 80 | 4.4 | |
| S | 23 | 6.814 | 13.3 | 13.6 | 6.8 | 7.0 | 6.8 | 7.0 | 7.0 | 5.00 | <0.1 | | | 204 | 5.3 | |
| M | 24 | 7.268 | 13.2 | 13.4 | 6.8 | 7.3 | 6.9 | 6.9 | 6.9 | 2.00 | <0.1 | | | 240 | 1.1 | |
| T | 25 | 7.153 | 13.2 | 12.7 | 7.0 | 7.0 | 6.9 | 7.0 | 7.0 | 2.00 | <0.1 | | | 80 | 1.6 | |
| W | 26 | 6.683 | 13.1 | 12.5 | 6.9 | 7.4 | 6.8 | 7.0 | 7.0 | 2.50 | <0.1 | 80.9 | 3.0 | | | |
| T | 27 | 7.499 | 13.0 | 12.3 | 6.8 | 6.9 | 6.9 | 6.9 | 6.9 | 3.50 | <0.1 | 88.3 | 5.5 | 20 | 4.6 | |
| F | 28 | 7.022 | 13.0 | 12.4 | 6.7 | 7.3 | 6.7 | 6.8 | 6.8 | 2.00 | <0.1 | 63.8 | 2.8 | 48 | 1.3 | |
| S | 29 | 6.741 | 12.9 | 12.2 | 6.8 | 7.0 | 6.9 | 7.0 | 7.0 | 2.50 | <0.1 | 73.0 | 8.0 | 48 | 0.7 | |
| S | 30 | 6.526 | 12.9 | 11.7 | 7.0 | 7.2 | 6.9 | 7.1 | 7.1 | 7.50 | <0.1 | | | 72 | 2.1 | |
| M | 31 | 6.593 | 12.7 | 11.4 | 7.0 | 7.2 | 6.9 | 7.1 | 7.1 | 1.50 | <0.1 | | | 40 | 1.6 | |
| AVERAGE | | | 7.537 | 13.9 | 14.7 | 6.6 | 7.6 | 6.7 | 7.4 | 12.0 | 0.0 | 90.6 | 6.7 | 94.3 | 2.4 | |
| Monthly | | | ave. | ave. | min | max | min | max | max | max | max | 92.6% | 400.3 | 97.5% | 153.1 | |

NIAGARA COUNTY SEWER DISTRICT #1

Dec-01

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| S | 1 | 10.065 | 1.01 | 0.25 | 0.69 | 0.82 | 0.76 | 6 | |
| S | 2 | 7.786 | 1.70 | 0.15 | 0.61 | 1.21 | 0.94 | | |
| M | 3 | 9.665 | 1.94 | 0.24 | 0.65 | 1.30 | 0.88 | | |
| T | 4 | 4.975 | | | 0.85 | 1.05 | 0.94 | | |
| W | 5 | 5.720 | 2.02 | 0.26 | 0.79 | 1.20 | 0.96 | 3 | |
| T | 6 | 4.847 | 5.38 | 0.40 | 0.43 | 0.93 | 0.72 | | |
| F | 7 | 8.426 | 3.68 | 0.38 | 0.21 | 0.24 | 0.22 | 760 | |
| S | 8 | 4.571 | 2.43 | 0.34 | 0.15 | 1.06 | 0.70 | 3 | |
| S | 9 | 7.857 | 12.63 | 0.36 | 0.98 | 1.05 | 1.01 | | |
| M | 10 | 4.770 | 2.95 | 0.43 | 0.77 | 0.92 | 0.84 | | |
| T | 11 | 4.358 | | | 0.70 | 0.81 | 0.76 | | |
| W | 12 | 4.803 | 6.80 | 0.53 | 0.81 | 1.32 | 1.02 | 3 | |
| T | 13 | 5.492 | 3.61 | 0.54 | 0.10 | 0.69 | 0.46 | | |
| F | 14 | 9.874 | 4.37 | 0.62 | 0.78 | 1.41 | 1.04 | 3 | |
| S | 15 | 8.280 | 2.35 | 0.46 | 0.51 | 0.75 | 0.65 | 3 | |
| S | 16 | 13.898 | 1.01 | 0.45 | 0.60 | 0.82 | 0.68 | | |
| M | 17 | 14.157 | 3.12 | 0.42 | 0.28 | 0.75 | 0.51 | | |
| T | 18 | 10.673 | | | 0.56 | 0.63 | 0.59 | | |
| W | 19 | 9.073 | 1.25 | 0.24 | 0.77 | 1.55 | 1.13 | 3 | |
| T | 20 | 9.990 | 1.38 | 0.19 | 1.04 | 1.50 | 1.27 | | |
| F | 21 | 6.194 | 1.58 | 0.18 | 0.60 | 1.18 | 0.87 | 3 | |
| S | 22 | 6.814 | 1.26 | 0.28 | 0.75 | 1.52 | 1.05 | 3 | |
| S | 23 | 7.268 | 2.35 | 0.26 | 1.16 | 1.48 | 1.31 | | |
| M | 24 | 7.153 | 1.78 | 0.35 | 1.05 | 1.31 | 1.15 | | |
| T | 25 | 6.683 | | | 0.64 | 0.87 | 0.74 | | |
| W | 26 | 7.499 | 1.82 | 0.32 | 1.10 | 1.30 | 1.17 | 3 | |
| T | 27 | 7.022 | 1.90 | 0.31 | 0.72 | 0.97 | 0.82 | | |
| F | 28 | 6.741 | 0.49 | 0.22 | 0.80 | 0.95 | 0.89 | 3 | |
| S | 29 | 6.526 | 5.71 | 0.24 | 0.73 | 0.99 | 0.82 | 3 | |
| S | 30 | 6.593 | 1.45 | 0.48 | 0.66 | 0.71 | 0.68 | | |
| M | 31 | 0.000 | 2.14 | 0.46 | 0.18 | 0.44 | 0.33 | | |
| AVERAGE | | 7.348 | 2.86 | 0.35 | 0.10 | 1.55 | 1.31 | 4.9 | 24.3 |
| | | | 22.1 | | | | | | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Jan-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 CERT. 4A

FRANK A. Nerone, P.E.

| DAY | DATE | FLOW | TEMPERATURE, C | | PH | | PH | | PH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|---------|---------|----------|-----------|-----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | PH, MAX | PH, MIN | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| T | 1 | 6.365 | 12.6 | 11.2 | 6.7 | 7.2 | 6.8 | 7.3 | 2.00 | <0.1 | | | | 5 | 1.9 | |
| W | 2 | 6.395 | 12.7 | 11.7 | 7.2 | 7.4 | 7.3 | 7.4 | 4.00 | <0.1 | 97.0 | 2.7 | 88 | 1.7 | | |
| T | 3 | 6.037 | 12.9 | 12.4 | 7.3 | 7.3 | 7.1 | 7.2 | 3.00 | <0.1 | 80.8 | 7.3 | 60 | 1.2 | | |
| F | 4 | 5.961 | 13.0 | 13.3 | 7.3 | 7.4 | 7.1 | 7.2 | 6.50 | <0.1 | 82.9 | 2.8 | 136 | 1.8 | | |
| S | 5 | 6.378 | 12.8 | 13.5 | 7.3 | 7.4 | 7.1 | 7.2 | 2.00 | <0.1 | 70.7 | 2.8 | 56 | 2.9 | | |
| S | 6 | 6.002 | 12.7 | 14.3 | 7.3 | 7.4 | 7.2 | 7.4 | 3.00 | <0.1 | | | 48 | 1.1 | | |
| M | 7 | 6.933 | 12.6 | 13.8 | 7.1 | 7.4 | 7.0 | 7.2 | 2.00 | <0.1 | | | 56 | 1.6 | | |
| T | 8 | 6.697 | 12.7 | 13.0 | 7.1 | 7.6 | 7.1 | 7.4 | 7.00 | <0.1 | | | 196 | 1.4 | | |
| W | 9 | 5.938 | 12.6 | 13.2 | 7.3 | 7.4 | 7.2 | 7.2 | 9.50 | <0.1 | 157.2 | 4.0 | | | | |
| T | 10 | 13.151 | 11.7 | 12.9 | 7.2 | 7.4 | 7.1 | 7.1 | 6.00 | <0.1 | 64.6 | 21.2 | 148 | 8.6 | | |
| F | 11 | 11.321 | 11.3 | 12.4 | 7.3 | 7.4 | 7.0 | 7.3 | 2.00 | <0.1 | 51.1 | 5.3 | 48 | 2.3 | | |
| S | 12 | 21.389 | 11.2 | 12.2 | 7.3 | 7.3 | 7.1 | 7.2 | 2.00 | <0.1 | 42.0 | 5.0 | 68 | 2.2 | | |
| S | 13 | 9.630 | 11.4 | 11.8 | 7.2 | 7.3 | 7.1 | 7.2 | 3.00 | <0.1 | | | 48 | 2.6 | | |
| M | 14 | 9.434 | 11.5 | 12.1 | 7.2 | 7.2 | 7.2 | 7.3 | 4.00 | <0.1 | | | 88 | 2.4 | | |
| T | 15 | 11.155 | 12.4 | 11.8 | 7.1 | 7.3 | 7.2 | 7.6 | 9.50 | <0.1 | | | 132 | 2.2 | | |
| W | 16 | 9.853 | 11.7 | 12.3 | 7.2 | 7.3 | 7.2 | 7.7 | 7.50 | <0.1 | 111.9 | 9.7 | 160 | 2.0 | | |
| T | 17 | 9.006 | 11.7 | 12.4 | 7.2 | 7.4 | 7.1 | 7.3 | 11.00 | <0.1 | 108.4 | 5.5 | 128 | 2.2 | | |
| F | 18 | 7.771 | 11.6 | 11.9 | 7.3 | 7.4 | 7.2 | 7.3 | 12.00 | <0.1 | 180.8 | 7.6 | 180 | 1.6 | | |
| S | 19 | 6.611 | 11.7 | 11.9 | 7.1 | 7.3 | 7.1 | 7.3 | 14.00 | <0.1 | 204.0 | 4.5 | 275 | 1.6 | | |
| S | 20 | 6.865 | 11.7 | 11.7 | 7.0 | 7.3 | 7.1 | 7.3 | 12.00 | <0.1 | | | 160 | 2.6 | | |
| M | 21 | 6.500 | 11.9 | 11.8 | 6.9 | 7.6 | 7.0 | 7.2 | 14.00 | <0.1 | | | 124 | 2.2 | | |
| T | 22 | 6.980 | 12.0 | 13.3 | 6.8 | 7.5 | 6.9 | 7.3 | 15.00 | <0.1 | | | 188 | 4.4 | | |
| W | 23 | 7.460 | 11.8 | 13.0 | 6.9 | 7.5 | 7.1 | 7.3 | 15.00 | <0.1 | 126.3 | 25.8 | | | | |
| T | 24 | 13.988 | 11.3 | 12.8 | 7.4 | 7.4 | 7.3 | 7.4 | 12.00 | <0.1 | 162.6 | 8.8 | 272 | 4.8 | | |
| F | 25 | 12.761 | 10.7 | 11.2 | 6.9 | 7.2 | 7.0 | 7.2 | 10.00 | <0.1 | 154.8 | 7.1 | 104 | 5.0 | | |
| S | 26 | 9.528 | 11.1 | 12.1 | 7.2 | 7.3 | 7.2 | 7.2 | 10.00 | <0.1 | 81.2 | 6.7 | 128 | 3.8 | | |
| S | 27 | 9.786 | 11.3 | 11.6 | 7.3 | 7.4 | 7.3 | 7.4 | 14.00 | <0.1 | | | 84 | 2.2 | | |
| M | 28 | 7.880 | 11.7 | 11.8 | 7.2 | 7.5 | 7.0 | 7.3 | 15.00 | <0.1 | | | 148 | 3.6 | | |
| T | 29 | 8.272 | 11.9 | 12.6 | 7.3 | 7.3 | 7.1 | 7.3 | 15.00 | <0.1 | | | 140 | 3.0 | | |
| W | 30 | 7.754 | 11.7 | 12.5 | 7.3 | 7.5 | 7.2 | 7.5 | 18.00 | <0.1 | 175.0 | 4.1 | 172 | 1.4 | | |
| T | 31 | 8.232 | 11.5 | 11.9 | 7.5 | 7.5 | 7.0 | 7.4 | 18.00 | <0.1 | 192.9 | 11.1 | 144 | 2.2 | | |
| AVERAGE | | 8.775 | 11.9 | 12.4 | 6.7 | 7.6 | 6.8 | 7.7 | 18.0 | 0.0 | 112.4 | 8.2 | 123.7 | 2.9 | | |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | 92.7% | 645.3 | 97.7% | 213.1 | | |

NIAGARA COUNTY SEWER DISTRICT #1

Jan-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | |
| T | 1 | 6.365 | | | 0.03 | 0.38 | 0.24 | |
| W | 2 | 6.395 | 2.26 | 0.62 | 0.05 | 0.93 | 0.62 | 3 |
| T | 3 | 6.037 | 3.44 | 0.60 | 0.73 | 0.80 | 0.77 | |
| F | 4 | 5.961 | 4.45 | 0.54 | 0.92 | 1.12 | 1.01 | 3 |
| S | 5 | 6.378 | 2.35 | 0.97 | 0.80 | 0.97 | 0.88 | 3 |
| S | 6 | 6.002 | 2.91 | 0.77 | 0.52 | 0.99 | 0.82 | |
| M | 7 | 6.933 | 1.94 | 0.78 | 0.52 | 1.01 | 0.77 | |
| T | 8 | 6.697 | | | 0.59 | 0.72 | 0.67 | |
| W | 9 | 5.938 | 4.29 | 0.50 | 0.51 | 0.99 | 0.75 | 3 |
| T | 10 | 13.151 | 2.31 | 0.48 | 0.15 | 0.54 | 0.29 | |
| F | 11 | 11.321 | 1.74 | 0.40 | 0.30 | 0.37 | 0.34 | 15 |
| S | 12 | 21.389 | 2.55 | 0.23 | 0.32 | 0.76 | 0.48 | 333 |
| S | 13 | 9.630 | 3.32 | 0.32 | 0.44 | 0.69 | 0.58 | |
| M | 14 | 9.434 | 3.07 | 0.37 | 0.23 | 0.50 | 0.40 | |
| T | 15 | 11.155 | | | 0.09 | 0.54 | 0.32 | |
| W | 16 | 9.853 | 4.33 | 0.35 | 0.00 | 0.32 | 0.21 | 1333 |
| T | 17 | 9.006 | 3.04 | 0.36 | 0.09 | 1.06 | 0.45 | |
| F | 18 | 7.771 | 6.48 | 0.36 | 0.74 | 1.10 | 0.97 | 3 |
| S | 19 | 6.611 | 4.54 | 0.40 | 0.77 | 0.88 | 0.81 | 3 |
| S | 20 | 6.865 | 4.25 | 0.46 | 0.30 | 0.83 | 0.49 | |
| M | 21 | 6.500 | 4.86 | 0.53 | 0.17 | 1.22 | 0.56 | |
| T | 22 | 6.980 | | | 1.00 | 1.26 | 1.10 | |
| W | 23 | 7.460 | 4.90 | 0.69 | 0.85 | 1.01 | 0.94 | |
| T | 24 | 13.988 | 4.50 | 0.49 | 0.93 | 1.46 | 1.22 | |
| F | 25 | 12.761 | 3.12 | 0.29 | 0.74 | 0.96 | 0.88 | 3 |
| S | 26 | 9.528 | 2.59 | 0.24 | 0.70 | 0.83 | 0.76 | 3 |
| S | 27 | 9.786 | 2.63 | 0.32 | 0.47 | 1.17 | 0.86 | |
| M | 28 | 7.880 | 3.76 | 0.33 | 0.63 | 1.60 | 1.00 | |
| T | 29 | 8.272 | | | 0.97 | 1.19 | 1.05 | |
| W | 30 | 7.754 | 3.32 | 0.52 | 0.75 | 1.29 | 1.07 | 3 |
| T | 31 | 8.232 | 3.24 | 0.62 | 0.75 | 1.00 | 0.86 | |
| AVERAGE | | 8.775 | 3.47 | 0.47 | 0.00 | 1.60 | 1.22 | 8.4 |
| | | | | 35.2 | | | | 186.3 |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Feb-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| F | 1 | 23.136 | 10.9 | 10.6 | 7.2 | 7.4 | 7.6 | 7.5 | 2 | <0.1 | 161.5 | 17.4 | 448 | 15.6 |
| S | 2 | 16.699 | 9.2 | 9.4 | 7.2 | 7.2 | 7.4 | 7.3 | 7.0 | <0.1 | 99.9 | 12.5 | 92 | 13.6 |
| S | 3 | 15.066 | 10.3 | 11.3 | 7.3 | 7.3 | 7.5 | 7.4 | 8.0 | <0.1 | | | 100 | 10.8 |
| M | 4 | 11.094 | 10.9 | 10.6 | 7.0 | 7.1 | 7.6 | 7.3 | 13.0 | <0.1 | | | 184 | 4.4 |
| T | 5 | 9.842 | 10.9 | 11.3 | 6.7 | 6.8 | 7.6 | 7.3 | 11.0 | <0.1 | | | 80 | 2.8 |
| W | 6 | 8.875 | 11.1 | 11.3 | 7.2 | 7.2 | 7.6 | 7.5 | 17.0 | <0.1 | 164.5 | 8.4 | | |
| T | 7 | 8.875 | 11.1 | 11.6 | 7.2 | 7.3 | 7.5 | 7.4 | 18.0 | <0.1 | 244.5 | 7.2 | 244 | 4.8 |
| F | 8 | 9.188 | 11.0 | 12.1 | 7.4 | 7.4 | 7.5 | 7.5 | 17.0 | <0.1 | 179.8 | 4.5 | 92 | 1.8 |
| S | 9 | 10.504 | 10.5 | 11.4 | 7.5 | 7.5 | 7.6 | 7.5 | 19.0 | <0.1 | 185.6 | 4.6 | 196 | 9.4 |
| S | 10 | 10.490 | 10.8 | 11.2 | 7.3 | 7.3 | 7.6 | 7.4 | 16.0 | <0.1 | | | 120 | 2.8 |
| M | 11 | 14.123 | 10.2 | 10.5 | 6.5 | 7.3 | 7.4 | 7.4 | 18.0 | <0.1 | | | 200 | 7.2 |
| T | 12 | 11.644 | 10.0 | 10.1 | 7.3 | 7.3 | 7.5 | 7.5 | 15.0 | <0.1 | | | 228 | 5.0 |
| W | 13 | 11.207 | 10.1 | 10.3 | 7.3 | 7.3 | 7.5 | 7.4 | 17.0 | <0.1 | 146.3 | 8.1 | 196 | 5.2 |
| T | 14 | 9.655 | 9.9 | 10.5 | 7.4 | 7.4 | 7.5 | 7.5 | 20.0 | <0.1 | 196.1 | 10.0 | 308 | 5.8 |
| F | 15 | 9.858 | 10.2 | 10.9 | 7.2 | 7.2 | 7.4 | 7.3 | 21.0 | <0.1 | 194.7 | 6.3 | 348 | 12.2 |
| S | 16 | 13.230 | 10.0 | 10.7 | 7.2 | 7.2 | 7.4 | 7.3 | 24.0 | <0.1 | 87.3 | 5.1 | 392 | 6.4 |
| S | 17 | 12.023 | 9.6 | 10.1 | 7.2 | 7.2 | 7.4 | 7.4 | 25.0 | <0.1 | | | 172 | 4.0 |
| M | 18 | 10.766 | 9.7 | 9.8 | 7.2 | 7.2 | 7.4 | 7.3 | 21.0 | <0.1 | | | 172 | 1.6 |
| T | 19 | 9.445 | 10.1 | 10.4 | 7.2 | 7.2 | 7.7 | 7.7 | 19.0 | <0.1 | | | 284 | 4.8 |
| W | 20 | 9.634 | 10.1 | 11.1 | 7.2 | 7.2 | 7.5 | 7.4 | 21.0 | <0.1 | 195.6 | 6.4 | | |
| T | 21 | 14.768 | 9.6 | 10.4 | 7.2 | 7.2 | 7.5 | 7.3 | 22.0 | <0.1 | 183.6 | 11.8 | 180 | 6.2 |
| F | 22 | 12.300 | 9.6 | 10.0 | 7.2 | 7.3 | 7.4 | 7.3 | 20.5 | <0.1 | 125.1 | 9.2 | 132 | 10.2 |
| S | 23 | 10.248 | 9.6 | 10.2 | 7.2 | 7.2 | 7.4 | 7.3 | 18.0 | <0.1 | 114.9 | 12.9 | 92 | 6.0 |
| S | 24 | 9.327 | 9.8 | 10.5 | 7.1 | 7.1 | 7.5 | 7.3 | 25.0 | <0.1 | | | 224 | 9.6 |
| M | 25 | 9.086 | 10.2 | 11.7 | 7.1 | 7.1 | 7.5 | 7.5 | 23.0 | <0.1 | | | 152 | 4.2 |
| T | 26 | 8.893 | 10.4 | 11.5 | 7.2 | 7.2 | 7.5 | 7.3 | 20.0 | <0.1 | | | 188 | 8.0 |
| W | 27 | 8.773 | 10.3 | 10.5 | 7.3 | 7.3 | 7.4 | 7.3 | 18.0 | <0.1 | 195.7 | 5.3 | 224 | 7.0 |
| T | 28 | 8.420 | 10.2 | 10.8 | 6.8 | 7.2 | 7.4 | 7.3 | 24.0 | <0.1 | 190.0 | 14.1 | 244 | 9.2 |
| AVERAGE | | 11.327 | 10.2 | 10.7 | 6.5 | 6.8 | 7.7 | 7.7 | 25.0 | 0.0 | 161.1 | 9.4 | 205.7 | 7.4 |
| | | Monthly | ave. | ave. | min | min | max | max | max | max | 94.2% | 922.2 | 96.4% | 712.2 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
Feb-02

| DAY | DATE | FLOW | PHOSPHOROUS | | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|----------|-------------------|----------|------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | | |
| F | 1 | 23.136 | 4.21 | 0.62 | 0.53 | 0.88 | 0.65 | 20 | | |
| S | 2 | 16.699 | 1.94 | 0.43 | 0.21 | 0.88 | 0.63 | 38 | | |
| S | 3 | 15.066 | 2.51 | 0.39 | 0.42 | 0.80 | 0.56 | | | |
| M | 4 | 11.094 | 3.44 | 0.36 | 0.57 | 0.88 | 0.74 | | | |
| T | 5 | 9.842 | | | 0.48 | 0.84 | 0.60 | | | |
| W | 6 | 8.875 | 2.79 | 0.51 | 0.56 | 0.67 | 0.61 | 3 | | |
| T | 7 | 8.875 | 2.47 | 0.46 | 0.57 | 0.78 | 0.66 | | | |
| F | 8 | 9.188 | 2.47 | 0.38 | 0.42 | 1.00 | 0.78 | 3 | | |
| S | 9 | 10.504 | 3.93 | 0.59 | 0.68 | 0.78 | 0.72 | 3 | | |
| S | 10 | 10.490 | 3.40 | 0.67 | 0.56 | 0.90 | 0.78 | | | |
| M | 11 | 14.123 | 1.42 | 0.66 | 0.48 | 0.70 | 0.60 | | | |
| T | 12 | 11.644 | | | 0.55 | 0.75 | 0.66 | | | |
| W | 13 | 11.207 | 4.74 | 0.75 | 0.65 | 0.83 | 0.77 | 3 | | |
| T | 14 | 9.655 | 4.21 | 0.87 | 0.32 | 0.88 | 0.68 | | | |
| F | 15 | 9.858 | 4.54 | 0.83 | 0.51 | 0.85 | 0.67 | 3 | | |
| S | 16 | 13.230 | 4.50 | 0.79 | 0.61 | 0.65 | 0.63 | 3 | | |
| S | 17 | 12.023 | 4.25 | 0.66 | 0.59 | 0.69 | 0.64 | | | |
| M | 18 | 10.766 | 4.99 | 0.57 | 0.52 | 0.72 | 0.64 | | | |
| T | 19 | 9.445 | | | 0.48 | 0.88 | 0.70 | | | |
| W | 20 | 9.634 | 4.25 | 0.72 | 0.56 | 0.73 | 0.62 | 3 | | |
| T | 21 | 14.768 | 0.94 | 0.76 | 0.56 | 1.18 | 0.78 | | | |
| F | 22 | 12.300 | 3.31 | 0.67 | 0.03 | 0.77 | 0.47 | 6 | | |
| S | 23 | 10.248 | 3.59 | 0.63 | 0.00 | 0.88 | 0.39 | 3 | | |
| S | 24 | 9.327 | | | 0.18 | 1.06 | 0.70 | | | |
| M | 25 | 9.086 | 4.68 | 0.64 | 0.62 | 0.90 | 0.78 | | | |
| T | 26 | 8.893 | 6.04 | 0.72 | 0.62 | 1.10 | 0.82 | | | |
| W | 27 | 8.773 | 4.01 | 0.64 | 0.85 | 1.47 | 1.16 | | | |
| T | 28 | 8.420 | 7.80 | 0.64 | 0.00 | 0.57 | 0.31 | | | |
| AVERAGE | | 11.327 | 3.63 | 0.63 | 0.00 | 1.47 | 1.16 | 4.8 | | |
| | | | | 60.5 | | | | 13.2 | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Mar-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | | pH | | | SETT SOLIDS, 1HR | | | CBOD | | SUSP SOLIDS | |
|----------------|------|--------|----------------|------|----------|----------|----------|----------|------------------|----------|----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | EFF, MIN | INF, MIN | EFF, MAX | EFF, MIN | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| F | 1 | 7.408 | 10.3 | 10.6 | 7.1 | 7.4 | 7.2 | 7.4 | 14.00 | <0.1 | 167.8 | 16.6 | 148 | 8.0 | |
| S | 2 | 7.608 | 10.3 | 10.7 | 7.3 | 7.5 | 7.3 | 7.4 | 30.00 | <0.1 | 177.4 | 25.2 | 236 | 8.0 | |
| S | 3 | 15.363 | 9.8 | 10.5 | 7.2 | 7.4 | 7.2 | 7.3 | 25.00 | <0.1 | | | 320 | 14.8 | |
| M | 4 | 11.624 | 9.6 | 9.6 | 7.1 | 7.3 | 7.2 | 7.4 | 15.00 | <0.1 | | | 176 | 9.2 | |
| T | 5 | 8.774 | 10.0 | 10.0 | 7.2 | 7.3 | 7.3 | 7.4 | 18.00 | <0.1 | | | 184 | 8.0 | |
| W | 6 | 6.679 | 10.1 | 10.4 | 6.7 | 7.5 | 6.9 | 7.3 | 7.00 | <0.1 | 180.7 | 6.3 | | | |
| T | 7 | 9.264 | 10.1 | 11.2 | 7.5 | 7.5 | 7.3 | 7.4 | 14.00 | <0.1 | 222.8 | 29.5 | 244 | 3.6 | |
| F | 8 | 9.177 | 10.5 | 11.5 | 7.4 | 7.4 | 7.2 | 7.3 | 21.00 | <0.1 | 182.2 | 3.5 | 188 | 3.6 | |
| S | 9 | 14.403 | 10.1 | 11.7 | 7.4 | 7.4 | 7.2 | 7.3 | 18.00 | <0.1 | 127.7 | 4.5 | 163 | 5.0 | |
| S | 10 | 9.870 | 9.8 | 10.3 | 7.3 | 7.7 | 7.4 | 7.6 | 19.00 | <0.1 | | | 124 | 8.4 | |
| M | 11 | 9.457 | 9.8 | 10.0 | 6.7 | 7.5 | 6.5 | 7.2 | 19.00 | <0.1 | | | 172 | 8.2 | |
| T | 12 | 9.137 | 9.9 | 10.8 | 6.8 | 7.8 | 7.0 | 7.6 | 19.00 | <0.1 | | | 232 | 3.4 | |
| W | 13 | 9.136 | 10.5 | 11.5 | 7.2 | 7.9 | 7.3 | 7.7 | 20.00 | <0.1 | 306.2 | 4.5 | | | |
| T | 14 | 7.700 | 10.6 | 12.1 | 7.2 | 7.5 | 7.2 | 7.4 | 20.00 | <0.1 | 228.3 | 7.4 | 248 | 3.6 | |
| F | 15 | 7.449 | 10.8 | 11.6 | 7.2 | 7.3 | 7.2 | 7.2 | 24.00 | <0.1 | 220.1 | 4.4 | 268 | 2.4 | |
| S | 16 | 7.284 | 10.7 | 12.0 | 7.2 | 7.3 | 7.0 | 7.2 | 25.00 | <0.1 | 187.0 | 5.5 | 244 | 3.4 | |
| S | 17 | 5.919 | 10.6 | 11.8 | 7.1 | 7.3 | 7.1 | 7.1 | 14.00 | <0.1 | | | 156 | 1.8 | |
| M | 18 | 7.854 | 10.7 | 12.0 | 6.6 | 7.4 | 6.9 | 7.4 | 25.00 | <0.1 | | | 284 | 3.4 | |
| T | 19 | 6.781 | 10.5 | 11.9 | 7.1 | 7.9 | 6.8 | 7.7 | 22.00 | <0.1 | | | | | |
| W | 20 | 7.206 | 10.6 | 11.9 | 7.3 | 7.5 | 7.3 | 7.3 | 12.00 | <0.1 | 189.4 | 7.1 | 176 | 4.2 | |
| T | 21 | 9.296 | 10.6 | 11.5 | 7.3 | 7.5 | 7.1 | 7.2 | 13.50 | <0.1 | 182.2 | 12.2 | 164 | 6.6 | |
| F | 22 | 9.322 | 10.4 | 10.9 | 6.9 | 7.2 | 7.0 | 7.2 | 25.00 | <0.1 | 225.3 | 3.1 | 192 | 3.4 | |
| S | 23 | 7.714 | 10.2 | 10.5 | 7.1 | 7.5 | 7.0 | 7.1 | 25.50 | <0.1 | 199.8 | 5.0 | 232 | 2.4 | |
| S | 24 | 7.306 | 10.2 | 11.1 | 7.1 | 7.3 | 7.0 | 7.2 | 28.00 | <0.1 | | | 272 | 2.4 | |
| M | 25 | 6.614 | 10.3 | 10.9 | 7.2 | 7.4 | 7.0 | 7.2 | 22.00 | <0.1 | | | 232 | 2.6 | |
| T | 26 | 7.010 | 10.5 | 11.0 | 6.7 | 7.0 | 7.0 | 7.2 | 21.00 | <0.1 | | | 312 | 2.8 | |
| W | 27 | 8.463 | 10.1 | 11.0 | 7.3 | 7.4 | 7.2 | 7.3 | 28.00 | <0.1 | 266.5 | 7.2 | | | |
| T | 28 | 10.348 | 10.0 | 10.7 | 7.2 | 7.4 | 7.2 | 7.3 | 23.00 | <0.1 | 211.8 | 13.1 | 268 | 5.0 | |
| F | 29 | 10.008 | 10.2 | 11.8 | 7.2 | 7.4 | 7.1 | 7.3 | 33.00 | <0.1 | 296.0 | 7.2 | 196 | 3.2 | |
| S | 30 | 17.389 | 9.5 | 10.6 | 7.2 | 7.3 | 7.1 | 7.2 | 17.00 | <0.1 | 278.6 | 19.8 | 440 | 14.3 | |
| S | 31 | 12.479 | 9.6 | 10.2 | 7.0 | 7.2 | 7.1 | 7.3 | 15.00 | <0.1 | | | 168 | 6.8 | |
| AVERAGE | | | 9.163 | 10.2 | 11.0 | 7.9 | 6.6 | 7.7 | 30.0 | 0.0 | 216.4 | 10.5 | 229.9 | 6.2 | |
| Monthly | | | ave. | ave. | min | max | min | max | max | max | 95.1% | 807.7 | 97.3% | 486.7 | |

NIAGARA COUNTY SEWER DISTRICT #1

Mar-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| F | 1 | 7.408 | 1.99 | 0.71 | 0.05 | 0.25 | 0.13 | 64 | |
| S | 2 | 7.608 | 1.40 | 0.67 | 0.00 | 0.27 | 0.15 | 2900 | |
| S | 3 | 15.363 | 4.52 | 0.62 | 0.15 | 0.18 | 0.17 | | |
| M | 4 | 11.624 | 2.42 | 0.65 | 0.00 | 0.24 | 0.11 | | |
| T | 5 | 8.774 | | | 0.66 | 0.72 | 0.70 | | |
| W | 6 | 6.679 | 2.34 | 0.75 | 0.72 | 1.02 | 0.84 | 3 | |
| T | 7 | 9.264 | 17.55 | 0.47 | 0.72 | 0.80 | 0.77 | | |
| F | 8 | 9.177 | 5.46 | 0.48 | 0.00 | 1.10 | 0.71 | 3 | |
| S | 9 | 14.403 | 5.50 | 0.47 | 0.88 | 1.20 | 1.05 | 3 | |
| S | 10 | 9.870 | 6.35 | 0.55 | 1.06 | 1.48 | 1.28 | | |
| M | 11 | 9.457 | 3.35 | 0.64 | 0.65 | 1.20 | 0.98 | | |
| T | 12 | 9.137 | | | 0.07 | 0.48 | 0.29 | | |
| W | 13 | 9.136 | 5.15 | 0.55 | 0.43 | 1.25 | 0.73 | 3 | |
| T | 14 | 7.700 | 4.41 | 0.50 | 0.10 | 0.20 | 0.15 | | |
| F | 15 | 7.449 | 3.59 | 0.59 | 0.98 | 1.24 | 1.09 | 3 | |
| S | 16 | 7.284 | 2.85 | 0.51 | 0.92 | 1.00 | 0.97 | 3 | |
| S | 17 | 5.919 | 4.45 | 0.70 | 1.04 | 1.27 | 1.15 | | |
| M | 18 | 7.854 | 7.45 | 0.82 | 0.89 | 1.30 | 1.04 | | |
| T | 19 | 6.781 | | | 0.74 | 0.95 | 0.87 | | |
| W | 20 | 7.206 | 3.08 | 0.91 | 0.38 | 1.00 | 0.70 | 3 | |
| T | 21 | 9.296 | 3.40 | 0.57 | 0.71 | 0.85 | 0.78 | 3 | |
| F | 22 | 9.322 | 3.78 | 0.50 | 0.67 | 0.78 | 0.72 | | |
| S | 23 | 7.714 | 3.51 | 0.48 | 0.86 | 1.08 | 0.95 | 3 | |
| S | 24 | 7.306 | 6.28 | 0.53 | 0.42 | 1.08 | 0.69 | | |
| M | 25 | 6.614 | 8.19 | 0.56 | 0.82 | 0.93 | 0.87 | | |
| T | 26 | 7.010 | | | 0.95 | 1.11 | 1.05 | | |
| W | 27 | 8.463 | 5.46 | 0.40 | 0.73 | 0.98 | 0.82 | 3 | |
| T | 28 | 10.348 | 0.54 | 0.30 | 1.08 | 1.20 | 1.12 | | |
| F | 29 | 10.008 | 2.83 | 0.24 | 0.00 | 0.41 | 0.26 | 37 | |
| S | 30 | 17.389 | 4.52 | 0.45 | 0.90 | 1.40 | 1.15 | 3 | |
| S | 31 | 12.479 | 1.48 | 0.36 | 0.41 | 1.20 | 0.80 | | |
| AVERAGE | | 9.163 | 4.61 | 0.55 | 0.00 | 1.48 | 1.28 | 7.3 | |
| | | | | 42.1 | | | | 82.3 | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Apr-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | EFF, MAX | INF, MAX | EFF, MIN | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| M | 1 | 11.284 | 10.0 | 11.0 | 7.2 | 7.3 | 7.1 | 7.1 | 7.1 | 19 | <0.1 | | | 228 | 7.6 | |
| T | 2 | 14.360 | 10.6 | 10.6 | 6.7 | 7.0 | 6.7 | 7.3 | 18.0 | <0.1 | | | 188 | 8.6 | | |
| W | 3 | 9.930 | 9.2 | 9.8 | 6.7 | 7.1 | 7.1 | 7.2 | 14.0 | <0.1 | | 196.2 | | | | |
| T | 4 | 13.911 | 9.6 | 10.2 | 7.0 | 7.2 | 7.2 | 7.4 | | <0.1 | | | | | | |
| F | 5 | 12.509 | 9.9 | 10.6 | 6.9 | 7.1 | 6.9 | 7.2 | 14.0 | <0.1 | | | | | | |
| S | 6 | 11.339 | 10.0 | 10.9 | 6.9 | 7.3 | 7.0 | 7.3 | 5.0 | <0.1 | | | | | | |
| S | 7 | 9.459 | 10.0 | 10.6 | 7.0 | 7.2 | 7.1 | 7.2 | 6.0 | <0.1 | | | | | | |
| M | 8 | 23.730 | 10.1 | 11.5 | 6.8 | 7.1 | 6.8 | 7.2 | 4.5 | <0.1 | | | | | | |
| T | 9 | 10.404 | 10.5 | 12.5 | 6.9 | 7.4 | 6.8 | 7.2 | 4.5 | <0.1 | | | | | | |
| W | 10 | 7.674 | 10.4 | 11.3 | 7.2 | 7.5 | 7.3 | 7.3 | 4.0 | <0.1 | | | | | | |
| T | 11 | 6.782 | 10.4 | 11.9 | 7.1 | 7.4 | 7.1 | 7.3 | 5.0 | <0.1 | | | | | | |
| F | 12 | 13.958 | 10.8 | 12.4 | 7.2 | 7.5 | 7.0 | 7.2 | 3.0 | <0.1 | | | | | | |
| S | 13 | 17.298 | 10.9 | 12.8 | 7.1 | 7.3 | 7.0 | 7.2 | 31.0 | <0.1 | | | | | | |
| S | 14 | 17.902 | 10.5 | 11.3 | 7.0 | 7.2 | 7.2 | 7.3 | 14.0 | <0.1 | | | | | | |
| M | 15 | 10.369 | 11.4 | 11.0 | 6.9 | 7.2 | 7.2 | 7.5 | 14.0 | <0.1 | | | | | | |
| T | 16 | 10.368 | 11.2 | 13.2 | 6.9 | 7.4 | 7.0 | 7.2 | 17.0 | <0.1 | | | | | | |
| W | 17 | 9.936 | 11.0 | 12.8 | 7.0 | 7.1 | 7.0 | 7.2 | 13.0 | <0.1 | | | | | | |
| T | 18 | 12.753 | 11.5 | 13.0 | 6.8 | 7.2 | 6.9 | 7.1 | 12.5 | <0.1 | | | | | | |
| F | 19 | 19.345 | 11.9 | 14.1 | 7.0 | 7.0 | 7.0 | 7.2 | 23.0 | <0.1 | | | | | | |
| S | 20 | 10.657 | 11.5 | 14.0 | 7.2 | 7.2 | 6.9 | 7.3 | 25.0 | <0.1 | | | | | | |
| S | 21 | 8.753 | 11.6 | 13.6 | 6.9 | 7.0 | 6.8 | 7.2 | 30.0 | <0.1 | | | | | | |
| M | 22 | 8.067 | 11.7 | 12.7 | 7.0 | 7.6 | 6.9 | 7.0 | 37.0 | <0.1 | | | | | | |
| T | 23 | 7.063 | 11.5 | 12.7 | 6.7 | 7.9 | 6.6 | 6.9 | 28.0 | <0.1 | | | | | | |
| W | 24 | 6.576 | 11.6 | 13.0 | 7.3 | 7.5 | 7.0 | 7.3 | 38.0 | <0.1 | | | | | | |
| T | 25 | 7.019 | 12.0 | 13.7 | 7.2 | 7.3 | 7.2 | 7.2 | 37.0 | <0.1 | | | | | | |
| F | 26 | 7.356 | 11.6 | 13.4 | 7.4 | 7.5 | 7.0 | 7.3 | 20.0 | <0.1 | | | | | | |
| S | 27 | 6.003 | 11.8 | 13.6 | 7.1 | 7.4 | 7.2 | 7.4 | 20.0 | <0.1 | | | | | | |
| S | 28 | 9.526 | 11.6 | 14.7 | 7.1 | 7.2 | 7.2 | 7.2 | 55.0 | <0.1 | | | | | | |
| M | 29 | 13.285 | 11.3 | 12.1 | 6.7 | 7.3 | 6.8 | 7.2 | 32.0 | <0.1 | | | | | | |
| T | 30 | 12.038 | 11.4 | 12.7 | 7.1 | 7.3 | 6.6 | 7.3 | 25.0 | <0.1 | | | | | | |
| AVERAGE | | | 11.322 | 12.3 | 6.7 | 7.9 | 6.6 | 7.5 | 55.0 | 0.0 | | | | | | |
| Monthly | | | ave. | ave. | min | max | min | max | max | max | | | | | | |
| | | | 10.9 | 12.3 | 6.7 | 7.9 | 6.6 | 7.5 | 55.0 | 0.0 | | | | | | |
| | | | | | | | | | 185.8 | 8.6 | | | | | | |
| | | | | | | | | | 95.4% | 762.2 | | | | | | |
| | | | | | | | | | 217.0 | 8.6 | | | | | | |
| | | | | | | | | | 97.4% | 527.9 | | | | | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Apr-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| M | 1 | 11.284 | 1.48 | 0.36 | 0.60 | 0.80 | 0.68 | | |
| T | 2 | 14.360 | 3.66 | 0.55 | 0.26 | 0.45 | 0.35 | | |
| W | 3 | 9.930 | 2.92 | 0.60 | 0.66 | 1.58 | 1.02 | 81 | |
| T | 4 | 13.911 | | | 0.94 | 1.43 | 1.17 | | |
| F | 5 | 12.509 | 19.23 | 0.40 | 0.00 | 1.55 | 0.89 | 3 | |
| S | 6 | 11.339 | 7.33 | 0.63 | 1.08 | 1.50 | 1.34 | 3 | |
| S | 7 | 9.459 | 4.02 | 0.48 | 0.87 | 1.27 | 1.04 | | |
| M | 8 | 23.730 | 1.99 | 0.67 | 0.98 | 1.05 | 1.01 | | |
| T | 9 | 10.404 | | | 0.94 | 1.40 | 1.22 | | |
| W | 10 | 7.674 | 0.66 | 0.50 | 1.02 | 1.41 | 1.26 | 3 | |
| T | 11 | 6.782 | 2.61 | 0.54 | 1.02 | 1.51 | 1.29 | | |
| F | 12 | 13.958 | 2.96 | 0.56 | 0.30 | 0.64 | 0.42 | | |
| S | 13 | 17.298 | 6.24 | 0.64 | 0.25 | 1.88 | 1.01 | 74 | |
| S | 14 | 17.902 | 2.46 | 0.51 | 0.10 | 1.13 | 0.48 | 3 | |
| M | 15 | 10.369 | 2.03 | 0.42 | 1.18 | 1.50 | 1.39 | | |
| T | 16 | 10.368 | | | 1.28 | 1.60 | 1.43 | | |
| W | 17 | 9.936 | 2.65 | 0.47 | 0.64 | 1.24 | 0.92 | 3 | |
| T | 18 | 12.753 | 2.30 | 0.43 | 0.77 | 1.33 | 0.98 | | |
| F | 19 | 19.345 | 4.21 | 0.42 | 0.61 | 1.02 | 0.80 | 3 | |
| S | 20 | 10.657 | 2.38 | 0.43 | 0.53 | 0.74 | 0.65 | 3 | |
| S | 21 | 8.753 | 5.69 | 0.45 | 0.34 | 0.57 | 0.42 | | |
| M | 22 | 8.067 | 4.75 | 0.62 | 0.14 | 1.07 | 0.74 | | |
| T | 23 | 7.063 | | | 0.53 | 1.18 | 0.91 | | |
| W | 24 | 6.576 | 10.10 | 0.55 | 0.63 | 1.10 | 0.88 | 3 | |
| T | 25 | 7.019 | 10.18 | 0.53 | 0.51 | 1.02 | 0.80 | | |
| F | 26 | 7.356 | 3.04 | 0.59 | 0.71 | 1.12 | 0.94 | 3 | |
| S | 27 | 6.003 | 3.98 | 0.63 | 0.52 | 1.21 | 0.78 | 3 | |
| S | 28 | 9.526 | 3.59 | 0.62 | 0.48 | 0.96 | 0.77 | | |
| M | 29 | 13.285 | 5.07 | 0.60 | 1.12 | 1.32 | 1.21 | | |
| T | 30 | 12.038 | | | 0.00 | 1.21 | 0.67 | | |
| AVERAGE | | 11.322 | 4.49 | 0.53 | 0.00 | 1.88 | 1.43 | 5.2 | 14.9 |
| | | | | 50.5 | | | | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 May-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|----------------|------|---------------|----------------|-------------|------------|------------|------------|------------|-------------|------------|------------------|------------|--------------|------------|-------------|-----------|
| | | | INF | EFF | INF, MIN | MAX | EFF, MIN | MAX | INF, ml/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| W | 1 | 8.564 | 11.6 | 13.1 | 6.9 | 7.2 | 7.0 | 7.2 | 22.00 | <0.1 | 155.4 | 12.7 | 280 | 5.6 | | |
| T | 2 | 4.657 | 14.6 | 13.4 | 6.9 | 7.4 | 7.1 | 7.4 | 23.00 | <0.1 | 300.3 | 12.8 | 196 | 3.0 | | |
| F | 3 | 8.809 | 11.6 | 12.8 | 7.2 | 7.3 | 7.2 | 7.3 | 24.00 | <0.1 | 237.2 | 3.4 | 112 | 4.2 | | |
| S | 4 | 7.893 | 11.7 | 13.2 | 7.1 | 7.3 | 7.0 | 7.2 | 14.00 | <0.1 | 264.8 | 7.4 | 408 | 8.4 | | |
| S | 5 | 9.023 | 12.0 | 13.6 | 7.1 | 7.3 | 7.1 | 7.2 | 32.00 | <0.1 | | | 320 | 5.8 | | |
| M | 6 | 7.688 | 12.2 | 14.1 | 6.7 | 7.2 | 7.0 | 7.2 | 14.00 | <0.1 | | | 284 | 3.8 | | |
| T | 7 | 7.703 | 12.3 | 14.7 | 6.6 | 7.0 | 6.7 | 7.1 | 37.00 | <0.1 | | | 328 | 3.8 | | |
| W | 8 | 8.828 | 12.2 | 14.2 | 7.0 | 7.2 | 7.2 | 7.2 | 14.00 | <0.1 | | | 608 | 5.8 | | |
| T | 9 | 11.268 | 12.2 | 14.5 | 7.0 | 7.4 | 7.0 | 7.2 | 15.00 | <0.1 | 342.3 | 10.9 | 372 | 5.0 | | |
| F | 10 | 10.098 | 12.0 | 14.3 | 7.2 | 7.3 | 6.9 | 7.2 | 34.00 | <0.1 | 209.7 | 6.7 | 190 | 3.8 | | |
| S | 11 | 7.648 | 12.2 | 14.3 | 7.0 | 7.1 | 6.9 | 7.2 | 24.00 | <0.1 | 340.5 | 4.6 | 320 | 3.6 | | |
| S | 12 | 10.177 | 12.3 | 13.9 | 6.8 | 7.2 | 6.8 | 7.3 | 18.00 | <0.1 | | | 728 | 4.2 | | |
| M | 13 | 21.770 | 12.4 | 13.9 | 6.7 | 7.0 | 6.6 | 7.0 | 25.00 | <0.1 | | | 376 | 9.0 | | |
| T | 14 | 31.769 | 12.1 | 12.2 | 6.6 | 7.5 | 6.5 | 7.2 | 15.00 | <0.1 | | | 264 | 14.4 | | |
| W | 15 | 18.776 | 11.7 | 12.4 | 7.2 | 7.5 | 7.3 | 7.4 | 12.00 | <0.1 | 82.9 | 8.9 | 116 | 14.5 | | |
| T | 16 | 13.641 | 12.1 | 13.3 | 7.2 | 7.4 | 7.2 | 7.3 | 18.00 | <0.1 | 128.6 | 6.2 | 96 | 4.3 | | |
| F | 17 | 13.949 | 12.1 | 13.3 | 7.4 | 7.4 | 7.3 | 7.3 | 24.00 | <0.1 | 91.7 | 4.0 | 180 | 4.2 | | |
| S | 18 | 12.636 | 12.1 | 13.2 | 7.2 | 7.4 | 7.2 | 7.3 | 23.00 | <0.1 | 217.3 | 6.0 | 60 | 1.0 | | |
| S | 19 | 11.346 | 12.1 | 13.1 | 7.2 | 7.4 | 6.9 | 7.2 | 32.00 | <0.1 | | | 260 | 2.5 | | |
| M | 20 | 9.266 | 12.3 | 13.2 | 7.0 | 7.3 | 7.0 | 7.2 | 70.00 | <0.1 | | | 224 | 3.9 | | |
| T | 21 | 10.323 | 12.3 | 13.5 | 7.1 | 7.4 | 7.2 | 7.4 | 70.00 | <0.1 | | | 460 | 2.6 | | |
| W | 22 | 8.266 | 12.5 | 13.7 | 7.4 | 7.4 | 7.2 | 7.3 | 65.00 | <0.1 | 348.2 | 7.3 | 480 | 5.0 | | |
| T | 23 | 7.725 | 12.6 | 14.2 | 7.3 | 7.3 | 7.2 | 7.2 | 60.00 | <0.1 | 368.9 | 6.4 | 440 | 3.8 | | |
| F | 24 | 6.913 | 12.6 | 14.5 | 7.2 | 7.5 | 7.2 | 7.3 | 52.00 | <0.1 | 214.9 | 5.6 | 412 | 2.8 | | |
| S | 25 | 6.204 | 12.5 | 14.7 | 7.3 | 7.4 | 7.2 | 7.3 | 17.00 | <0.1 | 155.2 | 5.7 | 264 | 3.2 | | |
| S | 26 | 6.803 | 12.5 | 14.2 | 7.2 | 7.4 | 7.2 | 7.2 | 9.00 | <0.1 | | | 88 | 2.2 | | |
| M | 27 | 5.949 | 12.4 | 13.8 | 7.3 | 7.4 | 7.1 | 7.2 | 27.00 | <0.1 | | | 260 | 2.6 | | |
| T | 28 | 6.220 | 12.5 | 14.3 | 7.3 | 7.4 | 7.0 | 7.1 | 32.00 | <0.1 | | | 240 | 2.2 | | |
| W | 29 | 6.021 | 12.9 | 14.3 | 6.9 | 7.4 | 7.1 | 7.1 | 34.00 | <0.1 | 247.6 | 3.9 | 276 | 3.2 | | |
| T | 30 | 5.572 | 13.0 | 15.2 | 7.3 | 7.4 | 7.1 | 7.2 | 34.00 | <0.1 | 272.9 | 8.6 | 204 | 5.0 | | |
| F | 31 | 9.346 | 13.1 | 15.6 | 7.2 | 7.3 | 6.9 | 7.1 | 24.00 | <0.1 | 223.9 | 3.2 | 376 | 1.4 | | |
| AVERAGE | | 10.156 | 12.3 | 13.8 | 6.6 | 7.5 | 6.5 | 7.4 | 70.0 | 0.0 | 214.9 | 6.7 | 290.2 | 5.9 | | |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | 96.9% | 522.6 | 98.0% | 498.5 | | |

NIAGARA COUNTY SEWER DISTRICT #1
May-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS | |
|---------|------|--------|-------------|----------|-------------------|----------|------------------|----------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | | AVE,mg/l |
| W | 1 | 8.564 | 3.43 | 0.46 | 0.40 | 1.20 | 0.67 | 38 | |
| T | 2 | 4.657 | 3.63 | 0.43 | 0.45 | 1.75 | 1.28 | | |
| F | 3 | 8.809 | 6.40 | 0.49 | 1.03 | 1.40 | 1.22 | 3 | |
| S | 4 | 7.893 | 3.82 | 0.57 | 0.95 | 1.15 | 1.08 | 3 | |
| S | 5 | 9.023 | 7.02 | 0.75 | 1.20 | 1.41 | 1.31 | | |
| M | 6 | 7.688 | 6.63 | 0.60 | 1.12 | 1.44 | 1.26 | | |
| T | 7 | 7.703 | | | 1.00 | 1.38 | 1.16 | | |
| W | 8 | 8.828 | 4.76 | 0.62 | 1.08 | 1.51 | 1.30 | 3 | |
| T | 9 | 11.268 | 7.33 | 0.65 | 0.48 | 0.64 | 0.58 | | |
| F | 10 | 10.098 | 6.86 | 0.57 | 0.50 | 0.67 | 0.56 | | |
| S | 11 | 7.648 | 7.02 | 0.52 | 0.45 | 1.32 | 0.97 | | |
| S | 12 | 10.177 | 5.89 | 0.63 | 0.73 | 1.35 | 0.98 | | |
| M | 13 | 21.770 | 6.98 | 0.62 | 0.81 | 1.42 | 1.10 | 5 | |
| T | 14 | 31.769 | | | 0.24 | 0.62 | 0.47 | | |
| W | 15 | 18.776 | 4.17 | 0.51 | 0.73 | 1.33 | 1.06 | 20 | |
| T | 16 | 13.641 | 6.75 | 0.31 | 0.55 | 1.21 | 0.92 | | |
| F | 17 | 13.949 | 2.42 | 0.45 | 1.35 | 1.63 | 1.47 | 3 | |
| S | 18 | 12.636 | 2.18 | 0.39 | 1.09 | 1.64 | 1.34 | 3 | |
| S | 19 | 11.346 | 5.92 | 0.57 | 0.80 | 1.52 | 1.07 | | |
| M | 20 | 9.266 | 6.27 | 0.54 | 0.79 | 1.33 | 1.08 | | |
| T | 21 | 10.323 | | | 0.80 | 0.97 | 0.87 | | |
| W | 22 | 8.266 | 12.87 | 0.79 | 0.95 | 1.47 | 1.25 | 3 | |
| T | 23 | 7.725 | 7.88 | 0.94 | 1.08 | 1.21 | 1.14 | | |
| F | 24 | 6.913 | 2.88 | 1.05 | 0.86 | 1.16 | 1.06 | 3 | |
| S | 25 | 6.204 | 5.18 | 0.97 | 0.84 | 1.16 | 0.98 | 3 | |
| S | 26 | 6.803 | 3.39 | 1.05 | 0.32 | 1.04 | 0.60 | | |
| M | 27 | 5.949 | 4.76 | 1.13 | 0.00 | 1.30 | 0.47 | | |
| T | 28 | 6.220 | | | 0.35 | 0.73 | 0.55 | | |
| W | 29 | 6.021 | 6.55 | 1.28 | 0.19 | 0.50 | 0.30 | 14 | |
| T | 30 | 5.572 | 4.84 | 1.24 | 1.21 | 1.52 | 1.41 | | |
| F | 31 | 9.346 | 6.83 | 0.99 | 1.45 | 1.80 | 1.57 | 3 | |
| AVERAGE | | 10.156 | 6.04 | 0.69 | 0.00 | 1.80 | 1.57 | 5.0 | |
| | | | | 55.3 | | | | 10.3 | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Jun-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | pH | pH | pH | pH | pH | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|----------------|------|--------------|----------------|-------------|------------|------------|------------|------------|------------|------------|------------------|------------|--------------|------------|--------------|------------|
| | | | INF | EFF | | | | | | | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, ml/l | EFF, ml/l |
| S | 1 | 7.610 | 12.5 | 16.2 | 7.4 | 7.4 | 7.4 | 7.4 | 7.1 | 7.2 | 23 | <0.1 | 285.3 | 5.4 | 464 | 2.2 |
| S | 2 | 6.173 | 12.4 | 15.0 | 7.3 | 7.4 | 7.4 | 7.0 | 7.0 | 7.1 | 24.0 | <0.1 | | | 340 | 1.4 |
| M | 3 | 5.430 | 12.5 | 14.6 | 7.2 | 7.4 | 7.4 | 7.0 | 7.0 | 7.1 | 24.0 | <0.1 | | | 340 | 0.8 |
| T | 4 | 6.432 | 12.8 | 15.3 | 7.0 | 7.6 | 7.6 | 7.0 | 7.0 | 7.4 | 33.0 | <0.1 | | | 300 | 2.0 |
| W | 5 | 10.582 | 12.7 | 16.0 | 7.3 | 7.4 | 7.4 | 7.1 | 7.1 | 7.2 | 34.0 | <0.1 | 295.7 | 4.2 | 388 | 3.4 |
| T | 6 | 8.837 | 12.8 | 16.1 | 7.2 | 7.4 | 7.4 | 7.0 | 7.0 | 7.1 | 28.0 | <0.1 | 267.0 | 3.3 | 244 | 3.0 |
| F | 7 | 6.782 | 12.8 | 16.1 | 7.2 | 7.4 | 7.4 | 7.2 | 7.2 | 7.2 | 28.0 | <0.1 | 146.2 | 3.0 | 200 | 1.8 |
| S | 8 | 5.873 | 12.8 | 16.6 | 7.2 | 7.3 | 7.3 | 7.1 | 7.1 | 7.2 | 30.0 | <0.1 | 197.4 | 9.0 | 256 | 3.2 |
| S | 9 | 5.981 | 12.9 | 16.4 | 7.0 | 7.3 | 7.3 | 7.0 | 7.0 | 7.1 | 34.0 | <0.1 | | | 284 | 3.4 |
| M | 10 | 4.974 | 13.0 | 16.8 | 7.1 | 7.4 | 7.4 | 6.9 | 6.9 | 7.1 | 14.0 | <0.1 | | | 200 | 2.2 |
| T | 11 | 6.307 | 13.3 | 17.6 | 7.2 | 7.4 | 7.4 | 7.2 | 7.2 | 7.3 | 28.0 | <0.1 | | | 216 | 2.0 |
| W | 12 | 4.730 | 13.1 | 18.2 | 7.4 | 7.4 | 7.4 | 7.1 | 7.1 | 7.3 | 10.0 | <0.1 | 173.0 | 2.7 | 152 | 3.6 |
| T | 13 | 4.979 | 13.0 | 17.7 | 7.3 | 7.3 | 7.3 | 7.1 | 7.1 | 7.2 | 27.0 | <0.1 | 161.8 | 3.8 | 224 | 1.8 |
| F | 14 | 5.184 | 12.9 | 17.2 | 7.1 | 7.3 | 7.3 | 7.1 | 7.1 | 7.1 | 33.0 | <0.1 | 218.8 | 1.4 | 232 | 1.0 |
| S | 15 | 5.699 | 12.9 | 17.1 | 7.1 | 7.3 | 7.3 | 7.0 | 7.0 | 7.2 | 30.0 | <0.1 | 259.0 | 7.1 | 228 | 1.2 |
| S | 16 | 5.702 | 12.8 | 17.0 | 7.1 | 7.1 | 7.2 | 7.1 | 7.1 | 7.4 | 22.0 | <0.1 | | | 216 | 1.2 |
| M | 17 | 11.085 | 12.9 | 16.4 | 6.8 | 7.1 | 7.1 | 6.9 | 6.9 | 7.2 | 34.5 | <0.1 | | | 388 | 10.4 |
| T | 18 | 12.743 | 12.6 | 14.6 | 6.9 | 7.4 | 7.4 | 7.0 | 7.0 | 7.0 | 17.0 | <0.1 | | | 216 | 10.5 |
| W | 19 | 8.632 | 13.3 | 16.6 | 7.1 | 7.3 | 7.3 | 7.0 | 7.0 | 7.1 | 21.0 | <0.1 | 147.1 | 5.1 | 196 | 8.3 |
| T | 20 | 8.567 | 13.8 | 17.2 | 7.2 | 7.3 | 7.3 | 7.1 | 7.1 | 7.2 | 23.0 | <0.1 | 145.8 | 1.7 | 228 | 0.6 |
| F | 21 | 6.316 | 13.9 | 17.5 | 6.9 | 7.3 | 7.3 | 6.6 | 6.6 | 7.1 | 26.0 | <0.1 | 197.9 | 2.0 | 360 | 1.4 |
| S | 22 | 7.310 | 13.4 | 18.3 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 35.0 | <0.1 | 250.5 | 22.8 | 268 | 2.2 |
| S | 23 | 5.997 | 13.6 | 18.3 | 6.9 | 7.0 | 7.0 | 6.8 | 6.8 | 7.0 | 34.0 | <0.1 | | | 228 | 0.6 |
| M | 24 | 5.155 | 14.1 | 18.3 | 6.9 | 7.4 | 7.4 | 7.0 | 7.0 | 7.1 | 21.0 | <0.1 | | | 120 | 2.6 |
| T | 25 | 5.658 | 14.1 | 18.1 | 7.0 | 7.2 | 7.2 | 7.0 | 7.0 | 7.3 | 35.0 | <0.1 | | | 348 | 5.0 |
| W | 26 | 4.801 | 14.5 | 19.5 | 7.2 | 7.3 | 7.3 | 7.1 | 7.1 | 7.2 | 35.0 | <0.1 | 249.9 | 15.6 | 340 | 2.4 |
| T | 27 | 5.729 | 15.1 | 19.7 | 7.1 | 7.3 | 7.3 | 7.1 | 7.1 | 7.3 | 21.0 | <0.1 | 221.5 | 19.4 | 252 | 3.0 |
| F | 28 | 7.090 | 15.3 | 19.3 | 6.9 | 7.1 | 7.1 | 7.0 | 7.0 | 7.1 | 24.0 | <0.1 | 164.6 | 4.1 | 168 | 6.0 |
| S | 29 | 5.066 | 15.1 | 19.1 | 7.1 | 7.3 | 7.3 | 6.9 | 6.9 | 7.2 | 20.0 | <0.1 | | | 212 | 3.2 |
| S | 30 | 4.282 | 14.6 | 19.5 | 7.0 | 7.4 | 7.4 | 7.0 | 7.0 | 7.2 | 23.0 | <0.1 | | | 216 | 2.0 |
| AVERAGE | | 6.657 | 13.4 | 17.2 | 6.8 | 7.6 | 7.6 | 6.6 | 6.6 | 7.4 | 35.0 | 0.0 | 219.0 | 7.0 | 266.9 | 3.6 |
| | | Monthly | ave. | ave. | min | max | max | min | min | max | max | max | 96.8% | 396.3 | 98.7% | 199.3 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
Jun-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS | |
|---------|------|--------|-------------|----------|-------------------|----------|------------------|----------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | | AVE,mg/l |
| S | 1 | 7.610 | 10.18 | 0.80 | 1.45 | 1.91 | 1.63 | 3 | |
| S | 2 | 6.173 | 3.20 | 0.68 | 1.30 | 1.50 | 1.40 | | |
| M | 3 | 5.430 | 8.77 | 1.05 | 1.36 | 1.81 | 1.56 | | |
| T | 4 | 6.432 | | | 1.47 | 1.73 | 1.62 | | |
| W | 5 | 10.582 | 8.81 | 0.87 | 1.11 | 1.35 | 1.22 | 3 | |
| T | 6 | 8.837 | 3.78 | 0.50 | 0.67 | 1.30 | 1.01 | | |
| F | 7 | 6.782 | 4.41 | 0.38 | 0.94 | 1.40 | 1.18 | 3 | |
| S | 8 | 5.873 | 2.93 | 0.50 | 0.58 | 1.50 | 1.04 | 3 | |
| S | 9 | 5.981 | 3.86 | 0.56 | 0.94 | 1.58 | 1.26 | | |
| M | 10 | 4.974 | 6.66 | 0.67 | 1.01 | 1.39 | 1.17 | | |
| T | 11 | 6.307 | | | 0.92 | 0.98 | 0.94 | | |
| W | 12 | 4.730 | 5.53 | 1.17 | 0.06 | 0.91 | 0.48 | 44 | |
| T | 13 | 4.979 | 3.59 | 1.21 | 0.73 | 1.10 | 0.93 | | |
| F | 14 | 5.184 | 4.13 | 0.91 | 0.86 | 1.54 | 1.13 | 3 | |
| S | 15 | 5.699 | 10.14 | 0.66 | 0.66 | 1.25 | 0.98 | 3 | |
| S | 16 | 5.702 | 3.54 | 0.52 | 0.83 | 0.90 | 0.86 | | |
| M | 17 | 11.085 | 7.44 | 0.61 | 0.62 | 1.13 | 0.91 | | |
| T | 18 | 12.743 | | | 0.87 | 1.21 | 0.99 | | |
| W | 19 | 8.632 | 2.37 | 0.45 | 0.90 | 1.31 | 1.07 | | |
| T | 20 | 8.567 | 2.53 | 0.48 | 0.94 | 1.23 | 1.06 | 3 | |
| F | 21 | 6.316 | 7.56 | 0.63 | 0.31 | 1.31 | 0.75 | 124 | |
| S | 22 | 7.310 | 2.57 | 1.01 | 0.21 | 0.24 | 0.22 | 11 | |
| S | 23 | 5.997 | 15.99 | 0.70 | 0.20 | 1.10 | 0.66 | | |
| M | 24 | 5.155 | 3.97 | 0.58 | 0.79 | 1.10 | 0.93 | | |
| T | 25 | 5.658 | | | 0.78 | 1.31 | 1.13 | | |
| W | 26 | 4.801 | 4.09 | 0.81 | 0.06 | 0.65 | 0.32 | 41 | |
| T | 27 | 5.729 | 4.60 | 0.65 | 0.00 | 0.27 | 0.18 | | |
| F | 28 | 7.090 | 3.82 | 0.42 | 0.19 | 2.28 | 1.41 | 3 | |
| S | 29 | 5.066 | 4.52 | 0.45 | 0.67 | 1.65 | 1.14 | 3 | |
| S | 30 | 4.282 | 3.74 | 0.48 | 0.40 | 0.57 | 0.46 | | |
| AVERAGE | | 6.657 | 5.19 | 0.67 | 0.00 | 2.28 | 1.63 | 6.6 | 38.4 |
| | | | | 36.3 | | | | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Jul-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | pH | pH | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|---------|----------------|------|----------|----------|-----|-----|-------|------------------|----------|----------|----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | INF, MAX | | | | EFF, MIN | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l |
| M | 1 | 4.670 | 14.7 | 19.4 | 7.1 | 7.3 | 6.7 | 7.3 | 25.00 | <0.1 | | | 220 | 2.0 | |
| T | 2 | 4.363 | 14.7 | 20.1 | 7.2 | 7.3 | 7.1 | 7.3 | 24.00 | <0.1 | | | 176 | 3.0 | |
| W | 3 | 4.428 | 15.0 | 20.0 | 7.1 | 7.3 | 7.2 | 7.4 | 24.00 | <0.1 | 207.2 | 7.0 | 272 | 17.2 | |
| T | 4 | 4.211 | 15.1 | 20.6 | 7.2 | 7.2 | 7.4 | 7.4 | 22.00 | <0.1 | 266.8 | 8.9 | 224 | 4.6 | |
| F | 5 | 4.293 | 16.4 | 20.0 | 7.2 | 7.4 | 7.3 | 7.5 | 21.00 | <0.1 | 223.0 | 2.9 | 352 | 2.0 | |
| S | 6 | 3.812 | 16.1 | 20.2 | 7.1 | 7.3 | 7.4 | 7.5 | 16.00 | <0.1 | 215.3 | 5.0 | 184 | 2.0 | |
| S | 7 | 4.278 | 16.1 | 19.8 | 7.0 | 7.2 | 7.0 | 7.4 | 17.00 | <0.1 | | | 144 | 1.6 | |
| M | 8 | 4.905 | 16.1 | 21.8 | 7.0 | 7.1 | 6.8 | 7.3 | 14.00 | <0.1 | | | 276 | 2.8 | |
| T | 9 | 3.903 | 16.4 | 19.9 | 6.9 | 7.4 | 7.1 | 7.5 | 13.00 | <0.1 | | | 124 | 2.4 | |
| W | 10 | 4.197 | 16.3 | 19.8 | 7.3 | 7.4 | 7.2 | 7.5 | 21.00 | <0.1 | 237.5 | 2.7 | 256 | 2.2 | |
| T | 11 | 4.490 | 16.4 | 20.4 | 7.0 | 7.3 | 7.2 | 7.4 | 21.00 | <0.1 | 253.4 | 6.1 | 256 | 3.8 | |
| F | 12 | 4.905 | 16.1 | 19.8 | 7.2 | 7.3 | 7.1 | 7.3 | 21.00 | <0.1 | 226.4 | 4.3 | 208 | 1.6 | |
| S | 13 | 4.613 | 15.4 | 19.8 | 7.0 | 7.1 | 7.1 | 7.2 | 25.00 | <0.1 | | | 240 | 2.2 | |
| S | 14 | 4.584 | 15.7 | 20.1 | 6.9 | 7.2 | 7.0 | 7.2 | 26.00 | <0.1 | | | 252 | 2.4 | |
| M | 15 | 4.901 | 15.9 | 20.1 | 6.8 | 7.1 | 7.0 | 7.1 | 23.00 | <0.1 | | | 180 | 2.4 | |
| T | 16 | 4.715 | 16.4 | 20.1 | 7.0 | 7.1 | 6.5 | 7.1 | 24.00 | <0.1 | | | 244 | 5.6 | |
| W | 17 | 4.929 | 16.4 | 20.9 | 6.9 | 7.1 | 6.6 | 7.1 | 18.00 | <0.1 | 183.9 | 5.9 | 208 | 4.2 | |
| T | 18 | 4.342 | 16.7 | 23.2 | 6.4 | 7.4 | 6.8 | 7.1 | 15.00 | <0.1 | | | 316 | 3.2 | |
| F | 19 | 4.191 | 18.1 | 21.7 | 7.0 | 7.2 | 6.6 | 7.1 | 17.00 | <0.1 | 184.2 | 3.4 | 216 | 6.0 | |
| S | 20 | 4.102 | 18.1 | 21.3 | 6.8 | 7.1 | 6.9 | 7.1 | 14.00 | <0.1 | 191.0 | 5.1 | 196 | 3.8 | |
| S | 21 | 4.122 | 17.1 | 21.0 | 6.5 | 7.0 | 6.6 | 7.0 | 13.00 | <0.1 | | | 232 | 4.4 | |
| M | 22 | 4.550 | 17.4 | 21.0 | 7.0 | 7.4 | 6.9 | 7.2 | 28.00 | <0.1 | | | 248 | 4.2 | |
| T | 23 | 5.664 | 17.4 | 21.4 | 6.5 | 6.7 | 6.5 | 6.6 | 21.00 | <0.1 | | | 264 | 1.8 | |
| W | 24 | 4.927 | 17.4 | 20.7 | 6.7 | 7.3 | 6.8 | 7.1 | 28.00 | <0.1 | 274.6 | 11.6 | 296 | 2.0 | |
| T | 25 | 8.959 | 17.4 | 20.6 | 7.2 | 7.3 | 7.0 | 7.2 | 14.00 | <0.1 | 174.8 | 2.3 | 152 | 1.8 | |
| F | 26 | 4.652 | 17.1 | 20.9 | 7.1 | 7.3 | 7.0 | 7.2 | 21.00 | <0.1 | 255.4 | 2.3 | 180 | 2.0 | |
| S | 27 | 5.021 | 17.1 | 21.4 | 7.3 | 7.3 | 6.8 | 7.3 | 17.50 | <0.1 | 100.5 | 4.5 | 216 | 3.2 | |
| S | 28 | 5.591 | 17.4 | 21.5 | 7.2 | 7.4 | 7.1 | 7.3 | 24.00 | <0.1 | | | 180 | 4.4 | |
| M | 29 | 7.132 | 17.1 | 21.6 | 7.1 | 7.3 | 6.7 | 7.1 | 24.00 | <0.1 | | | 212 | 2.8 | |
| T | 30 | 6.723 | 17.2 | 21.1 | 7.1 | 7.2 | 7.0 | 7.1 | 24.50 | <0.1 | | | 288 | 2.4 | |
| W | 31 | 5.497 | 17.1 | 20.7 | 6.8 | 7.1 | 6.9 | 7.1 | 19.00 | <0.1 | 158.1 | 1.7 | 248 | 1.4 | |
| AVERAGE | | 4.893 | 16.5 | 20.7 | 6.4 | 7.4 | 6.5 | 7.5 | 28.0 | 0.0 | 206.7 | 4.7 | 227.7 | 3.4 | |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | 97.7% | 191.4 | 98.5% | 134.5 | |

NIAGARA COUNTY SEWER DISTRICT #1

Jul-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| M | 1 | 4.670 | 2.53 | 0.39 | 0.07 | 0.51 | 0.33 | | |
| T | 2 | 4.363 | | | 0.00 | 0.45 | 0.22 | | |
| W | 3 | 4.428 | 3.59 | 0.75 | 0.29 | 0.68 | 0.46 | 7 | |
| T | 4 | 4.211 | 6.40 | 0.51 | 0.00 | 0.57 | 0.24 | | |
| F | 5 | 4.293 | 8.66 | 0.63 | 0.15 | 0.73 | 0.49 | 3 | |
| S | 6 | 3.812 | 3.78 | 0.80 | 0.07 | 0.47 | 0.30 | | |
| S | 7 | 4.278 | 27.26 | 0.82 | 0.17 | 0.45 | 0.34 | | |
| M | 8 | 4.905 | 5.03 | 0.76 | 0.20 | 0.95 | 0.45 | | |
| T | 9 | 3.903 | | | 0.72 | 1.02 | 0.82 | | |
| W | 10 | 4.197 | 12.51 | 0.67 | 0.74 | 1.82 | 1.19 | 3 | |
| T | 11 | 4.490 | 4.60 | 0.66 | 1.05 | 1.38 | 1.17 | | |
| F | 12 | 4.905 | 4.80 | 0.61 | 1.10 | 1.21 | 1.16 | 3 | |
| S | 13 | 4.613 | 6.08 | 1.34 | 1.05 | 1.31 | 1.16 | 3 | |
| S | 14 | 4.584 | 4.21 | 0.92 | 0.82 | 1.36 | 1.16 | | |
| M | 15 | 4.901 | 4.17 | 0.79 | 1.26 | 1.65 | 1.44 | | |
| T | 16 | 4.715 | | | 0.91 | 1.20 | 1.07 | | |
| W | 17 | 4.929 | 4.79 | 0.87 | 0.76 | 0.97 | 0.89 | | |
| T | 18 | 4.342 | 4.79 | 0.86 | 0.32 | 0.54 | 0.46 | | |
| F | 19 | 4.191 | 9.43 | 0.81 | 0.12 | 0.34 | 0.22 | 3 | |
| S | 20 | 4.102 | 4.68 | 0.80 | 0.10 | 0.76 | 0.50 | 3 | |
| S | 21 | 4.122 | 3.20 | 0.79 | 0.40 | 0.50 | 0.44 | | |
| M | 22 | 4.550 | 5.03 | 0.81 | 0.20 | 0.32 | 0.27 | | |
| T | 23 | 5.664 | | | 0.20 | 0.67 | 0.36 | | |
| W | 24 | 4.927 | 4.76 | 0.67 | 0.03 | 1.14 | 0.73 | 3 | |
| T | 25 | 8.959 | 4.17 | 0.51 | 0.92 | 1.09 | 1.02 | | |
| F | 26 | 4.652 | 4.10 | 0.60 | 1.01 | 1.22 | 1.10 | 3 | |
| S | 27 | 5.021 | 4.76 | 0.65 | 1.05 | 1.33 | 1.20 | 3 | |
| S | 28 | 5.591 | 3.35 | 0.83 | 1.09 | 1.35 | 1.24 | | |
| M | 29 | 7.132 | 4.72 | 0.93 | 1.12 | 1.36 | 1.25 | | |
| T | 30 | 6.723 | | | 1.02 | 1.18 | 1.09 | | |
| W | 31 | 5.497 | 4.79 | 0.73 | 1.06 | 1.30 | 1.18 | 3 | |
| AVERAGE | | 4.893 | 6.01 | 0.75 | 0.00 | 1.82 | 1.44 | 3.2 | |
| | | | 31.0 | | | | 4.5 | | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Aug-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | EFF, MIN | INF, MAX | pH | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|-------|----------------|------|----------|----------|-----|----------|----------|-------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | EFF, MAX | | | | | INF, mg/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| T | 1 | 4.273 | 18.1 | 21.1 | 6.8 | 7.3 | 6.8 | 7.2 | 7.2 | 17.00 | <0.1 | 213.5 | 15.2 | 172 | 2.4 | |
| F | 2 | 5.186 | 17.7 | 21.4 | 6.6 | 7.2 | 6.7 | 7.1 | 7.1 | 19.00 | <0.1 | 258.9 | 0.0 | 396 | 3.8 | |
| S | 3 | 4.030 | 17.7 | 21.3 | 6.7 | 6.9 | 6.5 | 6.8 | 6.8 | 19.00 | <0.1 | 177.4 | 1.0 | 248 | 2.0 | |
| S | 4 | 3.646 | 18.1 | 21.3 | 6.8 | 7.1 | 6.6 | 6.8 | 6.8 | 23.00 | <0.1 | | | 260 | 5.4 | |
| M | 5 | 4.227 | 18.4 | 21.8 | 6.6 | 7.0 | 6.7 | 7.0 | 7.0 | 25.00 | <0.1 | | | 228 | 1.0 | |
| T | 6 | 3.594 | 17.9 | 21.1 | 7.0 | 7.8 | 7.1 | 7.6 | 7.6 | 25.00 | <0.1 | | | 192 | 1.8 | |
| W | 7 | 3.543 | 18.1 | 21.5 | 7.3 | 7.7 | 7.0 | 7.6 | 7.6 | 26.00 | <0.1 | | | 268 | 2.4 | |
| T | 8 | 3.477 | 17.8 | 21.3 | 7.2 | 7.3 | 7.0 | 7.1 | 7.1 | 28.00 | <0.1 | 296.6 | 2.3 | 296 | 2.4 | |
| F | 9 | 3.619 | 18.1 | 21.5 | 7.0 | 7.4 | 7.0 | 7.2 | 7.2 | 19.00 | <0.1 | 250.7 | 1.6 | 236 | 4.6 | |
| S | 10 | 3.052 | 18.4 | 21.5 | 6.9 | 7.2 | 7.0 | 7.1 | 7.1 | 19.00 | <0.1 | 327.7 | 3.5 | 224 | 2.8 | |
| S | 11 | 4.258 | 18.4 | 21.9 | 7.0 | 7.3 | 6.8 | 6.9 | 6.9 | 30.00 | <0.1 | | 1.7 | 204 | 1.8 | |
| M | 12 | 3.675 | 18.8 | 22.5 | 7.1 | 7.3 | 6.9 | 7.1 | 7.1 | 25.00 | <0.1 | | | 208 | 2.8 | |
| T | 13 | 4.238 | 18.7 | 21.7 | 6.9 | 7.3 | 7.1 | 7.2 | 7.2 | 18.00 | <0.1 | | | 244 | 1.4 | |
| W | 14 | 3.976 | 18.7 | 21.4 | 7.1 | 7.2 | 6.9 | 7.1 | 7.1 | 24.00 | <0.1 | | | 220 | 0.6 | |
| T | 15 | 3.892 | 18.7 | 21.5 | 7.3 | 7.4 | 6.9 | 7.1 | 7.1 | 19.00 | <0.1 | 331.8 | 3.4 | 228 | 1.6 | |
| F | 16 | 3.597 | 18.1 | 22.2 | 7.3 | 7.4 | 7.0 | 7.1 | 7.1 | 21.00 | <0.1 | 226.4 | 2.6 | 216 | 5.2 | |
| S | 17 | 3.711 | 18.4 | 22.1 | 7.4 | 7.5 | 7.1 | 7.2 | 7.2 | 21.00 | <0.1 | 224.7 | 3.3 | 204 | 1.2 | |
| S | 18 | 3.546 | 18.4 | 21.9 | 7.0 | 7.2 | 6.9 | 7.0 | 7.0 | 29.00 | <0.1 | | | 240 | 0.4 | |
| M | 19 | 3.916 | 18.4 | 21.3 | 7.1 | 7.2 | 6.8 | 7.0 | 7.0 | 31.00 | <0.1 | | | 220 | 0.8 | |
| T | 20 | 3.262 | 17.7 | 20.9 | 6.8 | 7.2 | 7.0 | 7.3 | 7.3 | 22.00 | <0.1 | | | 196 | 2.4 | |
| W | 21 | 3.327 | 18.1 | 20.9 | 7.1 | 7.2 | 7.0 | 7.4 | 7.4 | 21.00 | <0.1 | 209.8 | 2.5 | 152 | 1.6 | |
| T | 22 | 3.603 | 19.2 | 21.6 | 7.1 | 7.3 | 7.0 | 7.2 | 7.2 | 26.00 | <0.1 | 217.9 | 3.1 | 236 | 3.2 | |
| F | 23 | 3.060 | 18.5 | 21.8 | 7.1 | 7.3 | 7.1 | 7.1 | 7.1 | 26.00 | <0.1 | 209.8 | 4.9 | 216 | 1.4 | |
| S | 24 | 3.919 | 18.4 | 22.4 | 7.3 | 7.5 | 6.9 | 7.2 | 7.2 | 29.50 | <0.1 | 136.9 | 11.8 | 228 | 2.2 | |
| S | 25 | 3.603 | 17.9 | 21.6 | 7.3 | 7.4 | 7.0 | 7.1 | 7.1 | 32.00 | <0.1 | | | 256 | 1.8 | |
| M | 26 | 3.470 | 18.2 | 21.8 | 7.1 | 7.3 | 7.0 | 7.3 | 7.3 | 24.00 | <0.1 | | | 256 | 2.6 | |
| T | 27 | 3.067 | 18.5 | 21.4 | 6.8 | 7.3 | 7.0 | 7.2 | 7.2 | 31.00 | <0.1 | | | 284 | 2.0 | |
| W | 28 | 4.250 | 18.7 | 21.4 | 7.2 | 7.3 | 7.0 | 7.2 | 7.2 | 24.00 | <0.1 | 185.2 | 0.8 | 228 | 2.0 | |
| T | 29 | 3.542 | 18.7 | 21.4 | 7.2 | 7.5 | 7.0 | 7.1 | 7.1 | 29.00 | <0.1 | 251.1 | 2.0 | 244 | 2.4 | |
| F | 30 | 3.176 | 18.4 | 21.7 | 7.1 | 7.3 | 6.9 | 7.1 | 7.1 | 21.00 | <0.1 | 432.5 | 3.7 | 276 | 2.8 | |
| S | 31 | 3.208 | 18.4 | 22.4 | 7.2 | 7.3 | 7.1 | 7.1 | 7.1 | 28.00 | <0.1 | 241.8 | | 260 | 9.8 | |
| AVERAGE | | 3.690 | 18.3 | 21.6 | 6.6 | 7.8 | 6.5 | 7.6 | 7.6 | 32.0 | 0.0 | 243.7 | 3.9 | 236.6 | 2.5 | |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | max | 98.4% | 120.7 | 98.9% | 77.7 | |

NIAGARA COUNTY SEWER DISTRICT #1

Aug-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|-----------|-------------------|-----------|------------------|----------|
| | | | INF. mg/l | EFF. mg/l | MIN. mg/l | MAX. mg/l | | |
| T | 1 | 4.273 | 2.88 | 0.61 | 1.03 | 1.26 | 1.15 | |
| F | 2 | 5.186 | 3.04 | 0.65 | 0.25 | 0.80 | 0.54 | 141 |
| S | 3 | 4.030 | 3.31 | 0.62 | 0.09 | 0.84 | 0.51 | 3200 |
| S | 4 | 3.646 | 4.71 | 0.82 | 1.00 | 1.34 | 1.21 | |
| M | 5 | 4.227 | 4.72 | 0.89 | 0.82 | 0.98 | 0.91 | |
| T | 6 | 3.594 | | | 1.05 | 2.35 | 1.79 | |
| W | 7 | 3.543 | 4.56 | 0.99 | 1.29 | 2.04 | 1.55 | |
| T | 8 | 3.477 | 6.05 | 0.89 | 1.32 | 1.86 | 1.61 | |
| F | 9 | 3.619 | 3.86 | 0.86 | 0.93 | 1.45 | 1.21 | 3 |
| S | 10 | 3.052 | 3.87 | 0.78 | 1.49 | 1.76 | 1.59 | 3 |
| S | 11 | 4.258 | 4.83 | 0.80 | 0.85 | 1.54 | 1.28 | |
| M | 12 | 3.675 | 4.79 | 0.73 | 1.17 | 1.51 | 1.32 | |
| T | 13 | 4.238 | | | 0.85 | 1.60 | 1.28 | |
| W | 14 | 3.976 | 1.63 | 0.68 | 1.02 | 1.37 | 1.20 | 3 |
| T | 15 | 3.892 | 1.91 | 0.63 | 1.39 | 1.62 | 1.54 | |
| F | 16 | 3.597 | 2.81 | 0.72 | 0.89 | 1.40 | 1.20 | 3 |
| S | 17 | 3.711 | 2.92 | 0.80 | 0.32 | 0.98 | 0.58 | 3 |
| S | 18 | 3.546 | 7.37 | 0.71 | 0.22 | 0.34 | 0.27 | |
| M | 19 | 3.916 | 3.94 | 0.61 | 0.20 | 0.39 | 0.29 | |
| T | 20 | 3.262 | | | 0.00 | 1.10 | 0.43 | |
| W | 21 | 3.327 | 2.96 | 0.55 | 1.15 | 1.33 | 1.23 | 3 |
| T | 22 | 3.603 | 7.25 | 0.64 | 1.23 | 1.37 | 1.29 | |
| F | 23 | 3.060 | 4.88 | 1.18 | 0.84 | 1.31 | 1.13 | 3 |
| S | 24 | 3.919 | 4.28 | 1.00 | 0.77 | 1.15 | 0.96 | 3 |
| S | 25 | 3.603 | 4.48 | 0.69 | 0.86 | 1.37 | 1.19 | |
| M | 26 | 3.470 | 4.64 | 0.73 | 1.10 | 1.30 | 1.17 | |
| T | 27 | 3.067 | | | 0.87 | 1.05 | 0.94 | |
| W | 28 | 4.250 | 5.26 | 0.92 | 0.77 | 0.94 | 0.86 | 3 |
| T | 29 | 3.542 | 5.93 | 0.89 | 0.81 | 1.01 | 0.91 | |
| F | 30 | 3.176 | 5.62 | 0.71 | 0.82 | 1.05 | 0.95 | 3 |
| S | 31 | 3.208 | 1.87 | 0.64 | 0.49 | 0.97 | 0.78 | 2300 |
| AVERAGE | | 3.690 | 4.24 | 0.77 | 0.00 | 2.35 | 1.79 | 11.5 |
| | | | 23.6 | | | | | 671.7 |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

Sep-02

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | INF, MIN | pH | pH | pH | pH | pH | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|----------------|------|--------------|----------------|-------------|------------|------------|------------|------------|------------|-------------|------------|------------------|------------|--------------|------------|-------------|-----------|
| | | | INF | EFF | | | | | | | | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| S | 1 | 3.763 | 18.4 | 18.4 | 7.1 | 7.1 | 7.4 | 7.1 | 7.2 | 23 | <0.1 | 284 | 2.2 | 284 | 2.2 | | |
| M | 2 | 3.743 | 18.4 | 22.7 | 7.1 | 7.1 | 7.3 | 7.0 | 7.1 | 21.0 | <0.1 | 216 | 2.0 | 216 | 2.0 | | |
| T | 3 | 4.304 | 18.4 | 22.9 | 7.3 | 7.3 | 7.4 | 6.9 | 7.1 | 21.0 | <0.1 | 396 | 2.2 | 396 | 2.2 | | |
| W | 4 | 3.751 | 18.4 | 22.9 | 7.1 | 7.1 | 7.1 | 6.9 | 7.3 | 14.5 | <0.1 | 250.8 | 1.8 | 244 | 1.2 | | |
| T | 5 | 4.012 | 18.4 | 22.8 | 7.2 | 7.2 | 7.3 | 6.9 | 7.0 | 23.0 | <0.1 | 170.6 | 3.5 | 160 | 1.1 | | |
| F | 6 | 4.202 | 18.4 | 22.0 | 7.2 | 7.2 | 7.3 | 6.9 | 7.2 | 22.5 | <0.1 | 145.9 | 2.3 | 168 | 1.3 | | |
| S | 7 | 4.002 | 18.4 | 22.6 | 7.1 | 7.1 | 7.3 | 6.9 | 7.1 | 24.0 | <0.1 | 226.8 | 2.2 | 268 | 6.0 | | |
| S | 8 | 4.512 | 18.4 | 22.8 | 7.1 | 7.1 | 7.3 | 6.7 | 7.1 | 22.0 | <0.1 | 236 | 1.6 | 236 | 1.6 | | |
| M | 9 | 4.469 | 18.7 | 22.8 | 7.2 | 7.2 | 7.4 | 6.9 | 7.3 | 22.0 | <0.1 | 212 | 2.1 | 212 | 2.1 | | |
| T | 10 | 4.481 | 19.1 | 23.2 | 7.1 | 7.1 | 7.1 | 6.8 | 7.0 | 22.0 | <0.1 | 232 | 1.3 | 232 | 1.3 | | |
| W | 11 | 5.678 | 19.7 | 22.6 | 7.3 | 7.3 | 7.4 | 6.8 | 7.0 | 23.0 | <0.1 | 229.1 | 3.2 | 248 | 1.6 | | |
| T | 12 | 4.668 | 19.4 | 22.0 | 7.1 | 7.1 | 7.4 | 6.7 | 7.1 | 20.0 | <0.1 | 137.3 | 2.4 | 192 | 0.4 | | |
| F | 13 | 3.836 | 19.1 | 22.2 | 7.1 | 7.1 | 7.4 | 6.8 | 7.5 | 24.0 | <0.1 | 135.1 | 3.4 | 304 | 3.0 | | |
| S | 14 | 3.503 | 18.7 | 23.0 | 7.3 | 7.3 | 7.3 | 6.7 | 6.8 | 24.0 | <0.1 | 173.3 | 1.8 | 212 | 2.4 | | |
| S | 15 | 4.336 | 18.4 | 22.9 | 7.2 | 7.2 | 7.3 | 6.8 | 6.8 | 22.0 | <0.1 | 240 | 2.2 | 240 | 2.2 | | |
| M | 16 | 4.107 | 18.4 | 22.3 | 7.1 | 7.1 | 7.4 | 6.8 | 7.1 | 22.0 | <0.1 | 264 | 2.0 | 264 | 2.0 | | |
| T | 17 | 3.571 | 18.1 | 22.4 | 6.6 | 6.6 | 7.3 | 6.7 | 7.0 | 23.0 | <0.1 | 296 | 2.0 | 296 | 2.0 | | |
| W | 18 | 3.870 | 17.1 | 22.7 | 7.2 | 7.2 | 7.4 | 7.0 | 7.1 | 20.0 | <0.1 | 149.1 | 1.4 | 404 | 1.0 | | |
| T | 19 | 3.815 | 17.8 | 23.4 | 7.3 | 7.3 | 7.3 | 6.9 | 7.2 | 24.0 | <0.1 | 140.8 | 2.2 | 228 | 2.2 | | |
| F | 20 | 4.218 | 18.4 | 24.1 | 7.2 | 7.2 | 7.3 | 6.8 | 7.0 | 24.0 | <0.1 | 199.3 | 1.4 | 224 | 1.2 | | |
| S | 21 | 3.694 | 19.1 | 24.1 | 7.3 | 7.3 | 7.5 | 7.0 | 7.2 | 22.0 | <0.1 | 193.2 | 1.7 | 204 | 1.4 | | |
| S | 22 | 3.443 | 19.4 | 23.7 | 7.1 | 7.1 | 7.3 | 6.8 | 7.0 | 19.0 | <0.1 | 248 | 3.6 | 248 | 3.6 | | |
| M | 23 | 3.555 | 19.1 | 23.1 | 7.2 | 7.2 | 7.3 | 6.7 | 7.0 | 22.0 | <0.1 | 192 | 2.2 | 192 | 2.2 | | |
| T | 24 | 4.048 | 19.1 | 22.7 | 7.1 | 7.1 | 7.3 | 6.8 | 7.0 | 24.0 | <0.1 | 316 | 1.4 | 316 | 1.4 | | |
| W | 25 | 4.071 | 18.5 | 23.1 | 7.0 | 7.0 | 7.4 | 6.9 | 7.1 | 21.0 | <0.1 | 176.5 | 2.5 | 248 | 1.6 | | |
| T | 26 | 4.253 | 18.1 | 21.8 | 7.3 | 7.3 | 7.4 | 7.0 | 7.1 | 19.0 | <0.1 | 183.7 | 3.5 | 204 | 1.6 | | |
| F | 27 | 7.608 | 18.4 | 20.1 | 7.0 | 7.0 | 7.4 | 7.1 | 7.2 | 27.0 | <0.1 | 130.2 | 2.3 | 320 | 2.0 | | |
| S | 28 | 4.689 | 17.8 | 19.3 | 7.2 | 7.2 | 7.4 | 6.8 | 7.2 | 21.0 | <0.1 | 283.0 | 2.0 | 364 | 2.2 | | |
| S | 29 | 4.469 | 17.4 | 19.6 | 7.2 | 7.2 | 7.4 | 6.9 | 6.9 | 15.0 | <0.1 | 264 | 2.0 | 264 | 2.0 | | |
| M | 30 | 4.769 | 18.1 | 21.1 | 7.2 | 7.2 | 7.2 | 6.9 | 6.9 | 21.0 | <0.1 | 148 | 2.0 | 148 | 2.0 | | |
| AVERAGE | | 4.248 | 18.5 | 22.3 | 6.6 | 6.6 | 7.5 | 6.7 | 7.5 | 27.0 | 0.0 | 185.6 | 2.4 | 252.8 | 1.9 | | |
| | | Monthly | ave. | ave. | min | max | min | max | max | max | max | 98.7% | 88.8 | 99.2% | 68.8 | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Sep-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|-------------------|----------|----------|---------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| S | 1 | 3.763 | 20.71 | 0.52 | 0.97 | 1.20 | 1.07 | | |
| M | 2 | 3.743 | 3.78 | 0.57 | 0.60 | 1.25 | 0.97 | | |
| T | 3 | 4.304 | | | 0.67 | 1.32 | 0.98 | | |
| W | 4 | 3.751 | 8.42 | 0.46 | 0.67 | 1.03 | 0.83 | 3 | |
| T | 5 | 4.012 | 5.69 | 0.50 | 0.48 | 1.33 | 0.95 | | |
| F | 6 | 4.202 | 11.11 | 0.65 | 0.70 | 0.81 | 0.75 | 3 | |
| S | 7 | 4.002 | 5.15 | 0.66 | 0.86 | 1.08 | 0.99 | 3 | |
| S | 8 | 4.512 | 17.35 | 0.68 | 1.15 | 1.42 | 1.31 | | |
| M | 9 | 4.469 | 16.84 | 0.83 | 0.95 | 1.12 | 1.04 | | |
| T | 10 | 4.481 | | | 1.03 | 1.33 | 1.21 | | |
| W | 11 | 5.678 | 12.51 | 1.17 | 1.11 | 2.08 | 1.47 | 3 | |
| T | 12 | 4.668 | 6.75 | 0.80 | 1.15 | 1.57 | 1.35 | | |
| F | 13 | 3.836 | 4.99 | 0.80 | 0.90 | 0.95 | 0.92 | 3 | |
| S | 14 | 3.503 | 5.56 | 0.92 | 0.90 | 1.04 | 0.95 | 3 | |
| S | 15 | 4.336 | 10.14 | 1.01 | 0.90 | 1.00 | 0.93 | | |
| M | 16 | 4.107 | 5.07 | 0.82 | 0.92 | 1.22 | 1.11 | | |
| T | 17 | 3.571 | | | 1.02 | 1.20 | 1.10 | | |
| W | 18 | 3.870 | 6.78 | 0.64 | 0.80 | 0.83 | 0.82 | 3 | |
| T | 19 | 3.815 | 10.37 | 0.69 | 0.78 | 1.14 | 0.92 | | |
| F | 20 | 4.218 | 5.69 | 0.71 | 0.24 | 1.65 | 0.86 | 124 | |
| S | 21 | 3.694 | 7.72 | 0.69 | 0.76 | 1.38 | 1.10 | 3 | |
| S | 22 | 3.443 | 5.12 | 0.90 | 0.79 | 1.10 | 0.93 | | |
| M | 23 | 3.555 | 3.12 | 0.88 | 0.71 | 1.58 | 1.19 | | |
| T | 24 | 4.048 | | | 0.62 | 1.19 | 0.97 | | |
| W | 25 | 4.071 | 2.38 | 0.82 | 1.26 | 1.58 | 1.41 | 3 | |
| T | 26 | 4.253 | 5.97 | 0.89 | 1.00 | 1.33 | 1.18 | | |
| F | 27 | 7.608 | 7.64 | 0.90 | 0.77 | 1.39 | 1.09 | 3 | |
| S | 28 | 4.689 | 5.88 | 0.55 | 1.17 | 1.44 | 1.34 | 3 | |
| S | 29 | 4.469 | 5.14 | 0.21 | 1.08 | 1.39 | 1.23 | | |
| M | 30 | 4.769 | 2.10 | 0.23 | 1.44 | 1.66 | 1.53 | | |
| AVERAGE | | 4.248 | 7.24 | 0.72 | 0.24 | 2.08 | 1.53 | 4.1 | |
| | | | 25.6 | | | | | 10.4 | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Oct-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|----------------|------|-------|----------------|------|----------|-----|----------|-----|----------|----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | MAX | EFF, MIN | MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| T | 1 | 4.022 | 18.5 | 21.1 | 7.0 | 7.3 | 7.0 | 7.2 | 19.00 | <0.1 | | | | 208 | 2.0 | |
| W | 2 | 4.104 | 19.5 | 21.4 | 7.0 | 8.0 | 7.1 | 7.2 | 21.00 | <0.1 | 196.4 | 2.8 | 152 | 1.2 | | |
| T | 3 | 4.321 | 19.2 | 21.0 | 7.4 | 7.4 | 7.1 | 7.4 | 25.50 | <0.1 | 218.9 | 4.4 | 220 | 1.2 | | |
| F | 4 | 4.268 | 19.1 | 20.7 | 7.2 | 7.2 | 6.8 | 7.1 | 22.00 | <0.1 | 172.6 | 4.3 | 188 | 1.1 | | |
| S | 5 | 8.144 | 19.4 | 21.3 | 7.2 | 7.3 | 7.0 | 7.1 | 22.00 | <0.1 | 212.8 | 3.2 | 352 | 0.9 | | |
| S | 6 | 3.945 | 18.5 | 20.7 | 7.2 | 7.2 | 6.9 | 7.0 | 23.00 | <0.1 | | | 172 | 0.7 | | |
| M | 7 | 3.469 | 18.9 | 20.2 | 7.3 | 7.5 | 6.8 | 7.0 | 25.00 | <0.1 | | | 201 | 1.0 | | |
| T | 8 | 4.107 | 19.1 | 20.1 | 7.2 | 7.4 | 6.8 | 7.2 | 25.00 | <0.1 | | | 708 | 0.5 | | |
| W | 9 | 3.524 | 19.0 | 19.3 | 7.3 | 7.3 | 6.8 | 7.2 | 26.00 | <0.1 | 164.0 | 1.4 | 192 | 0.6 | | |
| T | 10 | 3.678 | 18.9 | 20.0 | 7.3 | 7.5 | 6.9 | 7.0 | 23.00 | <0.1 | 218.2 | 3.3 | 228 | 1.0 | | |
| F | 11 | 3.978 | 18.5 | 20.7 | 7.0 | 7.3 | 6.9 | 7.0 | 21.00 | <0.1 | 209.5 | 1.6 | 232 | 0.8 | | |
| S | 12 | 4.523 | 20.0 | 21.3 | 7.0 | 7.3 | 6.9 | 7.1 | 27.00 | <0.1 | 231.4 | 5.1 | 364 | 1.1 | | |
| S | 13 | 3.795 | 19.0 | 21.4 | 7.2 | 7.3 | 7.0 | 7.1 | 27.00 | <0.1 | | | 292 | 0.6 | | |
| M | 14 | 3.960 | 18.3 | 20.2 | 7.3 | 7.4 | 7.1 | 7.3 | 28.00 | <0.1 | | | 184 | 0.8 | | |
| T | 15 | 4.222 | 18.5 | 19.1 | 7.3 | 7.4 | 7.0 | 7.2 | 20.00 | <0.1 | | | 308 | 0.8 | | |
| W | 16 | 5.730 | 18.7 | 19.6 | 7.2 | 7.4 | 7.0 | 7.1 | 26.00 | <0.1 | 192.6 | 3.2 | 348 | 0.5 | | |
| T | 17 | 4.439 | 18.2 | 19.2 | 7.2 | 7.4 | 6.9 | 7.1 | 24.00 | <0.1 | 254.8 | 3.9 | 316 | 1.2 | | |
| F | 18 | 8.389 | 18.0 | 18.9 | 7.2 | 7.4 | 6.9 | 7.1 | 19.00 | <0.1 | 108.6 | 10.7 | 172 | 1.6 | | |
| S | 19 | 6.055 | 17.9 | 18.9 | 7.2 | 7.3 | 6.9 | 7.0 | 17.00 | <0.1 | 70.1 | 3.6 | 360 | 2.4 | | |
| S | 20 | 5.032 | 17.5 | 18.2 | 7.2 | 7.3 | 6.9 | 7.2 | 16.00 | <0.1 | | | 360 | 1.8 | | |
| M | 21 | 4.259 | 17.4 | 18.5 | 7.0 | 7.3 | 6.7 | 6.9 | 12.50 | <0.1 | | | 144 | 2.0 | | |
| T | 22 | 4.348 | 17.5 | 18.7 | 7.1 | 7.4 | 7.0 | 7.3 | 11.00 | <0.1 | | | 112 | 2.2 | | |
| W | 23 | 3.765 | 17.1 | 19.1 | 7.3 | 7.4 | 6.9 | 7.0 | 11.00 | <0.1 | 152.9 | 2.0 | 184 | 2.2 | | |
| T | 24 | 3.874 | 17.2 | 18.6 | 7.4 | 7.5 | 6.9 | 7.0 | 15.00 | <0.1 | 223.0 | 2.0 | 348 | 2.4 | | |
| F | 25 | 5.881 | 17.3 | 18.8 | 7.0 | 7.4 | 6.9 | 7.0 | 11.00 | <0.1 | 150.4 | 1.8 | 212 | 2.0 | | |
| S | 26 | 4.906 | 17.0 | 18.0 | 7.1 | 7.4 | 6.9 | 7.1 | 16.00 | <0.1 | 106.6 | 24.7 | 212 | 2.4 | | |
| S | 27 | 4.224 | 16.9 | 18.2 | 6.9 | 7.4 | 6.9 | 7.0 | 16.00 | <0.1 | | | 164 | 1.8 | | |
| M | 28 | 4.646 | 16.8 | 18.1 | 7.1 | 7.4 | 6.8 | 7.0 | 15.00 | <0.1 | | | 208 | 2.8 | | |
| T | 29 | 4.050 | 16.9 | 18.4 | 7.4 | 7.5 | 7.0 | 7.0 | 19.50 | <0.1 | | | 176 | 2.0 | | |
| W | 30 | 3.968 | 17.2 | 18.1 | 7.4 | 7.5 | 7.0 | 7.1 | 22.00 | <0.1 | 206.3 | 2.7 | 148 | 0.3 | | |
| T | 31 | 3.886 | 16.7 | 17.2 | 7.2 | 7.4 | 7.1 | 7.1 | 0.00 | <0.1 | 188.0 | 20.6 | 212 | 1.0 | | |
| AVERAGE | | 4.565 | 18.2 | 19.5 | 6.9 | 8.0 | 6.7 | 7.4 | 28.0 | 0.0 | 176.7 | 5.8 | 247.6 | 1.4 | | |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | 96.7% | 234.4 | 99.4% | 53.7 | | |

NIAGARA COUNTY SEWER DISTRICT #1

Oct-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|-------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| T | 1 | 4.022 | | | 1.17 | 1.29 | 1.23 | | |
| W | 2 | 4.104 | 4.37 | 0.64 | 0.73 | 1.46 | 1.04 | 3 | |
| T | 3 | 4.321 | 2.81 | 0.39 | 0.82 | 1.18 | 1.04 | | |
| F | 4 | 4.268 | 7.49 | 0.88 | 0.84 | 1.10 | 0.95 | 3 | |
| S | 5 | 8.144 | 1.99 | 0.94 | 0.72 | 1.13 | 0.98 | 3 | |
| S | 6 | 3.945 | 4.44 | 0.90 | 1.08 | 1.31 | 1.16 | | |
| M | 7 | 3.469 | 6.16 | 0.96 | 1.30 | 1.80 | 1.52 | | |
| T | 8 | 4.107 | | | 0.95 | 1.26 | 1.11 | | |
| W | 9 | 3.524 | 3.90 | 0.97 | 1.50 | 1.64 | 1.55 | 3 | |
| T | 10 | 3.678 | 6.35 | 0.95 | 1.55 | 1.58 | 1.56 | | |
| F | 11 | 3.978 | 3.39 | 0.83 | 1.20 | 1.80 | 1.52 | 3 | |
| S | 12 | 4.523 | 6.63 | 0.76 | 0.47 | 1.31 | 0.83 | 3 | |
| S | 13 | 3.795 | 4.25 | 0.66 | 0.53 | 0.72 | 0.60 | | |
| M | 14 | 3.960 | 6.44 | 0.87 | 0.66 | 0.81 | 0.73 | | |
| T | 15 | 4.222 | | | 0.17 | 0.95 | 0.51 | | |
| W | 16 | 5.730 | 5.19 | 1.15 | 0.88 | 1.85 | 1.45 | 3 | |
| T | 17 | 4.439 | 6.39 | 0.90 | 0.92 | 0.98 | 0.95 | | |
| F | 18 | 8.389 | 3.15 | 0.59 | 1.06 | 1.10 | 1.08 | 3 | |
| S | 19 | 6.055 | 4.48 | 0.53 | 1.23 | 1.75 | 1.52 | 3 | |
| S | 20 | 5.032 | 4.13 | 0.55 | 1.10 | 1.20 | 1.15 | | |
| M | 21 | 4.259 | 2.07 | 0.25 | 0.74 | 1.12 | 0.89 | | |
| T | 22 | 4.348 | | | 1.18 | 1.48 | 1.31 | | |
| W | 23 | 3.765 | 3.23 | 0.51 | 1.10 | 1.54 | 1.31 | 3 | |
| T | 24 | 3.874 | 4.17 | 0.71 | 1.25 | 1.57 | 1.38 | | |
| F | 25 | 5.881 | 4.60 | 0.84 | 1.01 | 1.23 | 1.10 | 3 | |
| S | 26 | 4.906 | 4.21 | 1.33 | 0.16 | 0.99 | 0.51 | 119 | |
| S | 27 | 4.224 | 4.29 | 0.73 | 1.28 | 1.57 | 1.39 | | |
| M | 28 | 4.646 | 4.91 | 0.81 | 1.31 | 1.98 | 1.57 | | |
| T | 29 | 4.050 | | | 0.99 | 1.51 | 1.25 | | |
| W | 30 | 3.968 | 4.95 | 1.18 | 1.07 | 1.61 | 1.40 | | |
| T | 31 | 3.886 | 9.86 | 1.03 | 1.04 | 1.94 | 1.37 | | |
| AVERAGE | | 4.565 | 4.76 | 0.80 | 0.16 | 1.98 | 1.57 | 4.1 | |
| | | | 30.7 | | | | | 10.2 | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Apr-03

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|------------------|----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| T | 1 | 9.864 | 9.8 | 9.3 | 7.2 | 7.3 | 7.0 | 7.2 | 0.50 | <0.1 | | | 24 | 2.6 |
| W | 2 | 9.316 | 9.9 | 10.1 | 7.0 | 7.3 | 6.9 | 7.1 | 1.50 | <0.1 | 82.0 | 23.8 | 56 | 2.0 |
| T | 3 | 8.602 | 10.1 | 10.3 | 7.0 | 7.3 | 6.8 | 7.2 | 1.50 | <0.1 | 89.7 | 15.6 | 84 | 2.2 |
| F | 4 | 9.455 | 10.0 | 9.8 | 7.2 | 7.3 | 7.1 | 7.3 | 1.40 | <0.1 | 81.9 | 11.4 | 64 | 2.8 |
| S | 5 | 10.882 | 9.8 | 9.4 | 7.0 | 7.2 | 6.9 | 7.0 | 0.50 | <0.1 | 67.3 | 8.6 | 44 | 2.2 |
| S | 6 | 12.802 | 9.4 | 9.3 | 6.9 | 7.1 | 7.0 | 7.3 | 0.70 | <0.1 | | | 40 | 2.2 |
| M | 7 | 13.033 | 9.2 | 9.9 | 6.7 | 7.1 | 6.9 | 7.1 | 1.50 | <0.1 | | | 40 | 2.0 |
| T | 8 | 11.222 | 9.3 | 9.4 | 6.8 | 7.5 | 6.8 | 7.2 | 0.40 | <0.1 | | | 40 | 2.8 |
| W | 9 | 10.862 | 9.4 | 9.4 | 7.3 | 7.4 | 7.1 | 7.3 | 0.20 | <0.1 | 73.3 | 16.7 | 36 | 4.6 |
| T | 10 | 12.452 | 9.3 | 9.4 | 7.4 | 7.4 | 7.1 | 7.1 | 0.20 | <0.1 | 57.8 | 7.5 | 44 | 3.8 |
| F | 11 | 10.757 | 9.6 | 9.2 | 6.9 | 7.3 | 6.8 | 7.1 | 0.10 | <0.1 | 72.2 | 22.8 | 40 | 8.8 |
| S | 12 | 14.922 | 9.6 | 9.5 | 7.2 | 7.4 | 6.9 | 7.1 | 14.00 | <0.1 | 134.9 | 7.3 | 160 | 5.4 |
| S | 13 | 11.919 | 9.8 | 10.1 | 7.3 | 7.4 | 6.9 | 7.1 | 0.10 | <0.1 | | | 40 | 2.8 |
| M | 14 | 10.309 | 9.8 | 10.4 | 7.2 | 7.3 | 7.0 | 7.0 | 0.20 | <0.1 | | | 32 | 4.0 |
| T | 15 | 9.636 | 10.4 | 11.3 | 7.1 | 7.3 | 6.7 | 7.3 | 0.30 | <0.1 | | | 72 | 6.0 |
| W | 16 | 9.170 | 10.6 | 11.4 | 7.2 | 7.4 | 7.1 | 7.2 | 11.00 | <0.1 | 85.4 | 30.2 | 124 | 2.2 |
| T | 17 | 8.284 | 10.4 | 10.9 | 7.3 | 7.4 | 7.2 | 7.3 | 0.50 | <0.1 | 88.3 | 14.8 | 36 | 3.2 |
| F | 18 | 7.993 | 10.6 | 11.0 | 7.2 | 7.4 | 7.2 | 7.2 | 0.50 | <0.1 | 88.2 | 12.0 | 28 | 3.4 |
| S | 19 | 7.631 | 10.5 | 11.7 | 7.2 | 7.3 | 7.2 | 7.2 | 0.30 | <0.1 | 83.2 | 5.7 | 12 | 1.2 |
| S | 20 | 7.409 | 10.8 | 13.1 | 7.2 | 7.3 | 7.2 | 7.3 | 2.00 | <0.1 | | | 60 | 3.3 |
| M | 21 | 7.389 | 11.1 | 13.4 | 7.1 | 7.3 | 7.2 | 7.3 | 12.00 | <0.1 | | | 144 | 1.7 |
| T | 22 | 7.436 | 11.1 | 12.9 | 7.2 | 7.3 | 7.2 | 7.4 | 3.50 | <0.1 | | | 92 | 1.8 |
| W | 23 | 7.321 | 10.4 | 12.2 | 7.3 | 7.4 | 7.2 | 7.2 | 8.00 | <0.1 | 120.5 | 4.6 | 176 | 3.8 |
| T | 24 | 7.063 | 9.4 | 11.6 | 7.2 | 7.3 | 7.0 | 7.2 | 1.00 | <0.1 | 87.5 | 7.4 | 40 | 2.6 |
| F | 25 | 6.882 | 9.8 | 12.1 | 7.3 | 7.3 | 7.1 | 7.2 | 1.00 | <0.1 | 105.1 | 10.5 | 40 | 2.0 |
| S | 26 | 6.671 | 9.9 | 12.3 | 7.3 | 7.4 | 7.1 | 7.2 | 3.00 | <0.1 | 90.9 | 6.6 | 56 | 3.0 |
| S | 27 | 6.701 | 10.1 | 12.4 | 7.3 | 7.3 | 7.1 | 7.3 | 1.50 | <0.1 | | | 68 | 3.6 |
| M | 28 | 6.699 | 10.2 | 13.2 | 7.2 | 7.3 | 7.3 | 7.7 | 1.70 | <0.1 | | | 84 | 4.2 |
| T | 29 | 6.630 | 10.0 | 13.5 | 6.9 | 7.4 | 7.1 | 7.3 | 4.00 | <0.1 | | | 108 | 5.8 |
| W | 30 | 6.312 | 11.0 | 11.0 | 7.3 | 7.3 | 7.2 | 7.3 | 1.50 | <0.1 | 108.9 | 9.8 | 52 | 2.2 |
| AVERAGE | | 9.187 | 10.0 | 11.0 | 6.7 | 7.5 | 6.7 | 7.7 | 14.0 | 0.0 | 88.8 | 12.9 | 63.6 | 3.3 |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | 85.5% | 976.0 | 94.7% | 256.4 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
Apr-03

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | |
| T | 1 | 9.864 | | | 0.14 | 0.63 | 0.40 | |
| W | 2 | 9.316 | 1.60 | 0.31 | 0.25 | 1.21 | 0.88 | 3 |
| T | 3 | 8.602 | 2.64 | 0.30 | 0.64 | 1.23 | 0.95 | |
| F | 4 | 9.455 | 1.80 | 0.37 | 0.77 | 1.32 | 0.99 | 3 |
| S | 5 | 10.882 | 2.20 | 0.47 | 0.88 | 1.14 | 0.99 | 3 |
| S | 6 | 12.802 | 2.00 | 0.38 | 0.67 | 1.15 | 0.89 | |
| M | 7 | 13.033 | 2.08 | 0.35 | 0.75 | 1.14 | 0.93 | |
| T | 8 | 11.222 | | | 0.52 | 0.82 | 0.63 | |
| W | 9 | 10.862 | 1.56 | 0.39 | 0.56 | 0.64 | 0.61 | 7 |
| T | 10 | 12.452 | 1.80 | 0.54 | 0.23 | 0.59 | 0.40 | |
| F | 11 | 10.757 | 1.92 | 0.90 | 0.41 | 0.85 | 0.60 | 4 |
| S | 12 | 14.922 | 4.72 | 0.81 | 0.24 | 0.61 | 0.42 | 124 |
| S | 13 | 11.919 | 1.32 | 0.47 | 0.08 | 0.50 | 0.29 | |
| M | 14 | 10.309 | 1.44 | 0.54 | 0.00 | 0.42 | 0.18 | |
| T | 15 | 9.636 | | | 0.33 | 0.47 | 0.42 | |
| W | 16 | 9.170 | 4.60 | 0.80 | 0.27 | 0.48 | 0.37 | 3 |
| T | 17 | 8.284 | 1.52 | 0.91 | 0.39 | 1.08 | 0.80 | |
| F | 18 | 7.993 | 1.52 | 0.90 | 0.49 | 0.95 | 0.73 | 3 |
| S | 19 | 7.631 | 0.80 | 0.74 | 0.61 | 1.45 | 1.16 | |
| S | 20 | 7.409 | 5.08 | 0.70 | 0.32 | 0.67 | 0.54 | 3 |
| M | 21 | 7.389 | 6.44 | 0.74 | 0.00 | 0.71 | 0.34 | |
| T | 22 | 7.436 | | | 0.35 | 0.60 | 0.50 | |
| W | 23 | 7.321 | 4.88 | 0.54 | 0.33 | 0.50 | 0.43 | 3 |
| T | 24 | 7.063 | 2.24 | 0.49 | 0.00 | 0.54 | 0.28 | |
| F | 25 | 6.882 | 3.12 | 0.71 | 0.41 | 0.52 | 0.46 | |
| S | 26 | 6.671 | 2.72 | 0.91 | 0.35 | 0.43 | 0.40 | 3 |
| S | 27 | 6.701 | 2.44 | 0.77 | 0.28 | 0.38 | 0.34 | 1400 |
| M | 28 | 6.699 | 4.04 | 0.71 | 0.34 | 0.74 | 0.48 | |
| T | 29 | 6.630 | | | 0.13 | 0.35 | 0.24 | |
| W | 30 | 6.312 | 2.48 | 0.55 | 0.69 | 1.03 | 0.91 | 3 |
| AVERAGE | | 9.187 | 2.54 | 0.59 | 0.00 | 1.45 | 1.16 | 7.0 |
| | | | | 46.2 | | | | 23.3 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 May-03

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | EFF, MIN | INF, MAX | pH | EFF, MAX | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|---------|--------|----------------|------|----------|----------|-----|----------|----------|-------|----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | INF, MAX | | | | | | INF, m/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| T | 1 | 8.018 | 11.4 | 11.4 | 7.2 | 7.4 | 7.1 | 7.1 | 7.2 | 3.50 | 111.0 | 12.6 | 80 | 4.0 | | | |
| F | 2 | 9.709 | 11.5 | 11.5 | 7.1 | 7.4 | 7.1 | 7.1 | 7.3 | 2.00 | 92.8 | 7.8 | 72 | 3.8 | | | |
| S | 3 | 8.851 | 10.6 | 10.7 | 7.3 | 7.4 | 7.1 | 7.1 | 7.2 | 18.00 | 259.2 | 9.9 | 912 | 3.8 | | | |
| S | 4 | 7.989 | 10.8 | 11.1 | 7.3 | 7.4 | 7.1 | 7.4 | 7.4 | 0.50 | | | 44 | 2.8 | | | |
| M | 5 | 7.908 | 11.3 | 10.8 | 7.3 | 7.5 | 7.2 | 7.3 | 7.3 | 5.00 | | | 68 | 2.2 | | | |
| T | 6 | 10.517 | 11.5 | 11.1 | 7.3 | 7.4 | 7.2 | 7.3 | 7.3 | 0.50 | | | 52 | 3.0 | | | |
| W | 7 | 8.923 | 11.9 | 11.4 | 7.0 | 7.3 | 7.2 | 7.2 | 7.2 | 1.50 | 80.4 | 21.6 | 32 | 3.4 | | | |
| T | 8 | 7.979 | 12.0 | 11.8 | 6.9 | 7.3 | 6.8 | 7.1 | 7.1 | 0.50 | 74.6 | 11.4 | 44 | 3.8 | | | |
| F | 9 | 7.733 | 11.8 | 12.1 | 7.0 | 7.2 | 7.0 | 7.3 | 7.3 | 14.00 | 179.6 | 12.3 | 188 | 4.4 | | | |
| S | 10 | 7.214 | 12.0 | 12.9 | 7.0 | 7.2 | 7.0 | 7.2 | 7.2 | 15.00 | 206.9 | 11.6 | 160 | 2.8 | | | |
| S | 11 | 8.928 | 12.4 | 12.4 | 7.0 | 7.3 | 7.2 | 7.2 | 7.2 | 20.00 | | | 292 | 2.8 | | | |
| M | 12 | 9.663 | 12.3 | 11.7 | 6.7 | 7.2 | 6.8 | 7.2 | 6.9 | 12.00 | | | 124 | 2.2 | | | |
| T | 13 | 10.831 | 12.1 | 11.4 | 7.0 | 7.3 | 7.0 | 7.0 | 7.0 | 11.00 | | | 132 | 4.6 | | | |
| W | 14 | 9.655 | 11.8 | 11.5 | 7.1 | 7.1 | 7.1 | 7.1 | 7.1 | 11.00 | 147.4 | 10.0 | 112 | 5.4 | | | |
| T | 15 | 8.649 | 11.1 | 11.9 | 6.8 | 7.3 | 6.9 | 7.0 | 7.0 | 15.00 | 142.2 | 10.4 | 168 | 4.2 | | | |
| F | 16 | 9.852 | 10.8 | 12.2 | 7.0 | 7.1 | 7.0 | 7.1 | 7.1 | 21.00 | 200.8 | 4.7 | 192 | 2.8 | | | |
| S | 17 | 11.104 | 11.3 | 11.8 | 7.0 | 7.0 | 7.1 | 7.1 | 7.2 | 20.00 | 174.9 | 9.0 | 192 | 3.4 | | | |
| S | 18 | 9.375 | 11.0 | 12.2 | 6.7 | 7.1 | 7.1 | 7.1 | 7.2 | 25.00 | | | 232 | 2.0 | | | |
| M | 19 | 8.578 | 11.0 | 12.7 | 6.6 | 7.2 | 7.0 | 7.0 | 7.0 | 22.00 | | | 192 | 2.6 | | | |
| T | 20 | 8.369 | 11.5 | 13.1 | 7.3 | 7.4 | 7.1 | 7.1 | 7.2 | 26.00 | | | 316 | 3.2 | | | |
| W | 21 | 11.252 | 11.5 | 11.6 | 7.3 | 7.3 | 7.2 | 7.2 | 7.2 | 17.00 | 187.5 | 16.2 | 256 | 4.2 | | | |
| T | 22 | 9.306 | 11.9 | 11.5 | 7.3 | 7.4 | 7.1 | 7.1 | 7.1 | 26.00 | 155.7 | 3.0 | 192 | 2.2 | | | |
| F | 23 | 8.453 | 12.0 | 11.7 | 7.3 | 7.4 | 7.1 | 7.1 | 7.2 | 28.00 | 178.6 | 7.0 | 228 | 4.2 | | | |
| S | 24 | 9.965 | 12.2 | 12.0 | 7.1 | 7.4 | 6.9 | 7.2 | 7.2 | 29.00 | 134.7 | 5.6 | 260 | 8.0 | | | |
| S | 25 | 10.371 | 12.6 | 12.2 | 7.2 | 7.3 | 7.2 | 7.2 | 7.2 | 26.00 | | | 184 | 5.2 | | | |
| M | 26 | 8.884 | 12.5 | 12.2 | 7.1 | 7.3 | 7.1 | 7.1 | 7.2 | 32.00 | | | 232 | 3.0 | | | |
| T | 27 | 8.367 | 12.3 | 12.7 | 7.1 | 7.3 | 7.2 | 7.1 | 7.5 | 28.00 | | | 264 | 5.0 | | | |
| W | 28 | 8.379 | 12.5 | 13.0 | 7.3 | 7.3 | 7.1 | 7.1 | 7.2 | 18.00 | 188.4 | 15.4 | 196 | 6.2 | | | |
| T | 29 | 7.853 | 12.8 | 13.4 | 7.1 | 7.3 | 7.1 | 7.1 | 7.2 | 20.00 | 153.6 | 10.2 | 260 | 3.2 | | | |
| F | 30 | 7.958 | 12.3 | 12.9 | 7.2 | 7.3 | 7.1 | 7.1 | 7.2 | 19.00 | 200.7 | 3.9 | 484 | 3.0 | | | |
| S | 31 | 8.689 | 12.5 | 13.0 | 7.2 | 7.4 | 7.1 | 7.1 | 7.1 | 12.00 | 131.7 | 3.0 | 120 | 2.0 | | | |
| AVERAGE | 9.010 | 11.8 | 12.0 | ave. | 6.6 | 7.5 | 6.8 | 7.5 | max | 32.0 | 158.0 | 9.7 | 201.5 | 3.7 | | | |
| | Monthly | ave. | ave. | ave. | min | max | min | max | max | max | max | max | max | max | 277.2 | | |
| | | | | | | | | | | | | | | | 98.2% | 724.8 | |

NIAGARA COUNTY SEWER DISTRICT #1

May-03

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F. COLI | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|----------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | / 100 ml |
| T | 1 | 8.018 | 3.08 | 0.96 | 0.37 | 0.74 | 0.51 | |
| F | 2 | 9.709 | 2.72 | 0.67 | 0.05 | 0.48 | 0.23 | 3600 |
| S | 3 | 8.851 | 15.76 | 0.39 | 0.82 | 1.02 | 0.92 | 3 |
| S | 4 | 7.989 | 1.06 | 0.51 | 0.77 | 0.93 | 0.87 | |
| M | 5 | 7.908 | 3.28 | 0.62 | 0.00 | 1.13 | 0.51 | |
| T | 6 | 10.517 | | | 0.65 | 1.06 | 0.86 | |
| W | 7 | 8.923 | 1.76 | 0.68 | 0.28 | 1.45 | 0.77 | 6 |
| T | 8 | 7.979 | 3.76 | 0.81 | 0.48 | 1.10 | 0.81 | |
| F | 9 | 7.733 | 3.92 | 0.93 | 0.20 | 0.80 | 0.51 | 560 |
| S | 10 | 7.214 | 5.52 | 1.09 | 0.12 | 0.78 | 0.55 | 3 |
| S | 11 | 8.928 | 6.88 | 0.91 | 0.18 | 0.72 | 0.48 | |
| M | 12 | 9.663 | 3.96 | 0.71 | 0.36 | 1.20 | 0.71 | |
| T | 13 | 10.831 | | | 0.82 | 0.92 | 0.87 | |
| W | 14 | 9.655 | 2.76 | 0.52 | 0.51 | 0.90 | 0.71 | |
| T | 15 | 8.649 | 9.84 | 0.52 | 0.63 | 0.76 | 0.69 | 3 |
| F | 16 | 9.852 | 4.60 | 0.44 | 0.57 | 0.92 | 0.78 | 24 |
| S | 17 | 11.104 | 6.20 | 0.58 | 0.72 | 0.81 | 0.77 | 7 |
| S | 18 | 9.375 | 3.08 | 0.43 | 0.58 | 0.63 | 0.61 | |
| M | 19 | 8.578 | 3.64 | 0.52 | 0.67 | 0.91 | 0.81 | |
| T | 20 | 8.369 | | | 0.01 | 0.25 | 0.15 | |
| W | 21 | 11.252 | 4.72 | 0.83 | 0.44 | 0.84 | 0.69 | 3 |
| T | 22 | 9.306 | 4.00 | 0.83 | 0.46 | 0.78 | 0.67 | |
| F | 23 | 8.453 | 3.60 | 1.01 | 0.15 | 0.46 | 0.32 | 1020 |
| S | 24 | 9.965 | 4.12 | 1.29 | 0.91 | 0.98 | 0.94 | 3 |
| S | 25 | 10.371 | 5.80 | 1.00 | 0.72 | 0.75 | 0.73 | |
| M | 26 | 8.884 | 4.28 | 1.06 | 0.83 | 0.88 | 0.86 | |
| T | 27 | 8.367 | | | 0.00 | 0.83 | 0.51 | |
| W | 28 | 8.379 | 3.20 | 1.24 | 0.30 | 0.94 | 0.55 | 3 |
| T | 29 | 7.853 | 6.64 | 0.91 | 0.38 | 0.81 | 0.54 | |
| F | 30 | 7.958 | 11.68 | 0.72 | 0.34 | 1.03 | 0.61 | 867 |
| S | 31 | 8.689 | 5.88 | 0.34 | 0.35 | 1.15 | 0.79 | 3 |
| AVERAGE | | 9.010 | 5.05 | 0.77 | 0.00 | 1.45 | 0.94 | 21.4 |
| | | | | 57.7 | | | | 41.0 |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Jun-03

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|-----------|-----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| S | 1 | 12.107 | 12.6 | 12.1 | 7.2 | 7.5 | 7.1 | 7.3 | 7.3 | 11.00 | <0.1 | | | 176 | 4.4 | |
| M | 2 | 9.659 | 13.0 | 12.5 | 7.2 | 7.4 | 7.1 | 7.3 | 7.3 | 9.00 | <0.1 | | | 72 | 2.2 | |
| T | 3 | 8.249 | 13.2 | 13.1 | 7.1 | 7.3 | 7.2 | 7.3 | 7.3 | 6.50 | <0.1 | | | 164 | 2.2 | |
| W | 4 | 7.909 | 13.1 | 13.2 | 7.3 | 7.4 | 7.2 | 7.3 | 7.3 | 9.00 | <0.1 | 203.0 | 3.8 | 184 | 1.2 | |
| T | 5 | 9.369 | 13.1 | 13.3 | 7.1 | 7.4 | 7.2 | 7.2 | 7.2 | 25.00 | <0.1 | 230.2 | 3.0 | 272 | 1.0 | |
| F | 6 | 8.199 | 13.6 | 13.4 | 7.3 | 7.4 | 7.2 | 7.2 | 7.2 | 20.00 | <0.1 | 178.7 | 18.2 | 216 | 1.2 | |
| S | 7 | 7.599 | 13.4 | 14.3 | 7.3 | 7.4 | 7.2 | 7.3 | 7.3 | 14.00 | <0.1 | 219.0 | 3.2 | 284 | 1.2 | |
| S | 8 | 7.579 | 13.5 | 14.0 | 7.2 | 7.4 | 7.1 | 7.3 | 7.3 | 17.00 | <0.1 | | | 232 | 1.2 | |
| M | 9 | 10.459 | 13.8 | 14.2 | 7.3 | 7.4 | 7.1 | 7.2 | 7.2 | 16.00 | <0.1 | | | 200 | 1.8 | |
| T | 10 | 8.649 | 14.0 | 14.1 | 6.5 | 7.2 | 7.0 | 7.2 | 7.2 | 11.00 | <0.1 | | | 128 | 2.2 | |
| W | 11 | 8.249 | 14.0 | 14.4 | 7.3 | 7.4 | 7.2 | 7.2 | 7.2 | 14.50 | <0.1 | 211.7 | 3.8 | 212 | 0.7 | |
| T | 12 | 8.059 | 14.1 | 14.5 | 7.3 | 7.4 | 7.2 | 7.2 | 7.2 | 16.00 | <0.1 | 201.2 | 4.1 | 144 | 1.2 | |
| F | 13 | 11.239 | 14.3 | 14.0 | 7.2 | 7.3 | 7.0 | 7.2 | 7.2 | 13.00 | <0.1 | 134.0 | 3.2 | 116 | 1.0 | |
| S | 14 | 9.999 | 14.0 | 14.3 | 7.2 | 7.3 | 6.9 | 7.2 | 7.2 | 8.60 | <0.1 | 159.9 | 3.8 | 140 | 2.0 | |
| S | 15 | 8.569 | 14.8 | 14.4 | 7.1 | 7.3 | 7.1 | 7.2 | 7.2 | 15.00 | <0.1 | | | 92 | 0.4 | |
| M | 16 | 7.959 | 14.7 | 15.0 | 7.0 | 7.3 | 7.1 | 7.2 | 7.2 | 17.00 | <0.1 | | | 144 | 1.3 | |
| T | 17 | 7.359 | 14.9 | 15.2 | 7.0 | 7.3 | 7.0 | 7.3 | 7.3 | 16.00 | <0.1 | | | 232 | 1.0 | |
| W | 18 | 7.159 | 15.1 | 15.8 | 7.1 | 7.2 | 7.0 | 7.2 | 7.2 | 17.00 | <0.1 | 152.8 | 3.0 | 176 | 1.1 | |
| T | 19 | 6.989 | 14.9 | 15.0 | 7.0 | 7.3 | 6.9 | 7.1 | 7.1 | 18.00 | <0.1 | 210.5 | 3.0 | 196 | 2.0 | |
| F | 20 | 6.639 | 14.6 | 15.0 | 7.2 | 7.3 | 7.2 | 7.3 | 7.3 | 15.00 | <0.1 | 135.3 | 3.0 | 164 | 2.0 | |
| S | 21 | 6.689 | 14.7 | 16.0 | 7.0 | 7.2 | 7.0 | 7.1 | 7.1 | 21.00 | <0.1 | 200.8 | 3.3 | 324 | 2.2 | |
| S | 22 | 6.779 | 14.5 | 15.7 | 7.0 | 7.1 | 7.1 | 7.2 | 7.2 | 19.00 | <0.1 | | | 276 | 2.8 | |
| M | 23 | 6.599 | 14.8 | 16.2 | 7.2 | 7.3 | 7.2 | 7.2 | 7.2 | 17.00 | <0.1 | | | 192 | 2.6 | |
| T | 24 | 6.359 | 15.3 | 16.1 | 7.0 | 7.2 | 7.1 | 7.2 | 7.2 | 20.00 | <0.1 | | | 244 | 2.0 | |
| W | 25 | 6.269 | 15.4 | 16.5 | 7.3 | 7.3 | 7.2 | 7.2 | 7.2 | 18.00 | <0.1 | 178.7 | 3.0 | 192 | 1.6 | |
| T | 26 | 6.270 | 15.9 | 17.2 | 7.3 | 7.4 | 7.1 | 7.2 | 7.2 | 20.00 | <0.1 | 250.1 | 3.0 | 220 | 1.5 | |
| F | 27 | 5.990 | 15.8 | 17.5 | 7.2 | 7.4 | 7.1 | 7.2 | 7.2 | 15.00 | <0.1 | 201.8 | 3.0 | 160 | 2.2 | |
| S | 28 | 5.990 | 16.8 | 17.3 | 7.2 | 7.3 | 7.1 | 7.2 | 7.2 | 14.00 | <0.1 | 185.9 | 4.6 | 236 | 3.8 | |
| S | 29 | 5.640 | 16.9 | 17.7 | 7.1 | 7.4 | 7.1 | 7.2 | 7.2 | 19.00 | <0.1 | | | 212 | 2.6 | |
| M | 30 | 5.870 | 16.7 | 17.4 | 7.3 | 7.3 | 7.2 | 7.3 | 7.3 | 22.00 | <0.1 | | | 272 | 2.2 | |
| AVERAGE | | | 7.815 | 14.5 | 6.5 | 7.5 | 6.9 | 7.3 | 7.3 | 25.0 | 0.0 | 189.1 | 4.4 | 190.4 | 1.8 | |
| Monthly | | | ave. | ave. | min | max | min | max | max | max | max | 97.7% | 280.1 | 99.0% | 118.7 | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Jun-03

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | F.COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|-----------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | | |
| S | 1 | 12.107 | 5.20 | 0.43 | 0.58 | 1.00 | 0.79 | |
| M | 2 | 9.659 | 2.40 | 0.39 | 0.76 | 0.94 | 0.87 | |
| T | 3 | 8.249 | | | 0.26 | 0.50 | 0.41 | |
| W | 4 | 7.909 | 3.08 | 0.56 | 0.00 | 1.05 | 0.45 | 3 |
| T | 5 | 9.369 | 6.16 | 0.44 | 0.44 | 0.81 | 0.68 | |
| F | 6 | 8.199 | 4.64 | 0.34 | 0.37 | 0.87 | 0.68 | 15 |
| S | 7 | 7.599 | 4.08 | 0.38 | 0.30 | 0.68 | 0.48 | 9 |
| S | 8 | 7.579 | 4.16 | 0.37 | 0.20 | 0.67 | 0.39 | |
| M | 9 | 10.459 | 4.88 | 0.36 | 0.41 | 0.88 | 0.60 | |
| T | 10 | 8.649 | | | 0.40 | 0.72 | 0.55 | |
| W | 11 | 8.249 | 4.00 | 0.43 | 0.42 | 0.88 | 0.72 | 16 |
| T | 12 | 8.059 | 3.12 | 0.49 | 0.53 | 0.96 | 0.75 | |
| F | 13 | 11.239 | 3.40 | 0.41 | 0.44 | 0.95 | 0.64 | 3 |
| S | 14 | 9.999 | 3.96 | 0.40 | 0.74 | 0.89 | 0.80 | 3 |
| S | 15 | 8.569 | 2.52 | 0.42 | 0.75 | 0.84 | 0.79 | |
| M | 16 | 7.959 | 4.86 | 0.53 | 0.49 | 0.89 | 0.67 | |
| T | 17 | 7.359 | | | 0.59 | 0.84 | 0.76 | |
| W | 18 | 7.159 | 2.68 | 0.54 | 0.87 | 0.93 | 0.90 | 3 |
| T | 19 | 6.989 | 4.56 | 0.55 | 0.59 | 0.80 | 0.68 | |
| F | 20 | 6.639 | 6.16 | 0.69 | 0.41 | 0.87 | 0.63 | 3 |
| S | 21 | 6.689 | 6.76 | 0.82 | 0.32 | 0.36 | 0.34 | 3 |
| S | 22 | 6.779 | 5.24 | 0.89 | 0.41 | 0.79 | 0.64 | |
| M | 23 | 6.599 | 4.52 | 0.84 | 0.15 | 0.55 | 0.37 | |
| T | 24 | 6.359 | | | 0.60 | 0.95 | 0.73 | |
| W | 25 | 6.269 | 4.32 | 1.09 | 0.63 | 0.95 | 0.77 | 3 |
| T | 26 | 6.270 | 4.04 | 1.11 | 0.57 | 0.73 | 0.65 | |
| F | 27 | 5.990 | 4.08 | 1.04 | 0.45 | 0.70 | 0.56 | 3 |
| S | 28 | 5.990 | 3.40 | 0.89 | 0.25 | 0.56 | 0.39 | 3 |
| S | 29 | 5.640 | 3.40 | 0.94 | 0.38 | 0.49 | 0.44 | |
| M | 30 | 5.870 | 3.60 | 0.94 | 0.00 | 0.55 | 0.34 | |
| AVERAGE | | 7.815 | 4.16 | 0.57 | 0.00 | 1.05 | 0.90 | 4.3 |
| | | | | 37.7 | | | | 12.9 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Nov-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 CERT. 4A

FRANK A. Nerone, P.E.

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|--|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | | |
| F | 1 | 3.898 | 17.1 | 17.9 | 7.4 | 7.0 | 7.5 | 7.1 | 30 | <0.1 | 153.9 | 192 | 0.3 | | | |
| S | 2 | 4.357 | 16.5 | 17.6 | 7.4 | 7.0 | 7.5 | 7.1 | 28.0 | <0.1 | 191.7 | 272 | 1.0 | | | |
| S | 3 | 3.977 | 16.5 | 18.0 | 7.4 | 7.0 | 7.5 | 7.0 | 24.0 | <0.1 | | 328 | 0.8 | | | |
| M | 4 | 3.946 | 16.8 | 18.1 | 7.5 | 7.1 | 7.6 | 7.1 | 30.0 | <0.1 | | 240 | 18.4 | | | |
| T | 5 | 4.727 | 16.7 | 17.8 | 7.3 | 7.1 | 7.6 | 7.2 | 16.0 | <0.1 | | 264 | 1.5 | | | |
| W | 6 | 5.213 | 16.7 | 18.0 | 7.3 | 7.1 | 7.6 | 7.2 | 29.0 | <0.1 | 213.6 | 276 | 1.6 | | | |
| T | 7 | 5.334 | 16.7 | 18.1 | 7.4 | 7.0 | 7.5 | 7.1 | 26.0 | <0.1 | 184.2 | 272 | 2.6 | | | |
| F | 8 | 5.022 | 16.6 | 18.3 | 7.4 | 6.9 | 7.6 | 7.1 | 21.0 | <0.1 | 148.8 | 212 | 6.2 | | | |
| S | 9 | 4.929 | 16.4 | 19.8 | 7.4 | 7.0 | 7.5 | 7.1 | 28.0 | <0.1 | 200.2 | 276 | 9.2 | | | |
| S | 10 | 5.759 | 16.0 | 19.8 | 7.4 | 7.0 | 7.4 | 7.1 | 28.0 | <0.1 | | 288 | 9.0 | | | |
| M | 11 | 6.507 | 16.1 | 19.0 | 7.4 | 6.9 | 7.5 | 7.1 | 15.0 | <0.1 | | 228 | 12.0 | | | |
| T | 12 | 4.668 | 15.7 | 17.5 | 7.3 | 7.1 | 7.4 | 7.1 | 17.0 | <0.1 | | 1024 | 9.8 | | | |
| W | 13 | 4.928 | 15.8 | 17.4 | 7.2 | 7.0 | 7.3 | 7.1 | 18.0 | <0.1 | 119.9 | 220 | 6.8 | | | |
| T | 14 | 5.368 | 15.6 | 17.1 | 7.2 | 7.1 | 7.5 | 7.2 | 27.0 | <0.1 | 182.4 | 176 | 2.4 | | | |
| F | 15 | 5.357 | 15.6 | 16.7 | 7.3 | 7.0 | 7.5 | 7.2 | 26.0 | <0.1 | 173.6 | 320 | 7.2 | | | |
| S | 16 | 5.003 | 15.2 | 16.4 | 7.1 | 7.1 | 7.5 | 7.2 | 24.0 | <0.1 | 121.2 | 344 | 5.6 | | | |
| S | 17 | 7.980 | 14.9 | 15.7 | 7.2 | 6.9 | 7.4 | 7.1 | 17.0 | <0.1 | | 232 | 5.6 | | | |
| M | 18 | 9.125 | 14.4 | 14.9 | 7.3 | 7.0 | 7.4 | 7.1 | 25.0 | <0.1 | | 252 | 6.8 | | | |
| T | 19 | 6.261 | 15.1 | 15.6 | 7.1 | 7.0 | 7.4 | 7.1 | 6.0 | <0.1 | | 1200 | 5.6 | | | |
| W | 20 | 5.882 | 14.7 | 16.5 | 7.2 | 7.1 | 7.5 | 7.2 | 19.0 | <0.1 | 96.7 | 152 | 9.6 | | | |
| T | 21 | 5.271 | 14.8 | 16.9 | 6.9 | 7.2 | 7.5 | 7.4 | 20.0 | <0.1 | 120.9 | 292 | 4.8 | | | |
| F | 22 | 9.654 | 14.4 | 16.4 | 7.3 | 7.0 | 7.5 | 7.0 | 20.0 | <0.1 | 135.6 | 260 | 5.2 | | | |
| S | 23 | 13.171 | 13.4 | 13.6 | 7.0 | 7.0 | 7.5 | 7.2 | 16.0 | <0.1 | 121.2 | 188 | 20.0 | | | |
| S | 24 | 9.450 | 13.5 | 13.5 | 7.4 | 7.2 | 7.5 | 7.2 | 11.0 | <0.1 | | 140 | 12.2 | | | |
| M | 25 | 8.214 | 13.6 | 13.8 | 7.4 | 7.1 | 7.5 | 7.2 | 14.0 | <0.1 | | 88 | 6.4 | | | |
| T | 26 | 7.309 | 13.9 | 13.5 | 7.4 | 7.2 | 7.5 | 7.3 | 13.0 | <0.1 | | 216 | 3.2 | | | |
| W | 27 | 5.065 | 13.8 | 13.3 | 7.0 | 7.1 | 7.4 | 7.3 | 13.0 | <0.1 | 134.2 | 220 | 2.0 | | | |
| T | 28 | 6.339 | 13.3 | 12.9 | 7.0 | 7.1 | 7.3 | 7.3 | 22.0 | <0.1 | 137.9 | 220 | 0.8 | | | |
| F | 29 | 6.302 | 12.7 | 12.6 | 7.2 | 7.1 | 7.4 | 7.2 | 23.0 | <0.1 | 130.1 | 352 | 1.9 | | | |
| S | 30 | 6.750 | 13.4 | 12.9 | 7.2 | 7.1 | 7.5 | 7.1 | 23.0 | <0.1 | 122.7 | 228 | 1.1 | | | |
| AVERAGE | | | 15.2 | 16.3 | 6.9 | 6.9 | 7.6 | 7.4 | 30.0 | 0.0 | 147.0 | 299.1 | 6.0 | | | |
| Monthly | | | ave. | ave. | min | min | max | max | max | max | 94.4% | 416.4 | 98.0% | 344.4 | | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Nov-02

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| F | 1 | 3.898 | 7.02 | 1.19 | 1.47 | 2.75 | 2.32 | 3 | |
| S | 2 | 4.357 | 7.29 | 1.31 | 0.98 | 1.67 | 1.21 | 3 | |
| S | 3 | 3.977 | 5.53 | 1.29 | 0.92 | 1.54 | 1.29 | | |
| M | 4 | 3.946 | 5.77 | 1.16 | 0.82 | 1.66 | 1.26 | | |
| T | 5 | 4.727 | | | 1.00 | 1.70 | 1.30 | | |
| W | 6 | 5.213 | 4.36 | 1.02 | 1.35 | 1.91 | 1.55 | 3 | |
| T | 7 | 5.334 | 6.31 | 1.10 | 1.00 | 1.48 | 1.28 | | |
| F | 8 | 5.022 | 25.70 | 1.58 | 1.18 | 1.57 | 1.43 | 3 | |
| S | 9 | 4.929 | 4.01 | 1.65 | 1.41 | 2.60 | 2.03 | 3 | |
| S | 10 | 5.759 | 6.66 | 0.86 | 0.46 | 0.68 | 0.55 | | |
| M | 11 | 6.507 | 5.26 | 0.92 | 0.50 | 0.65 | 0.59 | | |
| T | 12 | 4.668 | | | 0.06 | 1.78 | 0.64 | | |
| W | 13 | 4.928 | 5.53 | 0.89 | 1.63 | 1.80 | 1.74 | 3 | |
| T | 14 | 5.368 | 4.48 | 1.32 | 1.44 | 3.05 | 2.03 | | |
| F | 15 | 5.357 | 3.70 | 1.17 | 1.62 | 2.33 | 1.97 | 3 | |
| S | 16 | 5.003 | 3.74 | 1.03 | 1.65 | 1.78 | 1.73 | 3 | |
| S | 17 | 7.980 | 5.19 | 0.97 | 0.68 | 1.40 | 0.96 | | |
| M | 18 | 9.125 | 3.90 | 0.78 | 1.20 | 1.53 | 1.31 | | |
| T | 19 | 6.261 | | | 1.65 | 1.88 | 1.75 | | |
| W | 20 | 5.882 | 2.07 | 0.94 | 1.60 | 1.77 | 1.71 | 3 | |
| T | 21 | 5.271 | 4.60 | 0.72 | 0.97 | 1.43 | 1.15 | | |
| F | 22 | 9.654 | 4.25 | 0.60 | 0.90 | 1.09 | 1.00 | 3 | |
| S | 23 | 13.171 | 2.77 | 0.70 | 0.00 | 1.62 | 1.05 | 5700 | |
| S | 24 | 9.450 | 2.26 | 0.59 | 1.50 | 1.91 | 1.71 | | |
| M | 25 | 8.214 | 2.92 | 0.64 | 1.03 | 1.51 | 1.35 | | |
| T | 26 | 7.309 | 3.78 | 0.42 | 0.90 | 1.22 | 1.08 | | |
| W | 27 | 5.065 | 2.85 | 0.36 | 0.35 | 0.73 | 0.54 | 3 | |
| T | 28 | 6.339 | 4.60 | 0.42 | 0.71 | 1.06 | 0.87 | | |
| F | 29 | 6.302 | 1.79 | 0.18 | 0.64 | 0.87 | 0.79 | 3 | |
| S | 30 | 6.750 | 2.22 | 0.27 | 0.76 | 0.90 | 0.84 | 3 | |
| AVERAGE | | 6.192 | 5.06 | 0.89 | 0.00 | 3.05 | 2.32 | 5.1 | |
| | | | | 43.8 | | | | 37.2 | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Dec-02

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | | pH | | pH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | EFF, MIN | INF, MAX | EFF, MAX | INF, m/l | EFF, m/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| S | 1 | 5.690 | 12.7 | 12.5 | 7.3 | 7.2 | 7.4 | 7.2 | 7.2 | 7.2 | 18.00 | <0.1 | | | 164 | 1.2 |
| M | 2 | 5.734 | 13.2 | 12.6 | 7.4 | 7.1 | 7.4 | 7.1 | 7.2 | 24.50 | <0.1 | | | 280 | 2.7 | |
| T | 3 | 5.030 | 13.1 | 13.3 | 7.3 | 7.3 | 7.4 | 7.2 | 7.3 | 29.00 | <0.1 | | | 460 | 1.2 | |
| W | 4 | 5.228 | 13.0 | 13.2 | 7.2 | 7.1 | 7.5 | 7.1 | 7.2 | 9.00 | <0.1 | 138.4 | 2.0 | 176 | 1.5 | |
| T | 5 | 5.014 | 13.4 | 14.1 | 7.2 | 7.1 | 7.4 | 7.1 | 7.2 | 13.00 | <0.1 | 202.1 | 14.0 | 272 | 1.3 | |
| F | 6 | 5.095 | 13.5 | 14.5 | 7.3 | 7.2 | 7.4 | 7.2 | 7.5 | 16.00 | <0.1 | 134.7 | 1.0 | 248 | 1.4 | |
| S | 7 | 5.199 | 13.4 | 14.4 | 7.3 | 7.1 | 7.4 | 7.1 | 7.2 | 24.00 | <0.1 | 208.4 | 5.2 | 340 | 1.4 | |
| S | 8 | 5.280 | 13.4 | 13.8 | 7.1 | 7.0 | 7.3 | 7.0 | 7.2 | 14.00 | <0.1 | | | 212 | 1.2 | |
| M | 9 | 4.616 | 13.4 | 13.5 | 7.2 | 7.0 | 7.4 | 7.0 | 7.3 | 10.00 | <0.1 | | | 200 | 1.6 | |
| T | 10 | 4.844 | 13.3 | 13.9 | 7.2 | 7.0 | 7.2 | 7.0 | 7.4 | 16.50 | <0.1 | | | 180 | 1.0 | |
| W | 11 | 4.537 | 13.3 | 14.1 | 7.2 | 7.0 | 7.3 | 7.0 | 7.2 | 20.00 | <0.1 | 168.4 | 2.3 | 216 | 0.8 | |
| T | 12 | 7.211 | 13.3 | 14.4 | 7.2 | 7.0 | 7.3 | 7.0 | 7.2 | 16.00 | <0.1 | 160.9 | 3.0 | 172 | 1.8 | |
| F | 13 | 8.687 | 12.9 | 14.1 | 7.1 | 7.0 | 7.3 | 7.0 | 7.1 | 21.00 | <0.1 | 172.8 | 6.3 | 256 | 2.0 | |
| S | 14 | 14.592 | 11.9 | 13.3 | 7.1 | 6.9 | 7.5 | 6.9 | 7.3 | 27.00 | <0.1 | 197.2 | 8.3 | 428 | 3.6 | |
| S | 15 | 12.610 | 11.5 | 12.5 | 7.2 | 7.0 | 7.2 | 7.0 | 7.1 | 18.00 | <0.1 | | | 236 | 3.6 | |
| M | 16 | 11.560 | 11.6 | 12.3 | 7.2 | 7.0 | 7.5 | 7.0 | 7.1 | 13.00 | <0.1 | | | 108 | 2.2 | |
| T | 17 | 8.400 | 11.7 | 12.0 | 6.9 | 7.1 | 7.4 | 7.1 | 7.2 | 20.00 | <0.1 | | | 100 | 2.2 | |
| W | 18 | 10.823 | 11.7 | 12.1 | 7.4 | 7.4 | 7.4 | 7.2 | 7.3 | 19.00 | <0.1 | 224.8 | 7.2 | 168 | 2.4 | |
| T | 19 | 9.327 | 11.8 | 12.3 | 7.4 | 7.3 | 7.5 | 7.3 | 7.4 | 17.00 | <0.1 | 138.8 | 5.3 | 120 | 2.0 | |
| F | 20 | 17.238 | 10.9 | 11.6 | 7.3 | 7.3 | 7.4 | 7.3 | 7.3 | 12.00 | <0.1 | 185.4 | 24.0 | 160 | 3.0 | |
| S | 21 | 12.786 | 10.6 | 10.9 | 7.1 | 7.0 | 7.4 | 7.0 | 7.1 | 10.00 | <0.1 | 131.0 | 3.7 | 84 | 2.0 | |
| S | 22 | 8.643 | 11.1 | 11.2 | 7.3 | 7.2 | 7.4 | 7.2 | 7.3 | 14.00 | <0.1 | | | 228 | 1.1 | |
| M | 23 | 10.780 | 11.2 | 11.2 | 7.3 | 7.1 | 7.3 | 7.1 | 7.4 | 14.00 | <0.1 | | | 184 | 1.2 | |
| T | 24 | 7.798 | 11.5 | 11.4 | 6.9 | 7.3 | 7.3 | 7.1 | 7.2 | 14.00 | <0.1 | | | 188 | 2.0 | |
| W | 25 | 5.418 | 11.6 | 11.6 | 7.2 | 6.9 | 7.4 | 6.9 | 7.5 | 17.00 | <0.1 | 169.2 | 12.0 | 164 | 2.0 | |
| T | 26 | 6.348 | 11.5 | 11.4 | 7.0 | 7.2 | 7.7 | 7.2 | 7.3 | 23.00 | <0.1 | 229.1 | 5.0 | 164 | 0.3 | |
| F | 27 | 5.901 | 11.7 | 11.3 | 7.0 | 6.8 | 7.3 | 6.8 | 7.1 | 14.00 | <0.1 | 164.8 | 4.2 | 164 | 1.0 | |
| S | 28 | 5.861 | 11.7 | 11.9 | 7.0 | 6.9 | 7.0 | 6.9 | 7.1 | 21.50 | <0.1 | 157.4 | 8.9 | 140 | 0.3 | |
| S | 29 | 6.341 | 11.8 | 12.2 | 7.1 | 6.9 | 7.4 | 6.9 | 7.2 | 13.00 | <0.1 | | | 136 | 0.3 | |
| M | 30 | 6.188 | 11.8 | 11.2 | 7.0 | 6.8 | 7.1 | 6.8 | 7.2 | 11.00 | <0.1 | | | 156 | 1.0 | |
| T | 31 | 14.234 | 11.3 | 10.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.1 | 0.00 | <0.1 | | | 340 | 1.8 | |
| AVERAGE | | 7.968 | 12.2 | 12.6 | 6.9 | 6.8 | 7.7 | 6.8 | 7.5 | 29.0 | 0.0 | 175.4 | 8.4 | 207.9 | 1.6 | |
| Monthly | | ave. | ave. | ave. | min | min | max | min | max | max | max | 95.2% | 563.6 | 99.2% | 125.3 | |

NIAGARA COUNTY SEWER DISTRICT #1

Dec-02

| DAY | DATE | FLOW | PHOSPHOROUS | | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|----------|-------------------|----------|-----|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | | |
| S | 1 | 5.690 | 1.13 | 0.49 | 0.40 | 0.81 | 0.64 | | | |
| M | 2 | 5.734 | 4.25 | 0.49 | 0.40 | 0.77 | 0.64 | | | |
| T | 3 | 5.030 | | | 0.60 | 0.98 | 0.74 | | | |
| W | 4 | 5.228 | 6.24 | 0.27 | 0.64 | 0.80 | 0.74 | 3 | | |
| T | 5 | 5.014 | 2.65 | 0.20 | 0.60 | 0.83 | 0.75 | | | |
| F | 6 | 5.095 | 4.13 | 0.19 | 0.45 | 0.60 | 0.52 | 3 | | |
| S | 7 | 5.199 | 6.31 | 0.21 | 0.29 | 0.55 | 0.43 | 3 | | |
| S | 8 | 5.280 | 1.99 | 0.18 | 0.06 | 1.05 | 0.63 | | | |
| M | 9 | 4.616 | 3.16 | 0.31 | 0.64 | 0.88 | 0.80 | | | |
| T | 10 | 4.844 | | | 0.73 | 1.10 | 0.91 | | | |
| W | 11 | 4.537 | 4.68 | 0.32 | 0.55 | 1.10 | 0.85 | 3 | | |
| T | 12 | 7.211 | 3.74 | 0.25 | 0.80 | 1.06 | 0.95 | | | |
| F | 13 | 8.687 | 3.74 | 0.29 | 0.82 | 1.23 | 1.08 | 3 | | |
| S | 14 | 14.592 | 5.89 | 0.31 | 1.10 | 1.67 | 1.42 | 3 | | |
| S | 15 | 12.610 | 5.54 | 0.62 | 1.27 | 1.41 | 1.33 | | | |
| M | 16 | 11.560 | 1.68 | 0.23 | 1.15 | 1.25 | 1.20 | | | |
| T | 17 | 8.400 | | | 0.40 | 1.23 | 0.87 | 3 | | |
| W | 18 | 10.823 | 3.08 | 0.22 | 0.82 | 1.12 | 0.97 | | | |
| T | 19 | 9.327 | 2.42 | 0.20 | 0.20 | 1.03 | 0.65 | | | |
| F | 20 | 17.238 | 2.50 | 0.43 | 1.25 | 1.74 | 1.50 | 3 | | |
| S | 21 | 12.786 | 2.03 | 0.18 | 0.92 | 1.26 | 1.07 | 3 | | |
| S | 22 | 8.643 | 2.03 | 0.20 | 0.73 | 1.05 | 0.91 | | | |
| M | 23 | 10.780 | 4.25 | 0.21 | 0.70 | 1.02 | 0.86 | | | |
| T | 24 | 7.798 | | | 0.45 | 0.91 | 0.61 | | | |
| W | 25 | 5.418 | 3.63 | 0.29 | 0.46 | 0.67 | 0.58 | 3 | | |
| T | 26 | 6.348 | 6.63 | 0.24 | 0.56 | 0.75 | 0.63 | | | |
| F | 27 | 5.901 | 18.72 | 0.41 | 0.45 | 0.60 | 0.52 | 3 | | |
| S | 28 | 5.861 | 4.09 | 0.40 | 0.34 | 0.49 | 0.39 | 3 | | |
| S | 29 | 6.341 | 4.21 | 0.40 | 0.49 | 0.57 | 0.53 | | | |
| M | 30 | 6.188 | 4.64 | 0.46 | 0.41 | 0.64 | 0.53 | | | |
| T | 31 | 14.234 | | | 0.20 | 1.52 | 0.82 | | | |
| AVERAGE | | 7.968 | 4.36 | 0.31 | 0.06 | 1.74 | 1.50 | 3.0 | | |
| | | | | 21.7 | | | | 3.0 | | |

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Feb-03

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX
 FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | pH | pH | pH | pH | pH | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|-----|-----|-----|-----|-----|------------------|----------|----------|----------|-------------|----------|
| | | | INF | EFF | | | | | | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, m/l | EFF, m/l |
| S | 1 | 5.552 | 11.2 | 11.4 | 7.0 | 7.2 | 7.0 | 7.2 | 7.0 | 5 | <0.1 | 208.2 | 14.1 | 136 | 4.8 |
| S | 2 | 5.126 | 11.4 | 11.3 | 7.1 | 7.3 | 7.1 | 7.3 | 7.1 | 5.5 | <0.1 | | | 144 | 2.4 |
| M | 3 | 6.599 | 11.2 | 11.8 | 7.1 | 7.4 | 7.1 | 7.3 | 7.1 | 5.0 | <0.1 | | | 136 | 3.4 |
| T | 4 | 12.625 | 10.4 | 10.2 | 6.8 | 7.2 | 7.0 | 7.2 | 7.0 | 10.0 | <0.1 | | | 216 | 3.8 |
| W | 5 | 10.688 | 9.7 | 8.8 | 7.0 | 7.6 | 7.0 | 7.1 | 7.1 | 3.0 | <0.1 | 79.3 | 8.3 | 72 | 4.6 |
| T | 6 | 9.379 | 9.8 | 9.5 | 7.0 | 7.5 | 7.0 | 7.1 | 7.1 | 4.0 | <0.1 | 92.3 | 9.5 | 92 | 3.4 |
| F | 7 | 8.297 | 10.1 | 10.0 | 7.1 | 7.6 | 7.1 | 7.3 | 7.1 | 2.0 | <0.1 | 83.3 | 8.0 | 68 | 2.6 |
| S | 8 | 7.712 | 9.9 | 9.6 | 7.2 | 7.6 | 7.2 | 7.4 | 7.4 | 4.0 | <0.1 | 104.6 | 8.1 | 80 | 3.2 |
| S | 9 | 6.784 | 10.0 | 9.4 | 7.2 | 7.5 | 7.2 | 7.3 | 7.3 | 21.0 | <0.1 | | | 324 | 2.0 |
| M | 10 | 6.909 | 10.3 | 9.7 | 7.2 | 7.4 | 7.2 | 7.3 | 7.3 | 33.0 | <0.1 | | | 352 | 2.0 |
| T | 11 | 6.114 | 10.3 | 9.5 | 7.1 | 7.3 | 7.1 | 7.2 | 7.2 | 12.0 | <0.1 | | | 208 | 3.0 |
| W | 12 | 6.688 | 10.3 | 9.3 | 7.0 | 7.3 | 7.0 | 7.2 | 7.2 | 4.0 | <0.1 | 144.9 | 8.6 | 120 | 3.4 |
| T | 13 | 5.970 | 10.2 | 9.2 | 7.1 | 7.3 | 7.1 | 7.2 | 7.2 | 8.0 | <0.1 | 140.4 | 5.1 | 196 | 5.0 |
| F | 14 | 5.608 | 10.2 | 9.2 | 7.0 | 7.2 | 7.0 | 7.1 | 7.1 | 14.0 | <0.1 | 315.5 | 3.4 | 236 | 3.4 |
| S | 15 | 5.181 | 10.3 | 9.7 | 6.8 | 7.2 | 6.9 | 7.1 | 7.1 | 20.0 | <0.1 | 282.4 | 2.8 | 200 | 2.0 |
| S | 16 | 4.561 | 10.3 | 9.3 | 7.0 | 7.2 | 7.0 | 7.2 | 7.2 | 22.0 | <0.1 | | | 340 | 1.6 |
| M | 17 | 4.683 | 10.2 | 9.0 | 7.0 | 7.3 | 7.1 | 7.2 | 7.2 | 20.0 | <0.1 | | | 304 | 0.6 |
| T | 18 | 5.808 | 10.3 | 9.4 | 7.0 | 7.3 | 7.0 | 7.3 | 7.3 | 25.0 | <0.1 | | | 368 | 1.2 |
| W | 19 | 4.653 | 10.5 | 10.2 | 6.9 | 7.1 | 6.9 | 7.0 | 7.0 | 19.0 | <0.1 | 214.1 | 4.8 | 328 | 7.4 |
| T | 20 | 5.006 | 10.8 | 10.2 | 6.8 | 7.0 | 6.8 | 7.0 | 7.0 | 16.0 | <0.1 | 253.3 | 3.0 | 260 | 3.4 |
| F | 21 | 5.406 | 10.8 | 10.3 | 6.9 | 7.4 | 7.1 | 7.4 | 7.4 | 13.0 | <0.1 | 163.8 | 10.3 | 192 | 1.4 |
| S | 22 | 6.866 | 10.9 | 10.8 | 6.8 | 7.1 | 6.8 | 7.1 | 7.1 | 9.0 | <0.1 | 167.7 | 13.8 | 184 | 3.2 |
| S | 23 | 13.620 | 9.5 | 9.8 | 6.8 | 7.1 | 6.8 | 7.1 | 7.1 | 31.0 | <0.1 | | | 436 | 3.2 |
| M | 24 | 10.214 | 9.4 | 8.6 | 6.8 | 7.2 | 7.0 | 7.2 | 7.2 | 0.8 | <0.1 | | | 48 | 6.2 |
| T | 25 | 8.040 | 9.7 | 8.8 | 6.6 | 7.5 | 6.8 | 7.2 | 7.2 | 0.5 | <0.1 | | | 92 | 4.4 |
| W | 26 | 8.007 | 9.8 | 8.6 | 7.1 | 7.5 | 7.1 | 7.2 | 7.2 | 1.0 | <0.1 | 130.3 | 20.2 | 48 | 5.2 |
| T | 27 | 7.970 | 9.9 | 9.1 | 7.1 | 7.5 | 7.1 | 7.2 | 7.2 | 0.2 | <0.1 | 74.4 | 11.9 | 68 | 6.2 |
| F | 28 | 7.274 | 10.0 | 9.5 | 7.0 | 7.4 | 7.0 | 7.2 | 7.2 | 0.2 | <0.1 | 84.4 | 16.2 | 60 | 15.0 |
| AVERAGE | | 7.191 | 10.3 | 9.7 | 6.6 | 7.6 | 6.8 | 7.4 | 7.4 | 33.0 | 0.0 | 144.7 | 9.7 | 189.6 | 3.9 |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | max | 93.3% | 557.3 | 98.0% | 239.8 |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1

Feb-03

| DAY | DATE | FLOW | PHOSPHOROUS | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|-------------------|----------|----------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | |
| S | 1 | 5.552 | 6.32 | 0.38 | 0.51 | 0.80 | 0.68 | 3 | |
| S | 2 | 5.126 | 3.62 | 0.39 | 0.73 | 0.85 | 0.79 | | |
| M | 3 | 6.599 | 3.47 | 0.44 | 0.59 | 0.76 | 0.70 | | |
| T | 4 | 12.625 | | | 0.48 | 1.04 | 0.81 | | |
| W | 5 | 10.688 | 1.60 | 0.27 | 0.63 | 0.89 | 0.73 | 3 | |
| T | 6 | 9.379 | 1.87 | 0.31 | 0.66 | 0.70 | 0.68 | | |
| F | 7 | 8.297 | 1.99 | 0.26 | 0.42 | 0.72 | 0.54 | 3 | |
| S | 8 | 7.712 | 2.50 | 0.21 | 0.61 | 0.71 | 0.66 | 3 | |
| S | 9 | 6.784 | 5.85 | 0.18 | 0.43 | 0.78 | 0.65 | | |
| M | 10 | 6.909 | 12.36 | 0.29 | 0.68 | 0.84 | 0.74 | | |
| T | 11 | 6.114 | | | 0.50 | 0.72 | 0.62 | | |
| W | 12 | 6.688 | 2.92 | 0.47 | 0.41 | 0.60 | 0.49 | 3 | |
| T | 13 | 5.970 | 4.21 | 0.46 | 0.20 | 0.53 | 0.34 | | |
| F | 14 | 5.608 | 4.88 | 0.34 | 0.41 | 0.70 | 0.53 | 3 | |
| S | 15 | 5.181 | 7.88 | 0.31 | 0.70 | 1.15 | 0.93 | 3 | |
| S | 16 | 4.561 | 7.68 | 0.65 | 0.73 | 1.65 | 1.04 | | |
| M | 17 | 4.683 | 7.45 | 0.34 | 0.60 | 0.70 | 0.66 | | |
| T | 18 | 5.808 | | | 0.62 | 0.73 | 0.66 | | |
| W | 19 | 4.653 | 6.12 | 0.70 | 0.44 | 0.70 | 0.54 | | |
| T | 20 | 5.006 | 6.04 | 0.22 | 0.40 | 0.47 | 0.44 | | |
| F | 21 | 5.406 | 3.19 | 0.14 | 0.29 | 0.42 | 0.34 | 3 | |
| S | 22 | 6.866 | 1.99 | 0.24 | 0.26 | 0.44 | 0.32 | 3 | |
| S | 23 | 13.620 | 12.16 | 0.35 | 0.31 | 0.34 | 0.32 | | |
| M | 24 | 10.214 | 1.09 | 0.22 | 0.32 | 0.37 | 0.34 | | |
| T | 25 | 8.040 | | | 0.24 | 0.48 | 0.36 | | |
| W | 26 | 8.007 | 0.66 | 0.28 | 0.20 | 0.80 | 0.56 | 3 | |
| T | 27 | 7.970 | 1.40 | 0.50 | 0.35 | 1.20 | 0.77 | | |
| F | 28 | 7.274 | 1.13 | 0.80 | 0.30 | 0.58 | 0.42 | 3 | |
| AVERAGE | | 7.191 | 4.52 | 0.36 | 0.20 | 1.65 | 1.04 | 3.0 | |
| | | | 20.3 | | | | | 3.0 | |

FRANK A. NERONE

NIAGARA COUNTY SEWER DISTRICT #1
 SPDES # NY-0027979
 Mar-03

7346 LIBERTY DRIVE
 NIAGARA FALLS, NEW YORK

716-693-0001
 716-693-8759 FAX

FRANK A. Nerone, P.E.
 CERT. 4A

| DAY | DATE | FLOW | TEMPERATURE, C | | PH | | PH | | SETT SOLIDS, 1HR | | CBOD | | SUSP SOLIDS | |
|---------|------|--------|----------------|------|----------|----------|----------|----------|------------------|-----------|-----------|-----------|-------------|-----------|
| | | | INF | EFF | INF, MIN | INF, MAX | EFF, MIN | EFF, MAX | INF, mg/l | EFF, ml/l | INF, mg/l | EFF, mg/l | INF, mg/l | EFF, mg/l |
| S | 1 | 6.923 | 10.1 | 10.1 | 7.1 | 7.4 | 7.0 | 7.1 | 0.20 | <0.1 | 112.2 | 12.6 | 64 | 4.2 |
| S | 2 | 8.942 | 10.1 | 9.8 | 7.3 | 7.4 | 7.0 | 7.2 | 15.00 | <0.1 | | | 284 | 4.8 |
| M | 3 | 9.017 | 9.7 | 8.8 | 7.3 | 7.5 | 7.1 | 7.3 | 0.20 | <0.1 | | | 24 | 2.6 |
| T | 4 | 6.579 | 9.8 | 8.9 | 7.3 | 7.6 | 7.1 | 7.2 | 10.00 | <0.1 | | | 808 | 3.0 |
| W | 5 | 8.748 | 10.1 | 9.8 | 7.3 | 7.4 | 7.2 | 7.2 | 3.50 | <0.1 | 124.9 | 10.0 | 132 | 4.2 |
| T | 6 | 5.910 | 10.0 | 9.8 | 7.3 | 7.5 | 7.1 | 7.2 | 0.50 | <0.1 | 137.4 | 19.6 | 60 | 2.8 |
| F | 7 | 7.317 | 9.9 | 9.4 | 7.4 | 7.4 | 7.2 | 7.2 | 0.50 | <0.1 | 106.8 | 26.4 | 44 | 1.8 |
| S | 8 | 8.124 | 10.0 | 10.1 | 7.3 | 7.4 | 7.2 | 7.2 | 0.40 | <0.1 | 96.0 | 16.2 | 60 | 3.2 |
| S | 9 | 14.625 | 9.2 | 8.3 | 7.4 | 7.4 | 7.2 | 7.3 | 3.50 | <0.1 | | | 68 | 12.4 |
| M | 10 | 11.429 | 9.1 | 8.0 | 7.2 | 7.4 | 7.1 | 7.2 | 2.00 | <0.1 | | | 60 | 4.4 |
| T | 11 | 9.811 | 9.3 | 8.0 | 6.7 | 7.3 | 6.8 | 7.1 | 4.50 | <0.1 | | | 100 | 3.0 |
| W | 12 | 10.869 | 9.4 | 8.3 | 7.2 | 7.4 | 7.2 | 7.2 | 4.00 | <0.1 | 107.0 | 19.1 | 88 | 5.2 |
| T | 13 | 9.845 | 9.5 | 8.9 | 7.3 | 7.4 | 7.1 | 7.2 | 11.00 | <0.1 | 167.0 | 25.2 | 212 | 4.6 |
| F | 14 | 7.316 | 9.5 | 9.1 | 7.3 | 7.4 | 7.1 | 7.2 | 10.00 | <0.1 | 163.4 | 12.4 | 92 | 4.8 |
| S | 15 | 10.024 | 9.7 | 9.9 | 7.2 | 7.4 | 7.0 | 7.2 | 14.00 | <0.1 | 188.0 | 16.6 | 204 | 5.2 |
| S | 16 | 22.383 | 9.0 | 8.7 | 7.1 | 7.3 | 7.0 | 7.2 | 20.00 | <0.1 | | | 416 | 7.0 |
| M | 17 | 23.017 | 7.9 | 8.5 | 7.1 | 7.2 | 6.9 | 7.1 | 15.00 | <0.1 | | | 284 | 6.6 |
| T | 18 | 29.858 | 7.4 | 15.4 | 6.8 | 7.4 | 6.9 | 7.3 | 15.00 | <0.1 | | | 324 | 18.8 |
| W | 19 | 20.023 | 7.7 | 12.9 | 7.3 | 7.4 | 7.0 | 7.3 | 12.00 | <0.1 | 81.7 | 14.6 | 76 | 14.4 |
| T | 20 | 20.548 | 8.4 | 7.3 | 7.2 | 7.4 | 7.0 | 7.2 | 16.50 | <0.1 | 110.8 | 12.2 | 132 | 6.4 |
| F | 21 | 20.387 | 8.4 | 7.6 | 7.2 | 7.3 | 6.9 | 7.1 | 15.00 | <0.1 | 85.2 | 10.7 | 116 | 8.5 |
| S | 22 | 20.226 | 8.8 | 8.1 | 7.2 | 7.3 | 7.0 | 7.1 | 10.00 | <0.1 | 57.5 | 7.7 | 88 | 8.5 |
| S | 23 | 17.356 | 8.8 | 8.2 | 7.2 | 7.3 | 7.1 | 7.2 | 12.00 | <0.1 | | | 100 | 7.0 |
| M | 24 | 13.664 | 9.0 | 9.1 | 7.1 | 7.2 | 7.1 | 7.2 | 11.00 | <0.1 | | | 100 | 3.6 |
| T | 25 | 12.450 | 9.3 | 9.3 | 7.2 | 7.5 | 7.1 | 7.3 | 30.00 | <0.1 | | | 532 | 3.2 |
| W | 26 | 12.964 | 9.3 | 9.6 | 7.3 | 7.4 | 7.1 | 7.2 | 3.00 | <0.1 | 96.1 | 14.1 | 80 | 5.0 |
| T | 27 | 9.337 | 9.7 | 9.6 | 7.1 | 7.6 | 7.0 | 7.4 | 1.50 | <0.1 | 91.8 | 17.4 | 84 | 5.6 |
| F | 28 | 10.347 | 10.0 | 9.8 | 7.2 | 7.3 | 6.9 | 7.1 | 1.00 | <0.1 | 66.0 | 13.7 | 112 | 8.8 |
| S | 29 | 10.169 | 10.3 | 10.5 | 7.1 | 7.3 | 6.9 | 7.0 | 0.50 | <0.1 | 160.3 | 14.4 | 560 | 4.6 |
| S | 30 | 10.628 | 9.8 | 9.9 | 7.0 | 7.3 | 7.1 | 7.3 | 0.50 | <0.1 | | | 40 | 4.0 |
| M | 31 | 9.515 | 9.9 | 9.4 | 7.2 | 7.5 | 7.0 | 7.1 | 15.00 | <0.1 | | | 200 | 2.8 |
| AVERAGE | | 12.850 | 9.3 | 9.4 | 6.7 | 7.6 | 6.8 | 7.4 | 30.0 | 0.0 | 107.3 | 14.5 | 185.0 | 7.1 |
| Monthly | | ave. | ave. | ave. | min | max | min | max | max | max | 86.5% | 1412.5 | 96.2% | 760.6 |

NIAGARA COUNTY SEWER DISTRICT #1

Mar-03

| DAY | DATE | FLOW | PHOSPHOROUS | | | CHLORINE RESIDUAL | | | F. COLI / 100 ml | COMMENTS |
|---------|------|--------|-------------|----------|----------|-------------------|----------|-------|------------------|----------|
| | | | INF,mg/l | EFF,mg/l | MIN,mg/l | MAX,mg/l | AVE,mg/l | | | |
| S | 1 | 6.923 | 1.01 | 0.45 | 0.34 | 0.58 | 0.45 | 9 | | |
| S | 2 | 8.942 | 2.76 | 0.44 | 0.45 | 0.46 | 0.45 | | | |
| M | 3 | 9.017 | 1.01 | 0.47 | 0.34 | 0.42 | 0.37 | | | |
| T | 4 | 6.579 | | | 0.17 | 0.32 | 0.27 | | | |
| W | 5 | 8.748 | 1.99 | 0.60 | 0.20 | 0.54 | 0.35 | 36 | | |
| T | 6 | 5.910 | 1.68 | 0.80 | 0.12 | 0.48 | 0.35 | 3 | | |
| F | 7 | 7.317 | 1.44 | 0.66 | 0.28 | 0.34 | 0.31 | 3 | | |
| S | 8 | 8.124 | 1.83 | 0.72 | 0.41 | 0.50 | 0.45 | | | |
| S | 9 | 14.625 | 2.44 | 0.80 | 0.42 | 0.59 | 0.48 | | | |
| M | 10 | 11.429 | 2.16 | 0.48 | 0.77 | 1.22 | 0.92 | | | |
| T | 11 | 9.811 | | | 0.42 | 1.45 | 0.89 | | | |
| W | 12 | 10.869 | 3.60 | 0.56 | 0.24 | 1.22 | 0.70 | 55 | | |
| T | 13 | 9.845 | 6.56 | 0.43 | 0.38 | 0.47 | 0.44 | | | |
| F | 14 | 7.316 | 2.76 | 0.31 | 0.35 | 1.20 | 0.72 | 3 | | |
| S | 15 | 10.024 | 5.00 | 0.23 | 0.39 | 0.62 | 0.53 | 28 | | |
| S | 16 | 22.383 | 7.76 | 0.30 | 0.62 | 1.03 | 0.84 | | | |
| M | 17 | 23.017 | 6.52 | 0.46 | 0.79 | 1.01 | 0.90 | | | |
| T | 18 | 29.858 | | | 0.44 | 0.60 | 0.52 | | | |
| W | 19 | 20.023 | 1.72 | 0.47 | 0.19 | 0.87 | 0.54 | 760 | | |
| T | 20 | 20.548 | 7.92 | 0.36 | 0.91 | 0.95 | 0.93 | | | |
| F | 21 | 20.387 | 25.20 | 0.35 | 0.60 | 0.74 | 0.67 | 25 | | |
| S | 22 | 20.226 | 1.48 | 0.21 | 0.86 | 1.09 | 0.97 | 3417 | | |
| S | 23 | 17.356 | 1.12 | 0.22 | 0.78 | 1.09 | 0.96 | | | |
| M | 24 | 13.664 | 2.12 | 0.19 | 0.36 | 1.05 | 0.74 | | | |
| T | 25 | 12.450 | | | 0.34 | 0.56 | 0.46 | | | |
| W | 26 | 12.964 | 2.60 | 0.28 | 0.49 | 0.76 | 0.63 | | | |
| T | 27 | 9.337 | 1.60 | 0.09 | 0.40 | 0.55 | 0.47 | | | |
| F | 28 | 10.347 | 1.72 | 0.21 | 0.40 | 0.60 | 0.49 | 45 | | |
| S | 29 | 10.169 | 1.96 | 0.22 | 0.35 | 0.45 | 0.40 | 440 | | |
| S | 30 | 10.628 | 1.20 | 0.12 | 0.34 | 0.55 | 0.47 | | | |
| M | 31 | 9.515 | 4.04 | 0.16 | 0.47 | 0.67 | 0.58 | | | |
| AVERAGE | | 12.850 | 4.89 | 0.39 | 0.12 | 1.45 | 0.97 | 40.0 | | |
| | | | | 41.8 | | | | 401.9 | | |

Appendix E
Phosphorus Summary
(Demonstration Project Sampling Results)

NIAGARA COUNTY SEWER DISTRICT #1

DECEMBER 04 FILTER DATA

| DATE Month/Day | PHOSPHORUS | | | SUSPENDED SOLIDS | | | BOD | |
|-------------------|-------------|-------------|-------------|------------------|-------------|------------|--------------|---------------|
| | Influent | Filter Feed | Effluent | Influent | Filter Feed | Effluent | Influent | Effluent |
| 12/10 | 16.21 | 0.44 | 0.25 | 1012 | 4.8 | 2.2 | >368 | <3 |
| 12/11 | 3.97 | 0.52 | 0.30 | 152 | 10.8 | 1.2 | 126.3 | <3 |
| 12/12 | 19.69 | 0.36 | <.24 | 856 | 18.0 | 2.3 | NO SET UP | |
| 12/13 | 7.5 | 0.40 | <.24 | 344 | 10.8 | 2.6 | NO SET UP | |
| 12/14 | - | 0.42 | - | 188 | 10.4 | 2.4 | NO SET UP | |
| 12/15 | 1.67 | 0.41 | <.24 | 140 | 7.2 | 1.4 | 89.1 | <3 |
| 12/16 | 5.96 | 0.46 | 0.31 | 296 | 7.2 | 1.0 | 132.0 | <3 |
| Average | 9.17 | 0.43 | 0.26 | 427 | 9.9 | 1.9 | 178.9 | < 3 |

For information on other
NYSERDA reports, contact:

New York State Energy Research
and Development Authority
17 Columbia Circle
Albany, New York 12203-6399

toll free: 1 (866) NYSERDA
local: (518) 862-1090
fax: (518) 862-1091

info@nysesda.org
www.nysesda.org

PRIMARY EFFLUENT FILTRATION

FINAL REPORT 05-08

STATE OF NEW YORK
GEORGE E. PATAKI, GOVERNOR

NEW YORK STATE ENERGY RESEARCH AND DEVELOPMENT AUTHORITY
VINCENT A. DEIORIO, ESQ., CHAIRMAN
PETER R. SMITH, PRESIDENT

NYSERDA

